

CHANGES TO DRAWINGS:

Drawing CS-003	Updated Lower Level and First Floor Egress Plans
Drawings A-001	Updated contractor work area and fencing.
Drawing D-101A	Updated demolition drawing
Drawing A-101B	Updated floor plan
Drawing A-205	Updated Scene Shop Sections
Drawing A-730	Updated Detail
Drawing A-906	Updated Finish Schedule
Drawing MD-101B	Refer to revised drawing MD-101B for revisions to remove the transfer grilles to the kitchen.
Drawing M-101B	Refer to revised drawing M-101B for revisions to replace the removed transfer grilles to the kitchen with new including new fire dampers thru the fire rated wall.
Drawing M-502	Refer to revised drawing M-502 for revisions to both the Network Tree & to the aplit air handling unit control diagram.
Drawing DFP-100B	Refer to revised drawing DFP-100B for updated fire protection demo.
Drawing FP-100B	Refer to revised drawing FP-100B for updated fire protection piping.
Drawing FP-201	Refer to revised drawing FP-201 for an updated detail 3, Fire Service Riser.

CHANGES TO SPECIFICATIONS:

Section 011000	Added Section 1.5.G to the specification
Section 078100	Updated Specification Section 078100
Section 210000	Section 210000 1.4.A.1 shall be changed to the following: Modify existing fire protection service/piping to include new fire pump and cover renovated sections of building as shown on contract drawings.
Section 230900	Section 230900 1.1.A.1 shall be changed to the following: This Section includes control equipment for HVAC systems and components, including control components for terminal units not supplied with factory-wired controls. This Section includes the Building Management System (BMS) control equipment for HVAC systems and

components, including open protocol control components for terminal heating and cooling units. It's the intent of this specification to have the controls contractor furnish a Siemens Desigo integrated building automation system. Each piece of equipment will have its own application specific controller (By ATC or unit manufacturer as noted in plans and specifications and network room sensor wired to a single web accessible enterprise network controller (ENC) including new computer workstation with graphical user interface software.

Section 230900

Section 230900 2.1.A shall be changed to the following:

- A. Manufacturers: Subject to compliance with requirements, provide products by one of the following:
 - a. Siemens Desigo. John Radetich: john.radetich@siemens.com
1-215-206-4594
 - b. Approved Equal

END OF ADDENDUM NO. 1