

# Client Sample Results

Client: Pennoni Associates, Inc.  
Project/Site: Rowan Univ. RCFM1614

TestAmerica Job ID: 460-128893-1

## Client Sample ID: PbCAS01C

Date Collected: 02/23/17 08:17

Date Received: 02/23/17 19:05

## Lab Sample ID: 460-128893-3

Matrix: Water

### Method: 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	445		2.0	0.16	ug/L	—		02/24/17 12:17	1

## Client Sample ID: PbCAS01D

Date Collected: 02/23/17 08:18

Date Received: 02/23/17 19:05

## Lab Sample ID: 460-128893-4

Matrix: Water

### Method: 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	88.8		2.0	0.16	ug/L	—		02/24/17 12:20	1

## Client Sample ID: PbCAS11C

Date Collected: 02/23/17 08:28

Date Received: 02/23/17 19:05

## Lab Sample ID: 460-128893-5

Matrix: Water

### Method: 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	4.3		2.0	0.16	ug/L	—		02/24/17 12:29	1

## Client Sample ID: PbCAS11D

Date Collected: 02/23/17 08:29

Date Received: 02/23/17 19:05

## Lab Sample ID: 460-128893-6

Matrix: Water

### Method: 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	1.2	J	2.0	0.16	ug/L	—		02/24/17 12:32	1