

Client Sample Results

Client: Pennoni Associates, Inc.
Project/Site: Rowan Univ. RCFM1614

TestAmerica Job ID: 460-126163-1

Client Sample ID: PbEPA2-01A

Date Collected: 12/29/16 10:11

Date Received: 12/29/16 18:15

Lab Sample ID: 460-126163-1

Matrix: Water

Method: 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	5.0		2.0	0.16	ug/L	—		01/04/17 20:42	1

Client Sample ID: PbEPA2-01B

Date Collected: 12/29/16 10:12

Date Received: 12/29/16 18:15

Lab Sample ID: 460-126163-2

Matrix: Water

Method: 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	2.4		2.0	0.16	ug/L	—		01/04/17 20:44	1

Client Sample ID: PbEPA2-02A

Date Collected: 12/29/16 10:41

Date Received: 12/29/16 18:15

Lab Sample ID: 460-126163-3

Matrix: Water

Method: 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	2.3		2.0	0.16	ug/L	—		01/04/17 20:36	1

Client Sample ID: PbEPA2-02B

Date Collected: 12/29/16 10:41

Date Received: 12/29/16 18:15

Lab Sample ID: 460-126163-4

Matrix: Water

Method: 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	5.3		2.0	0.16	ug/L	—		01/04/17 22:16	1

Client Sample ID: PbEPA2-03A

Date Collected: 12/29/16 10:43

Date Received: 12/29/16 18:15

Lab Sample ID: 460-126163-5

Matrix: Water

Method: 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	1.5	J	2.0	0.16	ug/L	—		01/04/17 22:19	1

Client Sample ID: PbEPA2-03B

Date Collected: 12/29/16 10:44

Date Received: 12/29/16 18:15

Lab Sample ID: 460-126163-6

Matrix: Water

Method: 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	1.1	J	2.0	0.16	ug/L	—		01/04/17 22:22	1

Client Sample ID: PbEPA2-04A

Date Collected: 12/29/16 10:42

Date Received: 12/29/16 18:15

Lab Sample ID: 460-126163-7

Matrix: Water

Method: 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	1.6	J	2.0	0.16	ug/L	—		01/04/17 22:25	1

Client Sample Results

Client: Pennoni Associates, Inc.
Project/Site: Rowan Univ. RCFM1614

TestAmerica Job ID: 460-126163-1

Client Sample ID: PbEPA2-04B

Date Collected: 12/29/16 10:42

Date Received: 12/29/16 18:15

Lab Sample ID: 460-126163-8

Matrix: Water

Method: 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	2.0		2.0	0.16	ug/L	—		01/04/17 22:27	1

Client Sample ID: PbEPA2-05A

Date Collected: 12/29/16 10:41

Date Received: 12/29/16 18:15

Lab Sample ID: 460-126163-9

Matrix: Water

Method: 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	1.6	J	2.0	0.16	ug/L	—		01/04/17 22:30	1

Client Sample ID: PbEPA2-05B

Date Collected: 12/29/16 10:41

Date Received: 12/29/16 18:15

Lab Sample ID: 460-126163-10

Matrix: Water

Method: 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	4.8		2.0	0.16	ug/L	—	01/05/17 11:32	01/06/17 12:37	1

Client Sample ID: PbEPA2-06A

Date Collected: 12/29/16 10:47

Date Received: 12/29/16 18:15

Lab Sample ID: 460-126163-11

Matrix: Water

Method: 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	1.9	J	2.0	0.16	ug/L	—		01/04/17 22:36	1

Client Sample ID: PbEPA2-06B

Date Collected: 12/29/16 10:48

Date Received: 12/29/16 18:15

Lab Sample ID: 460-126163-12

Matrix: Water

Method: 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	1.1	J	2.0	0.16	ug/L	—		01/04/17 22:51	1

Client Sample ID: PbEPA2-07A

Date Collected: 12/29/16 10:47

Date Received: 12/29/16 18:15

Lab Sample ID: 460-126163-13

Matrix: Water

Method: 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	4.1		2.0	0.16	ug/L	—		01/04/17 22:53	1

Client Sample ID: PbEPA2-07B

Date Collected: 12/29/16 10:48

Date Received: 12/29/16 18:15

Lab Sample ID: 460-126163-14

Matrix: Water

Method: 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	0.49	J	2.0	0.16	ug/L	—		01/04/17 22:56	1

Client Sample Results

Client: Pennoni Associates, Inc.
Project/Site: Rowan Univ. RCFM1614

TestAmerica Job ID: 460-126163-1

Client Sample ID: PbEPA2-08A

Date Collected: 12/29/16 10:50

Date Received: 12/29/16 18:15

Lab Sample ID: 460-126163-15

Matrix: Water

Method: 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	2.5		2.0	0.16	ug/L	—		01/04/17 22:59	1

Client Sample ID: PbEPA2-08B

Date Collected: 12/29/16 10:51

Date Received: 12/29/16 18:15

Lab Sample ID: 460-126163-16

Matrix: Water

Method: 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	4.2		2.0	0.16	ug/L	—		01/04/17 23:02	1

Client Sample ID: PbEPA2-09A

Date Collected: 12/29/16 10:50

Date Received: 12/29/16 18:15

Lab Sample ID: 460-126163-17

Matrix: Water

Method: 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	3.5		2.0	0.16	ug/L	—		01/04/17 23:05	1

Client Sample ID: PbEPA2-09B

Date Collected: 12/29/16 10:51

Date Received: 12/29/16 18:15

Lab Sample ID: 460-126163-18

Matrix: Water

Method: 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	3.9		2.0	0.16	ug/L	—		01/04/17 23:08	1

Client Sample ID: PbEPA2-10A

Date Collected: 12/29/16 10:55

Date Received: 12/29/16 18:15

Lab Sample ID: 460-126163-19

Matrix: Water

Method: 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	1.9	J	2.0	0.16	ug/L	—		01/04/17 23:11	1

Client Sample ID: PbEPA2-10B

Date Collected: 12/29/16 10:56

Date Received: 12/29/16 18:15

Lab Sample ID: 460-126163-20

Matrix: Water

Method: 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	0.58	J	2.0	0.16	ug/L	—		01/04/17 23:14	1

Client Sample ID: PbEPA2-11A

Date Collected: 12/29/16 10:56

Date Received: 12/29/16 18:15

Lab Sample ID: 460-126163-21

Matrix: Water

Method: 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	1.5	J	2.0	0.16	ug/L	—		01/04/17 22:33	1

TestAmerica Edison

Client Sample Results

Client: Pennoni Associates, Inc.
Project/Site: Rowan Univ. RCFM1614

TestAmerica Job ID: 460-126163-1

Client Sample ID: PbEPA2-11B

Lab Sample ID: 460-126163-22

Date Collected: 12/29/16 10:56

Matrix: Water

Date Received: 12/29/16 18:15

Method: 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	0.18	J	2.0	0.16	ug/L	—		01/05/17 18:38	1

Client Sample ID: PbEPA2-12A

Lab Sample ID: 460-126163-23

Date Collected: 12/29/16 10:58

Matrix: Water

Date Received: 12/29/16 18:15

Method: 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	2.2		2.0	0.16	ug/L	—		01/05/17 18:41	1

Client Sample ID: PbEPA2-12B

Lab Sample ID: 460-126163-24

Date Collected: 12/29/16 10:59

Matrix: Water

Date Received: 12/29/16 18:15

Method: 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	21.0		2.0	0.16	ug/L	—		01/05/17 18:32	1

Client Sample ID: PbEPA2-13A

Lab Sample ID: 460-126163-25

Date Collected: 12/29/16 10:58

Matrix: Water

Date Received: 12/29/16 18:15

Method: 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	6.1		2.0	0.16	ug/L	—		01/05/17 18:49	1

Client Sample ID: PbEPA2-13B

Lab Sample ID: 460-126163-26

Date Collected: 12/29/16 10:59

Matrix: Water

Date Received: 12/29/16 18:15

Method: 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	1.5	J	2.0	0.16	ug/L	—		01/05/17 18:52	1

Client Sample ID: PbEPA2-14A

Lab Sample ID: 460-126163-27

Date Collected: 12/29/16 10:13

Matrix: Water

Date Received: 12/29/16 18:15

Method: 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	0.90	J	2.0	0.16	ug/L	—		01/05/17 18:55	1

Client Sample ID: PbEPA2-14B

Lab Sample ID: 460-126163-28

Date Collected: 12/29/16 10:14

Matrix: Water

Date Received: 12/29/16 18:15

Method: 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	3.5		2.0	0.16	ug/L	—		01/05/17 18:58	1

Client Sample Results

Client: Pennoni Associates, Inc.
Project/Site: Rowan Univ. RCFM1614

TestAmerica Job ID: 460-126163-1

Client Sample ID: PbEPA2-15A

Date Collected: 12/29/16 10:15

Date Received: 12/29/16 18:15

Lab Sample ID: 460-126163-29

Matrix: Water

Method: 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	2.4		2.0	0.16	ug/L	—		01/05/17 19:01	1

Client Sample ID: PbEPA2-15B

Date Collected: 12/29/16 10:16

Date Received: 12/29/16 18:15

Lab Sample ID: 460-126163-30

Matrix: Water

Method: 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	3.0		2.0	0.16	ug/L	—		01/05/17 19:04	1

Client Sample ID: PbEPA2-16A

Date Collected: 12/29/16 10:14

Date Received: 12/29/16 18:15

Lab Sample ID: 460-126163-31

Matrix: Water

Method: 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	2.7		2.0	0.16	ug/L	—		01/05/17 19:07	1

Client Sample ID: PbEPA2-16B

Date Collected: 12/29/16 10:15

Date Received: 12/29/16 18:15

Lab Sample ID: 460-126163-32

Matrix: Water

Method: 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	1.4	J	2.0	0.16	ug/L	—		01/05/17 19:10	1

Client Sample ID: PbEPA2-17A

Date Collected: 12/29/16 10:12

Date Received: 12/29/16 18:15

Lab Sample ID: 460-126163-33

Matrix: Water

Method: 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	0.98	J	2.0	0.16	ug/L	—		01/05/17 19:12	1

Client Sample ID: PbEPA2-17B

Date Collected: 12/29/16 10:13

Date Received: 12/29/16 18:15

Lab Sample ID: 460-126163-34

Matrix: Water

Method: 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	3.5		2.0	0.16	ug/L	—		01/05/17 19:15	1

Client Sample ID: PbEPA2-18A

Date Collected: 12/29/16 10:22

Date Received: 12/29/16 18:15

Lab Sample ID: 460-126163-35

Matrix: Water

Method: 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	2.2		2.0	0.16	ug/L	—		01/05/17 19:24	1

Client Sample Results

Client: Pennoni Associates, Inc.
Project/Site: Rowan Univ. RCFM1614

TestAmerica Job ID: 460-126163-1

Client Sample ID: PbEPA2-18B

Date Collected: 12/29/16 10:23

Date Received: 12/29/16 18:15

Lab Sample ID: 460-126163-36

Matrix: Water

Method: 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	5.6		2.0	0.16	ug/L	—		01/05/17 19:33	1

Client Sample ID: PbEPA2-19A

Date Collected: 12/29/16 10:24

Date Received: 12/29/16 18:15

Lab Sample ID: 460-126163-37

Matrix: Water

Method: 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	2.7		2.0	0.16	ug/L	—		01/05/17 19:36	1

Client Sample ID: PbEPA2-19B

Date Collected: 12/29/16 10:25

Date Received: 12/29/16 18:15

Lab Sample ID: 460-126163-38

Matrix: Water

Method: 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	2.0		2.0	0.16	ug/L	—		01/05/17 19:38	1

Client Sample ID: PbEPA2-20A

Date Collected: 12/29/16 10:22

Date Received: 12/29/16 18:15

Lab Sample ID: 460-126163-39

Matrix: Water

Method: 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	1.4	J	2.0	0.16	ug/L	—		01/05/17 19:41	1

Client Sample ID: PbEPA2-20B

Date Collected: 12/29/16 10:23

Date Received: 12/29/16 18:15

Lab Sample ID: 460-126163-40

Matrix: Water

Method: 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	0.82	J	2.0	0.16	ug/L	—		01/05/17 19:44	1

Client Sample ID: PbEPA2-21A

Date Collected: 12/29/16 10:24

Date Received: 12/29/16 18:15

Lab Sample ID: 460-126163-41

Matrix: Water

Method: 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	2.2		2.0	0.16	ug/L	—		01/05/17 19:47	1

Client Sample ID: PbEPA2-21B

Date Collected: 12/29/16 10:25

Date Received: 12/29/16 18:15

Lab Sample ID: 460-126163-42

Matrix: Water

Method: 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	0.70	J	2.0	0.16	ug/L	—		01/05/17 01:27	1

Client Sample Results

Client: Pennoni Associates, Inc.
Project/Site: Rowan Univ. RCFM1614

TestAmerica Job ID: 460-126163-1

Client Sample ID: PbEPA2-22A

Date Collected: 12/29/16 10:32

Date Received: 12/29/16 18:15

Lab Sample ID: 460-126163-43

Matrix: Water

Method: 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	2.8		2.0	0.16	ug/L	—		01/05/17 01:30	1

Client Sample ID: PbEPA2-22B

Date Collected: 12/29/16 10:33

Date Received: 12/29/16 18:15

Lab Sample ID: 460-126163-44

Matrix: Water

Method: 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	3.3		2.0	0.16	ug/L	—		01/05/17 01:38	1

Client Sample ID: PbEPA2-23A

Date Collected: 12/29/16 10:34

Date Received: 12/29/16 18:15

Lab Sample ID: 460-126163-45

Matrix: Water

Method: 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	2.7		2.0	0.16	ug/L	—		01/05/17 01:21	1

Client Sample ID: PbEPA2-23B

Date Collected: 12/29/16 10:34

Date Received: 12/29/16 18:15

Lab Sample ID: 460-126163-46

Matrix: Water

Method: 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	2.6		2.0	0.16	ug/L	—		01/05/17 01:41	1

Client Sample ID: PbEPA2-24A

Date Collected: 12/29/16 10:32

Date Received: 12/29/16 18:15

Lab Sample ID: 460-126163-47

Matrix: Water

Method: 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	2.3		2.0	0.16	ug/L	—		01/05/17 01:44	1

Client Sample ID: PbEPA2-24B

Date Collected: 12/29/16 10:33

Date Received: 12/29/16 18:15

Lab Sample ID: 460-126163-48

Matrix: Water

Method: 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	0.53	J	2.0	0.16	ug/L	—		01/05/17 01:47	1

Client Sample ID: PbEPA2-25A

Date Collected: 12/29/16 10:30

Date Received: 12/29/16 18:15

Lab Sample ID: 460-126163-49

Matrix: Water

Method: 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	3.6		2.0	0.16	ug/L	—		01/05/17 01:50	1

Client Sample Results

Client: Pennoni Associates, Inc.
Project/Site: Rowan Univ. RCFM1614

TestAmerica Job ID: 460-126163-1

Client Sample ID: PbEPA2-25B

Lab Sample ID: 460-126163-50

Date Collected: 12/29/16 10:31

Matrix: Water

Date Received: 12/29/16 18:15

Method: 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	1.2	J	2.0	0.16	ug/L			01/05/17 01:53	1