

Client Sample Results

Client: Pennoni Associates, Inc.
Project/Site: Rowan Univ. RCFM1614

TestAmerica Job ID: 460-138162-1

Client Sample ID: PBEP A5-12E

Date Collected: 07/28/17 08:37

Date Received: 07/28/17 21:00

Lab Sample ID: 460-138162-41

Matrix: Water

Method: 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	0.77	J	2.0	0.16	ug/L			08/02/17 09:34	1

Client Sample ID: PBEP A5-12F

Date Collected: 07/28/17 08:38

Date Received: 07/28/17 21:00

Lab Sample ID: 460-138162-42

Matrix: Water

Method: 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	0.16	U	2.0	0.16	ug/L			08/02/17 09:37	1

TestAmerica Edison

Client Sample Results

Client: Pennoni Associates, Inc.
Project/Site: Rowan Univ. RCFM1614

TestAmerica Job ID: 460-138162-1

Client Sample ID: PBEP A5-16E

Lab Sample ID: 460-138162-43

Date Collected: 07/28/17 08:41

Matrix: Water

Date Received: 07/28/17 21:00

Method: 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	0.60	J	2.0	0.16	ug/L			08/02/17 09:47	1

Client Sample ID: PBEP A5-16F

Lab Sample ID: 460-138162-44

Date Collected: 07/28/17 08:42

Matrix: Water

Date Received: 07/28/17 21:00

Method: 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	0.16	U	2.0	0.16	ug/L			08/02/17 09:50	1

Client Sample ID: PBEP A5-21E

Lab Sample ID: 460-138162-45

Date Collected: 07/28/17 08:44

Matrix: Water

Date Received: 07/28/17 21:00

Method: 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	12.1		2.0	0.16	ug/L			08/02/17 09:53	1

Client Sample ID: PBEP A5-21F

Lab Sample ID: 460-138162-46

Date Collected: 07/28/17 08:45

Matrix: Water

Date Received: 07/28/17 21:00

Method: 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	0.16	U	2.0	0.16	ug/L			08/02/17 09:56	1