

Client Sample Results

Client: Pennoni Associates, Inc.
Project/Site: Rowan Univ. RCFM1614

TestAmerica Job ID: 460-126211-1

Client Sample ID: PbHPC01A

Date Collected: 12/30/16 09:41

Date Received: 12/30/16 16:30

Lab Sample ID: 460-126211-11

Matrix: Water

Method: 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	35.7		2.0	0.16	ug/L	—		01/11/17 14:29	1

Client Sample ID: PbHPC01B

Date Collected: 12/30/16 09:43

Date Received: 12/30/16 16:30

Lab Sample ID: 460-126211-12

Matrix: Water

Method: 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	7.0		2.0	0.16	ug/L	—		01/11/17 14:34	1

Client Sample ID: PbHPC02A

Date Collected: 12/30/16 10:23

Date Received: 12/30/16 16:30

Lab Sample ID: 460-126211-13

Matrix: Water

Method: 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	1.0	J	2.0	0.16	ug/L	—		01/11/17 14:36	1

Client Sample ID: PbHPC02B

Date Collected: 12/30/16 10:24

Date Received: 12/30/16 16:30

Lab Sample ID: 460-126211-14

Matrix: Water

Method: 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	1.6	J	2.0	0.16	ug/L	—		01/11/17 14:38	1

Client Sample Results

Client: Pennoni Associates, Inc.
Project/Site: Rowan Univ. RCFM1614

TestAmerica Job ID: 460-126211-1

Client Sample ID: PbHPC03A

Date Collected: 12/30/16 10:21

Date Received: 12/30/16 16:30

Lab Sample ID: 460-126211-15

Matrix: Water

Method: 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	2.8		2.0	0.16	ug/L		01/05/17 12:47	01/06/17 12:46	1

Client Sample ID: PbHPC03B

Date Collected: 12/30/16 10:36

Date Received: 12/30/16 16:30

Lab Sample ID: 460-126211-16

Matrix: Water

Method: 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	0.16	U	2.0	0.16	ug/L			01/11/17 14:40	1

Client Sample ID: PbHPC04A

Date Collected: 12/30/16 10:30

Date Received: 12/30/16 16:30

Lab Sample ID: 460-126211-17

Matrix: Water

Method: 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	1.2	J	2.0	0.16	ug/L			01/11/17 14:42	1

Client Sample ID: PbHPC04B

Date Collected: 12/30/16 10:31

Date Received: 12/30/16 16:30

Lab Sample ID: 460-126211-18

Matrix: Water

Method: 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	0.57	J	2.0	0.16	ug/L			01/11/17 14:44	1

Client Sample ID: PbHPC05A

Date Collected: 12/30/16 10:28

Date Received: 12/30/16 16:30

Lab Sample ID: 460-126211-19

Matrix: Water

Method: 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	2.0		2.0	0.16	ug/L			01/11/17 14:46	1

Client Sample ID: PbHPC05B

Date Collected: 12/30/16 10:29

Date Received: 12/30/16 16:30

Lab Sample ID: 460-126211-20

Matrix: Water

Method: 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	0.85	J	2.0	0.16	ug/L			01/11/17 14:48	1

Client Sample ID: PbHPC06A

Date Collected: 12/30/16 10:37

Date Received: 12/30/16 16:30

Lab Sample ID: 460-126211-21

Matrix: Water

Method: 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	0.95	J	2.0	0.16	ug/L			01/11/17 14:50	1

Client Sample Results

Client: Pennoni Associates, Inc.
Project/Site: Rowan Univ. RCFM1614

TestAmerica Job ID: 460-126211-1

Client Sample ID: PbHPC06B

Date Collected: 12/30/16 10:52

Date Received: 12/30/16 16:30

Lab Sample ID: 460-126211-22

Matrix: Water

Method: 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	0.22	J	2.0	0.16	ug/L	—		01/11/17 15:27	1

Client Sample ID: PbHPC07A

Date Collected: 12/30/16 10:42

Date Received: 12/30/16 16:30

Lab Sample ID: 460-126211-23

Matrix: Water

Method: 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	8.8		2.0	0.16	ug/L	—		01/11/17 15:40	1

Client Sample ID: PbHPC07B

Date Collected: 12/30/16 10:43

Date Received: 12/30/16 16:30

Lab Sample ID: 460-126211-24

Matrix: Water

Method: 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	1.5	J	2.0	0.16	ug/L	—		01/11/17 15:42	1

Client Sample ID: PbHPC08A

Date Collected: 12/30/16 10:41

Date Received: 12/30/16 16:30

Lab Sample ID: 460-126211-25

Matrix: Water

Method: 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	0.17	J	2.0	0.16	ug/L	—		01/11/17 15:31	1

Client Sample ID: PbHPC08B

Date Collected: 12/30/16 10:56

Date Received: 12/30/16 16:30

Lab Sample ID: 460-126211-26

Matrix: Water

Method: 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	0.17	J	2.0	0.16	ug/L	—		01/11/17 15:44	1

Client Sample ID: PbHPC09A

Date Collected: 12/30/16 10:39

Date Received: 12/30/16 16:30

Lab Sample ID: 460-126211-27

Matrix: Water

Method: 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	2.6		2.0	0.16	ug/L	—		01/11/17 15:46	1

Client Sample ID: PbHPC09B

Date Collected: 12/30/16 10:40

Date Received: 12/30/16 16:30

Lab Sample ID: 460-126211-28

Matrix: Water

Method: 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	1.6	J	2.0	0.16	ug/L	—		01/11/17 15:48	1

Client Sample Results

Client: Pennoni Associates, Inc.
Project/Site: Rowan Univ. RCFM1614

TestAmerica Job ID: 460-126211-1

Client Sample ID: PbHPC10A

Date Collected: 12/30/16 10:53

Date Received: 12/30/16 16:30

Lab Sample ID: 460-126211-29

Matrix: Water

Method: 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	0.27	J	2.0	0.16	ug/L	—		01/11/17 15:50	1

Client Sample ID: PbHPC10B

Date Collected: 12/30/16 11:08

Date Received: 12/30/16 16:30

Lab Sample ID: 460-126211-30

Matrix: Water

Method: 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	0.16	U	2.0	0.16	ug/L	—		01/11/17 15:52	1

Client Sample ID: PbHPC11A

Date Collected: 12/30/16 10:35

Date Received: 12/30/16 16:30

Lab Sample ID: 460-126211-31

Matrix: Water

Method: 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	0.85	J	2.0	0.16	ug/L	—		01/11/17 15:53	1

Client Sample ID: PbHPC11B

Date Collected: 12/30/16 10:36

Date Received: 12/30/16 16:30

Lab Sample ID: 460-126211-32

Matrix: Water

Method: 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	0.26	J	2.0	0.16	ug/L	—		01/11/17 15:55	1

Client Sample ID: PbHPC12A

Date Collected: 12/30/16 09:46

Date Received: 12/30/16 16:30

Lab Sample ID: 460-126211-33

Matrix: Water

Method: 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	0.16	U	2.0	0.16	ug/L	—		01/11/17 16:01	1

Client Sample ID: PbHPC12B

Date Collected: 12/30/16 09:47

Date Received: 12/30/16 16:30

Lab Sample ID: 460-126211-34

Matrix: Water

Method: 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	0.16	J	2.0	0.16	ug/L	—		01/11/17 16:03	1

Client Sample ID: PbHPC13A

Date Collected: 12/30/16 09:48

Date Received: 12/30/16 16:30

Lab Sample ID: 460-126211-35

Matrix: Water

Method: 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	2.4		2.0	0.16	ug/L	—		01/11/17 16:05	1

Client Sample Results

Client: Pennoni Associates, Inc.
Project/Site: Rowan Univ. RCFM1614

TestAmerica Job ID: 460-126211-1

Client Sample ID: PbHPC13B

Date Collected: 12/30/16 09:49

Date Received: 12/30/16 16:30

Lab Sample ID: 460-126211-36

Matrix: Water

Method: 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	2.5		2.0	0.16	ug/L	—		01/11/17 16:07	1

Client Sample ID: PbHPC14A

Date Collected: 12/30/16 09:50

Date Received: 12/30/16 16:30

Lab Sample ID: 460-126211-37

Matrix: Water

Method: 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	11.9		2.0	0.16	ug/L	—	01/05/17 12:47	01/12/17 13:26	1

Client Sample ID: PbHPC14B

Date Collected: 12/30/16 09:51

Date Received: 12/30/16 16:30

Lab Sample ID: 460-126211-38

Matrix: Water

Method: 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	3.2		2.0	0.16	ug/L	—		01/11/17 16:09	1

Client Sample ID: PbHPC15A

Date Collected: 12/30/16 09:53

Date Received: 12/30/16 16:30

Lab Sample ID: 460-126211-39

Matrix: Water

Method: 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	0.31	J	2.0	0.16	ug/L	—	01/05/17 12:47	01/06/17 12:50	1

Client Sample ID: PbHPC15B

Date Collected: 12/30/16 09:53

Date Received: 12/30/16 16:30

Lab Sample ID: 460-126211-40

Matrix: Water

Method: 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	1.3	J	2.0	0.16	ug/L	—	01/05/17 12:47	01/06/17 12:52	1

Client Sample ID: PbHPC16A

Date Collected: 12/30/16 10:08

Date Received: 12/30/16 16:30

Lab Sample ID: 460-126211-41

Matrix: Water

Method: 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	550		2.0	0.16	ug/L	—	01/05/17 12:47	01/06/17 12:57	1

Client Sample ID: PbHPC16B

Date Collected: 12/30/16 10:09

Date Received: 12/30/16 16:30

Lab Sample ID: 460-126211-42

Matrix: Water

Method: 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	39.7		2.0	0.16	ug/L	—		01/11/17 16:10	1

Client Sample Results

Client: Pennoni Associates, Inc.
Project/Site: Rowan Univ. RCFM1614

TestAmerica Job ID: 460-126211-1

Client Sample ID: PbHPC17A

Date Collected: 12/30/16 09:56

Date Received: 12/30/16 16:30

Lab Sample ID: 460-126211-43

Matrix: Water

Method: 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	0.16	U	2.0	0.16	ug/L	—		01/11/17 16:12	1

Client Sample ID: PbHPC17B

Date Collected: 12/30/16 09:57

Date Received: 12/30/16 16:30

Lab Sample ID: 460-126211-44

Matrix: Water

Method: 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	0.94	J	2.0	0.16	ug/L	—	01/05/17 12:47	01/06/17 12:59	1

Client Sample ID: PbHPC18A

Date Collected: 12/30/16 09:59

Date Received: 12/30/16 16:30

Lab Sample ID: 460-126211-45

Matrix: Water

Method: 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	9.8		2.0	0.16	ug/L	—	01/05/17 12:47	01/06/17 13:01	1

Client Sample ID: PbHPC18B

Date Collected: 12/30/16 10:00

Date Received: 12/30/16 16:30

Lab Sample ID: 460-126211-46

Matrix: Water

Method: 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	0.49	J	2.0	0.16	ug/L	—		01/11/17 16:14	1

Client Sample ID: PbHPC19A

Date Collected: 12/30/16 10:15

Date Received: 12/30/16 16:30

Lab Sample ID: 460-126211-47

Matrix: Water

Method: 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	3.1		2.0	0.16	ug/L	—		01/11/17 16:16	1

Client Sample ID: PbHPC19B

Date Collected: 12/30/16 10:17

Date Received: 12/30/16 16:30

Lab Sample ID: 460-126211-48

Matrix: Water

Method: 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	0.47	J	2.0	0.16	ug/L	—		01/11/17 16:43	1