

# Client Sample Results

Client: Pennoni Associates, Inc.  
Project/Site: Rowan Univ. RCFM1614

TestAmerica Job ID: 460-129087-1

**Client Sample ID: PbOAK- 06C**

**Date Collected: 02/28/17 10:36**

**Date Received: 02/28/17 20:30**

**Lab Sample ID: 460-129087-5**

**Matrix: Water**

**Method: 200.8 - Metals (ICP/MS)**

| Analyte | Result | Qualifier | RL  | MDL  | Unit | D | Prepared       | Analyzed       | Dil Fac |
|---------|--------|-----------|-----|------|------|---|----------------|----------------|---------|
| Lead    | 0.18   | J         | 2.0 | 0.16 | ug/L | — | 03/02/17 10:51 | 03/03/17 15:02 | 1       |

**Client Sample ID: PbOAK- 06D**

**Date Collected: 02/28/17 10:37**

**Date Received: 02/28/17 20:30**

**Lab Sample ID: 460-129087-6**

**Matrix: Water**

**Method: 200.8 - Metals (ICP/MS)**

| Analyte | Result | Qualifier | RL  | MDL  | Unit | D | Prepared | Analyzed       | Dil Fac |
|---------|--------|-----------|-----|------|------|---|----------|----------------|---------|
| Lead    | 0.16   | U         | 2.0 | 0.16 | ug/L | — |          | 03/01/17 13:19 | 1       |

**Client Sample ID: PbOAK- 14C**

**Date Collected: 02/28/17 10:39**

**Date Received: 02/28/17 20:30**

**Lab Sample ID: 460-129087-7**

**Matrix: Water**

**Method: 200.8 - Metals (ICP/MS)**

| Analyte | Result | Qualifier | RL  | MDL  | Unit | D | Prepared | Analyzed       | Dil Fac |
|---------|--------|-----------|-----|------|------|---|----------|----------------|---------|
| Lead    | 0.16   | U         | 2.0 | 0.16 | ug/L | — |          | 03/01/17 13:28 | 1       |

TestAmerica Edison

# Client Sample Results

Client: Pennoni Associates, Inc.  
Project/Site: Rowan Univ. RCFM1614

TestAmerica Job ID: 460-129087-1

**Client Sample ID: PbOAK- 14D**

**Date Collected: 02/28/17 10:40**

**Date Received: 02/28/17 20:30**

**Lab Sample ID: 460-129087-8**

**Matrix: Water**

**Method: 200.8 - Metals (ICP/MS)**

| Analyte | Result | Qualifier | RL  | MDL  | Unit | D | Prepared | Analyzed       | Dil Fac |
|---------|--------|-----------|-----|------|------|---|----------|----------------|---------|
| Lead    | 0.16   | U         | 2.0 | 0.16 | ug/L | — |          | 03/01/17 13:31 | 1       |

**Client Sample ID: PbOAK- 18C**

**Date Collected: 02/28/17 10:43**

**Date Received: 02/28/17 20:30**

**Lab Sample ID: 460-129087-9**

**Matrix: Water**

**Method: 200.8 - Metals (ICP/MS)**

| Analyte | Result | Qualifier | RL  | MDL  | Unit | D | Prepared | Analyzed       | Dil Fac |
|---------|--------|-----------|-----|------|------|---|----------|----------------|---------|
| Lead    | 0.16   | U         | 2.0 | 0.16 | ug/L | — |          | 03/01/17 13:35 | 1       |

**Client Sample ID: PbOAK- 18D**

**Date Collected: 02/28/17 10:44**

**Date Received: 02/28/17 20:30**

**Lab Sample ID: 460-129087-10**

**Matrix: Water**

**Method: 200.8 - Metals (ICP/MS)**

| Analyte | Result | Qualifier | RL  | MDL  | Unit | D | Prepared | Analyzed       | Dil Fac |
|---------|--------|-----------|-----|------|------|---|----------|----------------|---------|
| Lead    | 0.16   | U         | 2.0 | 0.16 | ug/L | — |          | 03/01/17 13:38 | 1       |