

Client Sample Results

Client: Pennoni Associates, Inc.
Project/Site: Rowan Univ. RCFM1614

TestAmerica Job ID: 460-138103-1

Client Sample ID: PbOAK 10-C

Date Collected: 07/27/17 08:35

Date Received: 07/27/17 19:45

Lab Sample ID: 460-138103-39

Matrix: Water

Method: 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	0.16	U	2.0	0.16	ug/L	—		07/29/17 14:26	1

Client Sample ID: PbOAK 10-D

Date Collected: 07/27/17 11:47

Date Received: 07/27/17 19:45

Lab Sample ID: 460-138103-40

Matrix: Water

Method: 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	0.16	U	2.0	0.16	ug/L	—		07/29/17 14:32	1

Client Sample ID: PbOAK 11-C

Date Collected: 07/27/17 08:32

Date Received: 07/27/17 19:45

Lab Sample ID: 460-138103-41

Matrix: Water

Method: 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	0.16	U	2.0	0.16	ug/L	—		07/29/17 14:35	1

Client Sample ID: PbOAK 11-D

Date Collected: 07/27/17 11:49

Date Received: 07/27/17 19:45

Lab Sample ID: 460-138103-42

Matrix: Water

Method: 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	0.16	U	2.0	0.16	ug/L	—		07/29/17 15:10	1

Client Sample Results

Client: Pennoni Associates, Inc.
Project/Site: Rowan Univ. RCFM1614

TestAmerica Job ID: 460-138103-1

Client Sample ID: PbOAK 19-C

Date Collected: 07/27/17 08:26

Date Received: 07/27/17 19:45

Lab Sample ID: 460-138103-43

Matrix: Water

Method: 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	0.16	U	2.0	0.16	ug/L	—		07/29/17 15:03	1

Client Sample ID: PbOAK 19-D

Date Collected: 07/27/17 11:45

Date Received: 07/27/17 19:45

Lab Sample ID: 460-138103-44

Matrix: Water

Method: 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	0.16	U	2.0	0.16	ug/L	—		07/29/17 15:13	1