

# Client Sample Results

Client: Pennoni Associates, Inc.  
Project/Site: Rowan Univ. RCFM1614

TestAmerica Job ID: 460-126009-1

**Client Sample ID: PbSC01A**  
Date Collected: 12/23/16 06:28  
Date Received: 12/23/16 16:50

**Lab Sample ID: 460-126009-37**  
Matrix: Water

**Method: 200.8 - Metals (ICP/MS)**

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	427		2.0	0.16	ug/L			12/30/16 16:14	1

**Client Sample ID: PbSC01B**  
Date Collected: 12/23/16 06:29  
Date Received: 12/23/16 16:50

**Lab Sample ID: 460-126009-38**  
Matrix: Water

**Method: 200.8 - Metals (ICP/MS)**

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	57.6		2.0	0.16	ug/L			12/30/16 16:16	1

**Client Sample ID: PbSC02A**  
Date Collected: 12/23/16 06:33  
Date Received: 12/23/16 16:50

**Lab Sample ID: 460-126009-39**  
Matrix: Water

**Method: 200.8 - Metals (ICP/MS)**

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	0.16	U	2.0	0.16	ug/L			12/30/16 16:19	1

**Client Sample ID: PbSC02B**  
Date Collected: 12/23/16 06:48  
Date Received: 12/23/16 16:50

**Lab Sample ID: 460-126009-40**  
Matrix: Water

**Method: 200.8 - Metals (ICP/MS)**

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	0.16	U	2.0	0.16	ug/L			12/30/16 16:22	1

**Client Sample ID: PbSC03A**  
Date Collected: 12/23/16 06:37  
Date Received: 12/23/16 16:50

**Lab Sample ID: 460-126009-41**  
Matrix: Water

**Method: 200.8 - Metals (ICP/MS)**

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	2.3		2.0	0.16	ug/L			12/30/16 16:25	1

**Client Sample ID: PbSC03B**  
Date Collected: 12/23/16 06:38  
Date Received: 12/23/16 16:50

**Lab Sample ID: 460-126009-42**  
Matrix: Water

**Method: 200.8 - Metals (ICP/MS)**

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	34.1		2.0	0.16	ug/L			12/30/16 16:28	1

# Client Sample Results

Client: Pennoni Associates, Inc.  
Project/Site: Rowan Univ. RCFM1614

TestAmerica Job ID: 460-126009-1

**Client Sample ID: PbSC04A**

**Lab Sample ID: 460-126009-43**

Date Collected: 12/23/16 08:51

Matrix: Water

Date Received: 12/23/16 16:50

Method: 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	6.2		2.0	0.16	ug/L			12/29/16 10:50	1

**Client Sample ID: PbSC04B**

**Lab Sample ID: 460-126009-44**

Date Collected: 12/23/16 08:52

Matrix: Water

Date Received: 12/23/16 16:50

Method: 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	2.6		2.0	0.16	ug/L			12/29/16 10:53	1

**Client Sample ID: PbSC05A**

**Lab Sample ID: 460-126009-45**

Date Collected: 12/23/16 08:51

Matrix: Water

Date Received: 12/23/16 16:50

Method: 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	13.4		2.0	0.16	ug/L			12/29/16 10:44	1

**Client Sample ID: PbSC05B**

**Lab Sample ID: 460-126009-46**

Date Collected: 12/23/16 08:52

Matrix: Water

Date Received: 12/23/16 16:50

Method: 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	3.2		2.0	0.16	ug/L			12/29/16 11:02	1

**Client Sample ID: PbSC06A**

**Lab Sample ID: 460-126009-47**

Date Collected: 12/23/16 06:43

Matrix: Water

Date Received: 12/23/16 16:50

Method: 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	1.3	J	2.0	0.16	ug/L			12/29/16 11:05	1

**Client Sample ID: PbSC06B**

**Lab Sample ID: 460-126009-48**

Date Collected: 12/23/16 06:44

Matrix: Water

Date Received: 12/23/16 16:50

Method: 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	91.7		2.0	0.16	ug/L			12/29/16 11:08	1

**Client Sample ID: PbSC07A**

**Lab Sample ID: 460-126009-49**

Date Collected: 12/23/16 07:04

Matrix: Water

Date Received: 12/23/16 16:50

Method: 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	3.7		2.0	0.16	ug/L			12/29/16 11:10	1

# Client Sample Results

Client: Pennoni Associates, Inc.  
Project/Site: Rowan Univ. RCFM1614

TestAmerica Job ID: 460-126009-1

**Client Sample ID: PbSC07B**

**Lab Sample ID: 460-126009-50**

Date Collected: 12/23/16 07:05

Matrix: Water

Date Received: 12/23/16 16:50

Method: 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	20.5		2.0	0.16	ug/L			12/29/16 11:13	1

**Client Sample ID: PbSC08A**

**Lab Sample ID: 460-126009-51**

Date Collected: 12/23/16 07:00

Matrix: Water

Date Received: 12/23/16 16:50

Method: 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	0.16	U	2.0	0.16	ug/L			12/29/16 11:16	1

**Client Sample ID: PbSC08B**

**Lab Sample ID: 460-126009-52**

Date Collected: 12/23/16 07:02

Matrix: Water

Date Received: 12/23/16 16:50

Method: 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	0.16	U	2.0	0.16	ug/L			12/29/16 11:19	1

**Client Sample ID: PbSC09A**

**Lab Sample ID: 460-126009-53**

Date Collected: 12/23/16 06:58

Matrix: Water

Date Received: 12/23/16 16:50

Method: 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	69.4		2.0	0.16	ug/L			12/29/16 11:22	1

**Client Sample ID: PbSC09B**

**Lab Sample ID: 460-126009-54**

Date Collected: 12/23/16 06:59

Matrix: Water

Date Received: 12/23/16 16:50

Method: 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	8.0		2.0	0.16	ug/L			12/29/16 11:25	1

**Client Sample ID: PbSC10A**

**Lab Sample ID: 460-126009-55**

Date Collected: 12/23/16 07:18

Matrix: Water

Date Received: 12/23/16 16:50

Method: 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	17.5		2.0	0.16	ug/L			12/29/16 11:28	1

**Client Sample ID: PbSC10B**

**Lab Sample ID: 460-126009-56**

Date Collected: 12/23/16 07:18

Matrix: Water

Date Received: 12/23/16 16:50

Method: 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	220		2.0	0.16	ug/L		12/29/16 10:11	12/30/16 22:24	1

# Client Sample Results

Client: Pennoni Associates, Inc.  
Project/Site: Rowan Univ. RCFM1614

TestAmerica Job ID: 460-126009-1

**Client Sample ID: PbSC12A**

Date Collected: 12/23/16 07:04

Date Received: 12/23/16 16:50

**Lab Sample ID: 460-126009-57**

Matrix: Water

**Method: 200.8 - Metals (ICP/MS)**

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	0.29	J	2.0	0.16	ug/L			12/29/16 11:36	1

**Client Sample ID: PbSC12B**

Date Collected: 12/23/16 07:05

Date Received: 12/23/16 16:50

**Lab Sample ID: 460-126009-58**

Matrix: Water

**Method: 200.8 - Metals (ICP/MS)**

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	0.17	J	2.0	0.16	ug/L			12/29/16 11:45	1

**Client Sample ID: PbSC13A**

Date Collected: 12/23/16 07:08

Date Received: 12/23/16 16:50

**Lab Sample ID: 460-126009-59**

Matrix: Water

**Method: 200.8 - Metals (ICP/MS)**

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	0.25	J	2.0	0.16	ug/L			12/29/16 11:48	1

**Client Sample ID: PbSC13B**

Date Collected: 12/23/16 07:09

Date Received: 12/23/16 16:50

**Lab Sample ID: 460-126009-60**

Matrix: Water

**Method: 200.8 - Metals (ICP/MS)**

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	0.16	U	2.0	0.16	ug/L			12/29/16 11:51	1

**Client Sample ID: PbSC14A**

Date Collected: 12/23/16 07:10

Date Received: 12/23/16 16:50

**Lab Sample ID: 460-126009-61**

Matrix: Water

**Method: 200.8 - Metals (ICP/MS)**

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	0.16	U	2.0	0.16	ug/L			12/29/16 11:54	1

**Client Sample ID: PbSC14B**

Date Collected: 12/23/16 07:11

Date Received: 12/23/16 16:50

**Lab Sample ID: 460-126009-62**

Matrix: Water

**Method: 200.8 - Metals (ICP/MS)**

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	0.16	U	2.0	0.16	ug/L			12/29/16 11:56	1

**Client Sample ID: PbSC15A**

Date Collected: 12/23/16 06:37

Date Received: 12/23/16 16:50

**Lab Sample ID: 460-126009-63**

Matrix: Water

**Method: 200.8 - Metals (ICP/MS)**

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	0.16	U	2.0	0.16	ug/L			12/29/16 11:59	1

# Client Sample Results

Client: Pennoni Associates, Inc.  
Project/Site: Rowan Univ. RCFM1614

TestAmerica Job ID: 460-126009-1

**Client Sample ID: PbSC15B**

Date Collected: 12/23/16 06:38

Date Received: 12/23/16 16:50

**Lab Sample ID: 460-126009-64**

Matrix: Water

Method: 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	0.16	U	2.0	0.16	ug/L			12/29/16 13:50	1

**Client Sample ID: PbSC16A**

Date Collected: 12/23/16 06:41

Date Received: 12/23/16 16:50

**Lab Sample ID: 460-126009-65**

Matrix: Water

Method: 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	2450		20.0	1.6	ug/L		12/29/16 10:11	12/30/16 22:30	10

**Client Sample ID: PbSC16B**

Date Collected: 12/23/16 06:42

Date Received: 12/23/16 16:50

**Lab Sample ID: 460-126009-66**

Matrix: Water

Method: 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	7.6		2.0	0.16	ug/L			12/29/16 13:53	1

**Client Sample ID: PbSC17A**

Date Collected: 12/23/16 06:48

Date Received: 12/23/16 16:50

**Lab Sample ID: 460-126009-67**

Matrix: Water

Method: 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	28.8		2.0	0.16	ug/L			12/29/16 14:01	1

**Client Sample ID: PbSC17B**

Date Collected: 12/23/16 07:03

Date Received: 12/23/16 16:50

**Lab Sample ID: 460-126009-68**

Matrix: Water

Method: 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	11.7		2.0	0.16	ug/L			12/29/16 13:41	1

**Client Sample ID: PbSC18A**

Date Collected: 12/23/16 07:38

Date Received: 12/23/16 16:50

**Lab Sample ID: 460-126009-69**

Matrix: Water

Method: 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	0.16	U	2.0	0.16	ug/L			12/29/16 14:04	1

**Client Sample ID: PbSC18B**

Date Collected: 12/23/16 07:39

Date Received: 12/23/16 16:50

**Lab Sample ID: 460-126009-70**

Matrix: Water

Method: 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	0.16	U	2.0	0.16	ug/L			12/29/16 14:07	1

# Client Sample Results

Client: Pennoni Associates, Inc.  
Project/Site: Rowan Univ. RCFM1614

TestAmerica Job ID: 460-126009-1

**Client Sample ID: PbSC19A**

Date Collected: 12/23/16 07:46

Date Received: 12/23/16 16:50

**Lab Sample ID: 460-126009-71**

Matrix: Water

Method: 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	33.0		2.0	0.16	ug/L			12/29/16 14:10	1

**Client Sample ID: PbSC19B**

Date Collected: 12/23/16 07:46

Date Received: 12/23/16 16:50

**Lab Sample ID: 460-126009-72**

Matrix: Water

Method: 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	10.1		2.0	0.16	ug/L			12/29/16 14:13	1

**Client Sample ID: PbSC20A**

Date Collected: 12/23/16 07:49

Date Received: 12/23/16 16:50

**Lab Sample ID: 460-126009-73**

Matrix: Water

Method: 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	2.7		2.0	0.16	ug/L			12/29/16 14:16	1

**Client Sample ID: PbSC20B**

Date Collected: 12/23/16 07:50

Date Received: 12/23/16 16:50

**Lab Sample ID: 460-126009-74**

Matrix: Water

Method: 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	2.1		2.0	0.16	ug/L			12/29/16 14:18	1

**Client Sample ID: PbSC21A**

Date Collected: 12/23/16 07:27

Date Received: 12/23/16 16:50

**Lab Sample ID: 460-126009-75**

Matrix: Water

Method: 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	0.16	U	2.0	0.16	ug/L			12/29/16 14:21	1

**Client Sample ID: PbSC21B**

Date Collected: 12/23/16 07:42

Date Received: 12/23/16 16:50

**Lab Sample ID: 460-126009-76**

Matrix: Water

Method: 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	0.16	U	2.0	0.16	ug/L			12/29/16 14:24	1

**Client Sample ID: PbSC22A**

Date Collected: 12/23/16 07:30

Date Received: 12/23/16 16:50

**Lab Sample ID: 460-126009-77**

Matrix: Water

Method: 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	6.0		2.0	0.16	ug/L			12/29/16 14:27	1

# Client Sample Results

Client: Pennoni Associates, Inc.  
Project/Site: Rowan Univ. RCFM1614

TestAmerica Job ID: 460-126009-1

**Client Sample ID: PbSC22B**

**Lab Sample ID: 460-126009-78**

Date Collected: 12/23/16 07:45

Matrix: Water

Date Received: 12/23/16 16:50

Method: 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	1.7	J	2.0	0.16	ug/L			12/29/16 14:36	1

**Client Sample ID: PbSC23A**

**Lab Sample ID: 460-126009-79**

Date Collected: 12/23/16 07:23

Matrix: Water

Date Received: 12/23/16 16:50

Method: 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	1.1	J	2.0	0.16	ug/L			12/29/16 14:44	1

**Client Sample ID: PbSC23B**

**Lab Sample ID: 460-126009-80**

Date Collected: 12/23/16 07:40

Matrix: Water

Date Received: 12/23/16 16:50

Method: 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	0.53	J	2.0	0.16	ug/L			12/29/16 14:47	1

**Client Sample ID: PbSC24A**

**Lab Sample ID: 460-126009-81**

Date Collected: 12/23/16 07:48

Matrix: Water

Date Received: 12/23/16 16:50

Method: 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	0.16	U	2.0	0.16	ug/L			12/29/16 14:50	1

**Client Sample ID: PbSC24B**

**Lab Sample ID: 460-126009-82**

Date Collected: 12/23/16 07:49

Matrix: Water

Date Received: 12/23/16 16:50

Method: 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	0.16	U	2.0	0.16	ug/L			12/29/16 14:53	1

**Client Sample ID: PbSC25A**

**Lab Sample ID: 460-126009-83**

Date Collected: 12/23/16 07:47

Matrix: Water

Date Received: 12/23/16 16:50

Method: 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	0.16	U	2.0	0.16	ug/L			12/29/16 14:56	1

**Client Sample ID: PbSC25B**

**Lab Sample ID: 460-126009-84**

Date Collected: 12/23/16 07:48

Matrix: Water

Date Received: 12/23/16 16:50

Method: 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	0.16	U	2.0	0.16	ug/L			12/29/16 14:59	1

# Client Sample Results

Client: Pennoni Associates, Inc.  
Project/Site: Rowan Univ. RCFM1614

TestAmerica Job ID: 460-126009-1

**Client Sample ID: PbSC26A**

Date Collected: 12/23/16 08:05

Date Received: 12/23/16 16:50

**Lab Sample ID: 460-126009-85**

Matrix: Water

Method: 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	7.2		2.0	0.16	ug/L			12/29/16 16:23	1

**Client Sample ID: PbSC26B**

Date Collected: 12/23/16 08:06

Date Received: 12/23/16 16:50

**Lab Sample ID: 460-126009-86**

Matrix: Water

Method: 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	0.47	J	2.0	0.16	ug/L			12/29/16 16:26	1

**Client Sample ID: PbSC27A**

Date Collected: 12/23/16 08:02

Date Received: 12/23/16 16:50

**Lab Sample ID: 460-126009-87**

Matrix: Water

Method: 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	118		2.0	0.16	ug/L		12/29/16 10:11	12/30/16 22:36	1

**Client Sample ID: PbSC27B**

Date Collected: 12/23/16 08:03

Date Received: 12/23/16 16:50

**Lab Sample ID: 460-126009-88**

Matrix: Water

Method: 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	3.6		2.0	0.16	ug/L			12/29/16 16:17	1

**Client Sample ID: PbSC28A**

Date Collected: 12/23/16 07:59

Date Received: 12/23/16 16:50

**Lab Sample ID: 460-126009-89**

Matrix: Water

Method: 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	18.2		2.0	0.16	ug/L			12/29/16 16:35	1

**Client Sample ID: PbSC28B**

Date Collected: 12/23/16 08:00

Date Received: 12/23/16 16:50

**Lab Sample ID: 460-126009-90**

Matrix: Water

Method: 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	1.7	J	2.0	0.16	ug/L			12/29/16 16:38	1

**Client Sample ID: PbSC29A**

Date Collected: 12/23/16 07:59

Date Received: 12/23/16 16:50

**Lab Sample ID: 460-126009-91**

Matrix: Water

Method: 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	32.9		2.0	0.16	ug/L			12/29/16 16:40	1

# Client Sample Results

Client: Pennoni Associates, Inc.  
Project/Site: Rowan Univ. RCFM1614

TestAmerica Job ID: 460-126009-1

**Client Sample ID: PbSC29B**

Date Collected: 12/23/16 08:00

Date Received: 12/23/16 16:50

**Lab Sample ID: 460-126009-92**

Matrix: Water

Method: 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	6.0		2.0	0.16	ug/L			12/29/16 16:43	1

**Client Sample ID: PbSC30A**

Date Collected: 12/23/16 08:06

Date Received: 12/23/16 16:50

**Lab Sample ID: 460-126009-93**

Matrix: Water

Method: 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	10.6		2.0	0.16	ug/L			12/29/16 16:46	1

**Client Sample ID: PbSC30B**

Date Collected: 12/23/16 08:07

Date Received: 12/23/16 16:50

**Lab Sample ID: 460-126009-94**

Matrix: Water

Method: 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	11.6		2.0	0.16	ug/L			12/29/16 16:49	1

**Client Sample ID: PbSC31A**

Date Collected: 12/23/16 08:08

Date Received: 12/23/16 16:50

**Lab Sample ID: 460-126009-95**

Matrix: Water

Method: 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	2.2		2.0	0.16	ug/L			12/29/16 16:52	1

**Client Sample ID: PbSC31B**

Date Collected: 12/23/16 08:09

Date Received: 12/23/16 16:50

**Lab Sample ID: 460-126009-96**

Matrix: Water

Method: 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	0.89	J	2.0	0.16	ug/L			12/29/16 17:03	1

**Client Sample ID: PbSC32A**

Date Collected: 12/23/16 07:26

Date Received: 12/23/16 16:50

**Lab Sample ID: 460-126009-97**

Matrix: Water

Method: 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	36.9		2.0	0.16	ug/L			12/29/16 17:12	1

**Client Sample ID: PbSC32B**

Date Collected: 12/23/16 07:27

Date Received: 12/23/16 16:50

**Lab Sample ID: 460-126009-98**

Matrix: Water

Method: 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	3.8		2.0	0.16	ug/L			12/29/16 17:15	1

# Client Sample Results

Client: Pennoni Associates, Inc.  
Project/Site: Rowan Univ. RCFM1614

TestAmerica Job ID: 460-126009-1

**Client Sample ID: PbSC33A**

**Lab Sample ID: 460-126009-99**

Date Collected: 12/23/16 07:26

Matrix: Water

Date Received: 12/23/16 16:50

Method: 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	12.3		2.0	0.16	ug/L			12/29/16 17:18	1

**Client Sample ID: PbSC33B**

**Lab Sample ID: 460-126009-100**

Date Collected: 12/23/16 07:27

Matrix: Water

Date Received: 12/23/16 16:50

Method: 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	9.4		2.0	0.16	ug/L			12/29/16 17:21	1

**Client Sample ID: PbSC34A**

**Lab Sample ID: 460-126009-101**

Date Collected: 12/23/16 07:33

Matrix: Water

Date Received: 12/23/16 16:50

Method: 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	6.8		2.0	0.16	ug/L			12/29/16 17:24	1

**Client Sample ID: PbSC34B**

**Lab Sample ID: 460-126009-102**

Date Collected: 12/23/16 07:34

Matrix: Water

Date Received: 12/23/16 16:50

Method: 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	0.37	J	2.0	0.16	ug/L			12/29/16 17:27	1

**Client Sample ID: PbSC35A**

**Lab Sample ID: 460-126009-103**

Date Collected: 12/23/16 07:33

Matrix: Water

Date Received: 12/23/16 16:50

Method: 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	7.4		2.0	0.16	ug/L			12/29/16 17:30	1

**Client Sample ID: PbSC35B**

**Lab Sample ID: 460-126009-104**

Date Collected: 12/23/16 07:34

Matrix: Water

Date Received: 12/23/16 16:50

Method: 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	0.74	J	2.0	0.16	ug/L			12/29/16 17:32	1

**Client Sample ID: PbSC36A**

**Lab Sample ID: 460-126009-105**

Date Collected: 12/23/16 07:35

Matrix: Water

Date Received: 12/23/16 16:50

Method: 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	5.1		2.0	0.16	ug/L			12/29/16 17:35	1

# Client Sample Results

Client: Pennoni Associates, Inc.  
Project/Site: Rowan Univ. RCFM1614

TestAmerica Job ID: 460-126009-1

**Client Sample ID: PbSC36B**

**Lab Sample ID: 460-126009-106**

Date Collected: 12/23/16 07:36

Matrix: Water

Date Received: 12/23/16 16:50

Method: 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	0.63	J	2.0	0.16	ug/L			12/29/16 18:01	1

**Client Sample ID: PbSC37A**

**Lab Sample ID: 460-126009-107**

Date Collected: 12/23/16 07:20

Matrix: Water

Date Received: 12/23/16 16:50

Method: 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	3.0		2.0	0.16	ug/L			12/29/16 18:07	1

**Client Sample ID: PbSC37B**

**Lab Sample ID: 460-126009-108**

Date Collected: 12/23/16 07:21

Matrix: Water

Date Received: 12/23/16 16:50

Method: 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	0.63	J	2.0	0.16	ug/L			12/29/16 18:10	1

**Client Sample ID: PbSC38A**

**Lab Sample ID: 460-126009-109**

Date Collected: 12/23/16 07:23

Matrix: Water

Date Received: 12/23/16 16:50

Method: 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	2.0		2.0	0.16	ug/L			12/29/16 18:19	1

**Client Sample ID: PbSC38B**

**Lab Sample ID: 460-126009-110**

Date Collected: 12/23/16 07:24

Matrix: Water

Date Received: 12/23/16 16:50

Method: 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	3.5		2.0	0.16	ug/L			12/29/16 18:22	1

**Client Sample ID: PbSC39A**

**Lab Sample ID: 460-126009-111**

Date Collected: 12/23/16 07:12

Matrix: Water

Date Received: 12/23/16 16:50

Method: 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	0.16	J	2.0	0.16	ug/L			12/29/16 18:25	1

**Client Sample ID: PbSC39B**

**Lab Sample ID: 460-126009-112**

Date Collected: 12/23/16 07:30

Matrix: Water

Date Received: 12/23/16 16:50

Method: 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	1.2	J	2.0	0.16	ug/L			12/29/16 18:27	1

# Client Sample Results

Client: Pennoni Associates, Inc.  
Project/Site: Rowan Univ. RCFM1614

TestAmerica Job ID: 460-126009-1

**Client Sample ID: PbSC40A**

**Lab Sample ID: 460-126009-113**

Date Collected: 12/23/16 08:16

Matrix: Water

Date Received: 12/23/16 16:50

Method: 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	0.53	J	2.0	0.16	ug/L			12/29/16 18:30	1

**Client Sample ID: PbSC40B**

**Lab Sample ID: 460-126009-114**

Date Collected: 12/23/16 08:17

Matrix: Water

Date Received: 12/23/16 16:50

Method: 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	1.6	J	2.0	0.16	ug/L			12/29/16 18:39	1

**Client Sample ID: PbSC41A**

**Lab Sample ID: 460-126009-115**

Date Collected: 12/23/16 08:14

Matrix: Water

Date Received: 12/23/16 16:50

Method: 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	3.0		2.0	0.16	ug/L			12/29/16 18:42	1

**Client Sample ID: PbSC41B**

**Lab Sample ID: 460-126009-116**

Date Collected: 12/23/16 08:15

Matrix: Water

Date Received: 12/23/16 16:50

Method: 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	97.5		2.0	0.16	ug/L		12/29/16 10:11	12/30/16 22:41	1

**Client Sample ID: PbSC42A**

**Lab Sample ID: 460-126009-117**

Date Collected: 12/23/16 08:26

Matrix: Water

Date Received: 12/23/16 16:50

Method: 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	1.8	J	2.0	0.16	ug/L			12/29/16 18:45	1

**Client Sample ID: PbSC42B**

**Lab Sample ID: 460-126009-118**

Date Collected: 12/23/16 08:27

Matrix: Water

Date Received: 12/23/16 16:50

Method: 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	0.16	J	2.0	0.16	ug/L			12/29/16 18:54	1

**Client Sample ID: PbSC43A**

**Lab Sample ID: 460-126009-119**

Date Collected: 12/23/16 08:26

Matrix: Water

Date Received: 12/23/16 16:50

Method: 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	0.68	J	2.0	0.16	ug/L			12/29/16 18:56	1

# Client Sample Results

Client: Pennoni Associates, Inc.  
Project/Site: Rowan Univ. RCFM1614

TestAmerica Job ID: 460-126009-1

**Client Sample ID: PbSC43B**

**Lab Sample ID: 460-126009-120**

Date Collected: 12/23/16 08:27

Matrix: Water

Date Received: 12/23/16 16:50

Method: 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	14.8		2.0	0.16	ug/L			12/29/16 18:59	1

**Client Sample ID: PbSC44A**

**Lab Sample ID: 460-126009-121**

Date Collected: 12/23/16 08:02

Matrix: Water

Date Received: 12/23/16 16:50

Method: 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	0.16	U	2.0	0.16	ug/L			12/29/16 19:02	1

**Client Sample ID: PbSC44B**

**Lab Sample ID: 460-126009-122**

Date Collected: 12/23/16 08:17

Matrix: Water

Date Received: 12/23/16 16:50

Method: 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	0.16	U	2.0	0.16	ug/L			12/29/16 19:05	1

**Client Sample ID: PbSC46A**

**Lab Sample ID: 460-126009-123**

Date Collected: 12/23/16 08:05

Matrix: Water

Date Received: 12/23/16 16:50

Method: 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	389		2.0	0.16	ug/L			12/29/16 19:08	1

**Client Sample ID: PbSC46B**

**Lab Sample ID: 460-126009-124**

Date Collected: 12/23/16 08:20

Matrix: Water

Date Received: 12/23/16 16:50

Method: 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	2.1		2.0	0.16	ug/L			12/29/16 19:11	1

**Client Sample ID: PbSC50A**

**Lab Sample ID: 460-126009-125**

Date Collected: 12/23/16 07:38

Matrix: Water

Date Received: 12/23/16 16:50

Method: 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	9.5		2.0	0.16	ug/L			12/29/16 19:14	1

**Client Sample ID: PbSC50B**

**Lab Sample ID: 460-126009-126**

Date Collected: 12/23/16 07:39

Matrix: Water

Date Received: 12/23/16 16:50

Method: 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	2.2		2.0	0.16	ug/L			12/29/16 19:17	1

# Client Sample Results

Client: Pennoni Associates, Inc.  
Project/Site: Rowan Univ. RCFM1614

TestAmerica Job ID: 460-126009-1

**Client Sample ID: PbSC51A**

**Lab Sample ID: 460-126009-127**

Date Collected: 12/23/16 07:38

Matrix: Water

Date Received: 12/23/16 16:50

**Method: 200.8 - Metals (ICP/MS)**

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	10.2		2.0	0.16	ug/L			12/29/16 15:25	1

**Client Sample ID: PbSC51B**

**Lab Sample ID: 460-126009-128**

Date Collected: 12/23/16 07:39

Matrix: Water

Date Received: 12/23/16 16:50

**Method: 200.8 - Metals (ICP/MS)**

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	3.9		2.0	0.16	ug/L			12/29/16 15:30	1

**Client Sample ID: PbSC52A**

**Lab Sample ID: 460-126009-129**

Date Collected: 12/23/16 08:28

Matrix: Water

Date Received: 12/23/16 16:50

**Method: 200.8 - Metals (ICP/MS)**

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	0.16	U	2.0	0.16	ug/L			12/29/16 15:33	1

**Client Sample ID: PbSC52B**

**Lab Sample ID: 460-126009-130**

Date Collected: 12/23/16 08:29

Matrix: Water

Date Received: 12/23/16 16:50

**Method: 200.8 - Metals (ICP/MS)**

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	0.16	U	2.0	0.16	ug/L			12/29/16 15:42	1