

Client Sample Results

Client: Pennoni Associates, Inc.
Project/Site: Rowan Univ. RCFM1614

TestAmerica Job ID: 460-128893-1

Client Sample ID: PbSC01C

Date Collected: 02/23/17 09:38

Date Received: 02/23/17 19:05

Lab Sample ID: 460-128893-19

Matrix: Water

Method: 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	382		2.0	0.16	ug/L		02/24/17 18:17	02/25/17 14:59	1

Client Sample ID: PbSC01D

Date Collected: 02/23/17 09:39

Date Received: 02/23/17 19:05

Lab Sample ID: 460-128893-20

Matrix: Water

Method: 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	4.1		2.0	0.16	ug/L			02/24/17 16:49	1

Client Sample ID: PbSC09C

Date Collected: 02/23/17 11:07

Date Received: 02/23/17 19:05

Lab Sample ID: 460-128893-21

Matrix: Water

Method: 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	15.1		2.0	0.16	ug/L			02/24/17 16:52	1

Client Sample Results

Client: Pennoni Associates, Inc.
Project/Site: Rowan Univ. RCFM1614

TestAmerica Job ID: 460-128893-1

Client Sample ID: PbSC09D

Lab Sample ID: 460-128893-22

Date Collected: 02/23/17 11:08

Matrix: Water

Date Received: 02/23/17 19:05

Method: 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	2.8		2.0	0.16	ug/L			02/24/17 16:55	1

Client Sample ID: PbSC27C

Lab Sample ID: 460-128893-23

Date Collected: 02/23/17 09:13

Matrix: Water

Date Received: 02/23/17 19:05

Method: 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	4.0		2.0	0.16	ug/L			02/24/17 16:58	1

Client Sample ID: PbSC27D

Lab Sample ID: 460-128893-24

Date Collected: 02/23/17 09:14

Matrix: Water

Date Received: 02/23/17 19:05

Method: 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	0.58	J	2.0	0.16	ug/L			02/24/17 17:01	1