

Client Sample Results

Client: Pennoni Associates, Inc.
Project/Site: Rowan Univ. RCFM1614

TestAmerica Job ID: 460-129721-1

Client Sample ID: PbSC09-E

Date Collected: 03/10/17 09:11
Date Received: 03/10/17 20:30

Lab Sample ID: 460-129721-1

Matrix: Water

Method: 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	29.8		2.0	0.16	ug/L			03/13/17 12:02	1

Client Sample ID: PbSC09-F

Date Collected: 03/10/17 09:13
Date Received: 03/10/17 20:30

Lab Sample ID: 460-129721-2

Matrix: Water

Method: 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	0.23	J	2.0	0.16	ug/L			03/13/17 12:05	1

Client Sample ID: PbSC53-A

Date Collected: 03/10/17 09:27
Date Received: 03/10/17 20:30

Lab Sample ID: 460-129721-3

Matrix: Water

Method: 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	4.8		2.0	0.16	ug/L			03/13/17 12:13	1

Client Sample ID: PbSC53-B

Date Collected: 03/10/17 09:28
Date Received: 03/10/17 20:30

Lab Sample ID: 460-129721-4

Matrix: Water

Method: 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	0.16	J	2.0	0.16	ug/L			03/13/17 12:16	1

Client Sample ID: PbSC32-C

Date Collected: 03/10/17 09:38
Date Received: 03/10/17 20:30

Lab Sample ID: 460-129721-5

Matrix: Water

Method: 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	1.1	J	2.0	0.16	ug/L			03/13/17 11:56	1

Client Sample ID: PbSC32-D

Date Collected: 03/10/17 09:39
Date Received: 03/10/17 20:30

Lab Sample ID: 460-129721-6

Matrix: Water

Method: 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	0.16	U	2.0	0.16	ug/L			03/13/17 12:19	1

Client Sample ID: PbSC33-C

Date Collected: 03/10/17 09:39
Date Received: 03/10/17 20:30

Lab Sample ID: 460-129721-7

Matrix: Water

Method: 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	208		2.0	0.16	ug/L			03/13/17 12:22	1

Client Sample Results

Client: Pennoni Associates, Inc.
Project/Site: Rowan Univ. RCFM1614

TestAmerica Job ID: 460-129721-1

Client Sample ID: PbSC33-D

Lab Sample ID: 460-129721-8

Date Collected: 03/10/17 09:40

Matrix: Water

Date Received: 03/10/17 20:30

Method: 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	2.3		2.0	0.16	ug/L			03/13/17 12:25	1