

# Client Sample Results

Client: Pennoni Associates, Inc.  
Project/Site: Rowan Univ. RCFM1614

TestAmerica Job ID: 460-138103-1

**Client Sample ID: PbSC 03-C**  
**Date Collected: 07/27/17 08:47**  
**Date Received: 07/27/17 19:45**

**Lab Sample ID: 460-138103-7**  
**Matrix: Water**

**Method: 200.8 - Metals (ICP/MS)**

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	15.3		2.0	0.16	ug/L			07/29/17 11:23	1

# Client Sample Results

Client: Pennoni Associates, Inc.  
Project/Site: Rowan Univ. RCFM1614

TestAmerica Job ID: 460-138103-1

## Client Sample ID: PbSC 03-D

Date Collected: 07/27/17 08:48  
Date Received: 07/27/17 19:45

## Lab Sample ID: 460-138103-8

Matrix: Water

### Method: 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	0.93	J	2.0	0.16	ug/L		07/31/17 13:55	08/01/17 12:04	1

## Client Sample ID: PbSC 06-C

Date Collected: 07/27/17 08:49  
Date Received: 07/27/17 19:45

## Lab Sample ID: 460-138103-9

Matrix: Water

### Method: 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	7.8		2.0	0.16	ug/L			07/29/17 11:26	1

## Client Sample ID: PbSC 06-D

Date Collected: 07/27/17 08:49  
Date Received: 07/27/17 19:45

## Lab Sample ID: 460-138103-10

Matrix: Water

### Method: 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	1.0	J	2.0	0.16	ug/L			07/29/17 11:29	1

## Client Sample ID: PbSC 09-G

Date Collected: 07/27/17 08:29  
Date Received: 07/27/17 19:45

## Lab Sample ID: 460-138103-11

Matrix: Water

### Method: 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	1.0	J	2.0	0.16	ug/L			07/29/17 11:32	1

## Client Sample ID: PbSC 09-H

Date Collected: 07/27/17 08:30  
Date Received: 07/27/17 19:45

## Lab Sample ID: 460-138103-12

Matrix: Water

### Method: 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	0.33	J	2.0	0.16	ug/L			07/29/17 11:36	1

## Client Sample ID: PbSC 10-C

Date Collected: 07/27/17 11:05  
Date Received: 07/27/17 19:45

## Lab Sample ID: 460-138103-13

Matrix: Water

### Method: 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	0.16	U	2.0	0.16	ug/L			07/29/17 11:39	1

## Client Sample ID: PbSC 10-D

Date Collected: 07/27/17 11:06  
Date Received: 07/27/17 19:45

## Lab Sample ID: 460-138103-14

Matrix: Water

### Method: 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	0.16	U	2.0	0.16	ug/L			07/29/17 11:42	1

# Client Sample Results

Client: Pennoni Associates, Inc.  
Project/Site: Rowan Univ. RCFM1614

TestAmerica Job ID: 460-138103-1

## Client Sample ID: PbSC 11-A

Date Collected: 07/27/17 08:36

Date Received: 07/27/17 19:45

## Lab Sample ID: 460-138103-15

Matrix: Water

### Method: 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	0.16	U	2.0	0.16	ug/L			07/29/17 11:52	1

## Client Sample ID: PbSC 11-B

Date Collected: 07/27/17 08:37

Date Received: 07/27/17 19:45

## Lab Sample ID: 460-138103-16

Matrix: Water

### Method: 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	0.53	J	2.0	0.16	ug/L			07/29/17 12:01	1

## Client Sample ID: PbSC 17-C

Date Collected: 07/27/17 08:58

Date Received: 07/27/17 19:45

## Lab Sample ID: 460-138103-17

Matrix: Water

### Method: 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	0.16	U	2.0	0.16	ug/L			07/29/17 12:04	1

## Client Sample ID: PbSC 17-D

Date Collected: 07/27/17 09:55

Date Received: 07/27/17 19:45

## Lab Sample ID: 460-138103-18

Matrix: Water

### Method: 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	0.16	U	2.0	0.16	ug/L			07/29/17 12:07	1

## Client Sample ID: PbSC 29-C

Date Collected: 07/27/17 09:27

Date Received: 07/27/17 19:45

## Lab Sample ID: 460-138103-19

Matrix: Water

### Method: 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	0.16	U	2.0	0.16	ug/L			07/29/17 12:12	1

## Client Sample ID: PbSC 29-D

Date Collected: 07/27/17 09:28

Date Received: 07/27/17 19:45

## Lab Sample ID: 460-138103-20

Matrix: Water

### Method: 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	0.16	U	2.0	0.16	ug/L			07/29/17 12:15	1

## Client Sample ID: PbSC 33-E

Date Collected: 07/27/17 09:23

Date Received: 07/27/17 19:45

## Lab Sample ID: 460-138103-21

Matrix: Water

### Method: 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	0.71	J	2.0	0.16	ug/L			07/29/17 12:18	1

# Client Sample Results

Client: Pennoni Associates, Inc.  
Project/Site: Rowan Univ. RCFM1614

TestAmerica Job ID: 460-138103-1

## Client Sample ID: PbSC 33-F

Date Collected: 07/27/17 09:24  
Date Received: 07/27/17 19:45

## Lab Sample ID: 460-138103-22

Matrix: Water

### Method: 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	0.23	J	2.0	0.16	ug/L			07/29/17 13:18	1

## Client Sample ID: PbSC 47-A

Date Collected: 07/27/17 09:08  
Date Received: 07/27/17 19:45

## Lab Sample ID: 460-138103-23

Matrix: Water

### Method: 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	0.17	J	2.0	0.16	ug/L			07/29/17 13:21	1

## Client Sample ID: PbSC 47-B

Date Collected: 07/27/17 09:09  
Date Received: 07/27/17 19:45

## Lab Sample ID: 460-138103-24

Matrix: Water

### Method: 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	0.16	U	2.0	0.16	ug/L			07/29/17 13:30	1

## Client Sample ID: PbSC 48-A

Date Collected: 07/27/17 09:11  
Date Received: 07/27/17 19:45

## Lab Sample ID: 460-138103-25

Matrix: Water

### Method: 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	0.16	U	2.0	0.16	ug/L			07/29/17 13:12	1

## Client Sample ID: PbSC 48-B

Date Collected: 07/27/17 09:12  
Date Received: 07/27/17 19:45

## Lab Sample ID: 460-138103-26

Matrix: Water

### Method: 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	0.16	U	2.0	0.16	ug/L			07/29/17 13:33	1

## Client Sample ID: PbSC 53-E

Date Collected: 07/27/17 09:34  
Date Received: 07/27/17 19:45

## Lab Sample ID: 460-138103-27

Matrix: Water

### Method: 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	3.6		2.0	0.16	ug/L			07/29/17 13:36	1

## Client Sample ID: PbSC 53-F

Date Collected: 07/27/17 09:35  
Date Received: 07/27/17 19:45

## Lab Sample ID: 460-138103-28

Matrix: Water

### Method: 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	0.32	J	2.0	0.16	ug/L			07/29/17 13:39	1

# Client Sample Results

Client: Pennoni Associates, Inc.  
Project/Site: Rowan Univ. RCFM1614

TestAmerica Job ID: 460-138103-1

**Client Sample ID: PbSC 54-A**

**Date Collected: 07/27/17 08:54**

**Date Received: 07/27/17 19:45**

**Lab Sample ID: 460-138103-29**

**Matrix: Water**

**Method: 200.8 - Metals (ICP/MS)**

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	0.26	J	2.0	0.16	ug/L			07/29/17 13:43	1

**Client Sample ID: PbSC 54-B**

**Date Collected: 07/27/17 08:55**

**Date Received: 07/27/17 19:45**

**Lab Sample ID: 460-138103-30**

**Matrix: Water**

**Method: 200.8 - Metals (ICP/MS)**

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	0.18	J	2.0	0.16	ug/L			07/29/17 13:46	1