

Client Sample Results

Client: Pennoni Associates, Inc.
Project/Site: Rowan Univ. RCFM1614

TestAmerica Job ID: 460-138162-1

Client Sample ID: PbSCH-27-E

Date Collected: 07/28/17 09:12
Date Received: 07/28/17 21:00

Lab Sample ID: 460-138162-25

Matrix: Water

Method: 200.8 - Metals (ICP/MS)

| Analyte | Result | Qualifier | RL | MDL | Unit | D | Prepared | Analyzed | Dil Fac |
|---------|--------|-----------|-----|------|------|---|----------|----------------|---------|
| Lead | 2.2 | | 2.0 | 0.16 | ug/L | | | 08/01/17 15:44 | 1 |

Client Sample ID: PbSCH-27-F

Date Collected: 07/28/17 09:13
Date Received: 07/28/17 21:00

Lab Sample ID: 460-138162-26

Matrix: Water

Method: 200.8 - Metals (ICP/MS)

| Analyte | Result | Qualifier | RL | MDL | Unit | D | Prepared | Analyzed | Dil Fac |
|---------|--------|-----------|-----|------|------|---|----------|----------------|---------|
| Lead | 3.2 | | 2.0 | 0.16 | ug/L | | | 08/01/17 15:47 | 1 |

Client Sample ID: PbSCH-46-E

Date Collected: 07/28/17 09:05
Date Received: 07/28/17 21:00

Lab Sample ID: 460-138162-27

Matrix: Water

Method: 200.8 - Metals (ICP/MS)

| Analyte | Result | Qualifier | RL | MDL | Unit | D | Prepared | Analyzed | Dil Fac |
|---------|--------|-----------|-----|------|------|---|----------|----------------|---------|
| Lead | 8.5 | | 2.0 | 0.16 | ug/L | | | 08/01/17 15:50 | 1 |

Client Sample ID: PbSCH-46-F

Date Collected: 07/28/17 09:22
Date Received: 07/28/17 21:00

Lab Sample ID: 460-138162-28

Matrix: Water

Method: 200.8 - Metals (ICP/MS)

| Analyte | Result | Qualifier | RL | MDL | Unit | D | Prepared | Analyzed | Dil Fac |
|---------|--------|-----------|-----|------|------|---|----------|----------------|---------|
| Lead | 1.7 | J | 2.0 | 0.16 | ug/L | | | 08/01/17 15:53 | 1 |