

Client Sample Results

Client: Pennoni Associates, Inc.
Project/Site: Rowan Univ. RCFM1614

TestAmerica Job ID: 460-132536-1

Client Sample ID: PbTWN1601K-C

Date Collected: 04/27/17 09:31

Date Received: 04/28/17 19:00

Lab Sample ID: 460-132536-5

Matrix: Water

Method: 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	0.16	U	2.0	0.16	ug/L			05/03/17 13:35	1

Client Sample ID: PbTWN1601K-D

Date Collected: 04/27/17 09:32

Date Received: 04/28/17 19:00

Lab Sample ID: 460-132536-6

Matrix: Water

Method: 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	0.16	U	2.0	0.16	ug/L			05/03/17 13:38	1

Client Sample ID: PbTWN1602K-C

Date Collected: 04/27/17 09:34

Date Received: 04/28/17 19:00

Lab Sample ID: 460-132536-7

Matrix: Water

Method: 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	0.16	U	2.0	0.16	ug/L			05/03/17 13:41	1

Client Sample Results

Client: Pennoni Associates, Inc.
Project/Site: Rowan Univ. RCFM1614

TestAmerica Job ID: 460-132536-1

Client Sample ID: PbTWN1602K-D

Lab Sample ID: 460-132536-8

Date Collected: 04/27/17 09:35

Matrix: Water

Date Received: 04/28/17 19:00

Method: 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	0.16	U	2.0	0.16	ug/L			05/03/17 13:44	1

Client Sample ID: PbTWN1603K-C

Lab Sample ID: 460-132536-9

Date Collected: 04/27/17 09:38

Matrix: Water

Date Received: 04/28/17 19:00

Method: 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	0.16	U	2.0	0.16	ug/L			05/03/17 13:47	1

Client Sample ID: PbTWN1603K-D

Lab Sample ID: 460-132536-10

Date Collected: 04/27/17 09:39

Matrix: Water

Date Received: 04/28/17 19:00

Method: 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	0.16	U	2.0	0.16	ug/L			05/03/17 13:50	1

Client Sample ID: PbTWN1604K-C

Lab Sample ID: 460-132536-11

Date Collected: 04/27/17 09:41

Matrix: Water

Date Received: 04/28/17 19:00

Method: 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	0.16	U	2.0	0.16	ug/L			05/03/17 13:58	1

Client Sample ID: PbTWN1604K-D

Lab Sample ID: 460-132536-12

Date Collected: 04/27/17 09:43

Matrix: Water

Date Received: 04/28/17 19:00

Method: 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	0.16	U	2.0	0.16	ug/L			05/03/17 14:07	1

Client Sample ID: PbTWN1605K-C

Lab Sample ID: 460-132536-13

Date Collected: 04/27/17 09:46

Matrix: Water

Date Received: 04/28/17 19:00

Method: 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	0.16	U	2.0	0.16	ug/L			05/03/17 14:10	1

Client Sample ID: PbTWN1605K-D

Lab Sample ID: 460-132536-14

Date Collected: 04/27/17 09:47

Matrix: Water

Date Received: 04/28/17 19:00

Method: 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	0.16	U	2.0	0.16	ug/L			05/03/17 14:13	1

Client Sample Results

Client: Pennoni Associates, Inc.
Project/Site: Rowan Univ. RCFM1614

TestAmerica Job ID: 460-132536-1

Client Sample ID: PbTWN1606K-C

Lab Sample ID: 460-132536-15

Date Collected: 04/27/17 09:50

Matrix: Water

Date Received: 04/28/17 19:00

Method: 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	0.16	U	2.0	0.16	ug/L			05/03/17 14:16	1

Client Sample ID: PbTWN1606K-D

Lab Sample ID: 460-132536-16

Date Collected: 04/27/17 09:51

Matrix: Water

Date Received: 04/28/17 19:00

Method: 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	0.16	U	2.0	0.16	ug/L			05/03/17 14:19	1

Client Sample Results

Client: Pennoni Associates, Inc.
Project/Site: Rowan Univ. RCFM1614

TestAmerica Job ID: 460-132536-1

Client Sample ID: PbTWN1501K-C

Date Collected: 04/27/17 09:10

Date Received: 04/28/17 19:00

Lab Sample ID: 460-132536-23

Matrix: Water

Method: 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	0.16	U	2.0	0.16	ug/L			05/04/17 10:24	1

Client Sample ID: PbTWN1501K-D

Date Collected: 04/27/17 09:11

Date Received: 04/28/17 19:00

Lab Sample ID: 460-132536-24

Matrix: Water

Method: 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	0.16	U	2.0	0.16	ug/L			05/04/17 10:32	1

Client Sample ID: PbTWN1502K-C

Date Collected: 04/27/17 09:13

Date Received: 04/28/17 19:00

Lab Sample ID: 460-132536-25

Matrix: Water

Method: 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	0.16	U	2.0	0.16	ug/L			05/04/17 10:35	1

Client Sample ID: PbTWN1502K-D

Date Collected: 04/27/17 09:14

Date Received: 04/28/17 19:00

Lab Sample ID: 460-132536-26

Matrix: Water

Method: 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	0.16	U	2.0	0.16	ug/L			05/04/17 10:38	1

Client Sample ID: PbTWN1503K-C

Date Collected: 04/27/17 09:16

Date Received: 04/28/17 19:00

Lab Sample ID: 460-132536-27

Matrix: Water

Method: 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	0.16	U	2.0	0.16	ug/L			05/04/17 10:41	1

Client Sample ID: PbTWN1504K-C

Date Collected: 04/27/17 09:17

Date Received: 04/28/17 19:00

Lab Sample ID: 460-132536-28

Matrix: Water

Method: 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	0.16	U	2.0	0.16	ug/L			05/04/17 10:44	1

Client Sample Results

Client: Pennoni Associates, Inc.
Project/Site: Rowan Univ. RCFM1614

TestAmerica Job ID: 460-132536-1

Client Sample ID: PbTWN1504K-C

Lab Sample ID: 460-132536-29

Date Collected: 04/27/17 09:18

Matrix: Water

Date Received: 04/28/17 19:00

Method: 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	0.16	U	2.0	0.16	ug/L			05/04/17 10:47	1

Client Sample ID: PbTWN1504K-D

Lab Sample ID: 460-132536-30

Date Collected: 04/27/17 09:19

Matrix: Water

Date Received: 04/28/17 19:00

Method: 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	0.16	U	2.0	0.16	ug/L			05/04/17 10:49	1

Client Sample ID: PbTWN1505K-C

Lab Sample ID: 460-132536-31

Date Collected: 04/27/17 09:21

Matrix: Water

Date Received: 04/28/17 19:00

Method: 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	0.16	U	2.0	0.16	ug/L			05/04/17 10:52	1

Client Sample ID: PbTWN1505K-D

Lab Sample ID: 460-132536-32

Date Collected: 04/27/17 09:22

Matrix: Water

Date Received: 04/28/17 19:00

Method: 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	0.16	U	2.0	0.16	ug/L			05/04/17 11:07	1

Client Sample ID: PbTWN1506K-C

Lab Sample ID: 460-132536-33

Date Collected: 04/27/17 09:24

Matrix: Water

Date Received: 04/28/17 19:00

Method: 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	0.16	U	2.0	0.16	ug/L			05/04/17 11:09	1

Client Sample ID: PbTWN1506K-D

Lab Sample ID: 460-132536-34

Date Collected: 04/27/17 09:25

Matrix: Water

Date Received: 04/28/17 19:00

Method: 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	0.16	U	2.0	0.16	ug/L			05/04/17 11:12	1