

Client Sample Results

Client: Pennoni Associates, Inc.
Project/Site: Rowan Univ. RCFM1614

TestAmerica Job ID: 460-126112-1

Client Sample ID: PbTRI01A

Date Collected: 12/28/16 08:33

Date Received: 12/28/16 19:15

Lab Sample ID: 460-126112-1

Matrix: Water

Method: 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	227		2.0	0.16	ug/L	—		01/03/17 14:52	1

Client Sample ID: PbTRI01B

Date Collected: 12/28/16 08:34

Date Received: 12/28/16 19:15

Lab Sample ID: 460-126112-2

Matrix: Water

Method: 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	4.8		2.0	0.16	ug/L	—		01/03/17 14:47	1

Client Sample ID: PbTRI02A

Date Collected: 12/28/16 08:54

Date Received: 12/28/16 19:15

Lab Sample ID: 460-126112-3

Matrix: Water

Method: 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	4.1		2.0	0.16	ug/L	—		01/03/17 14:55	1

Client Sample ID: PbTRI02B

Date Collected: 12/28/16 08:54

Date Received: 12/28/16 19:15

Lab Sample ID: 460-126112-4

Matrix: Water

Method: 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	3.9		2.0	0.16	ug/L	—		01/03/17 15:04	1

Client Sample ID: PbTRI03A

Date Collected: 12/28/16 08:56

Date Received: 12/28/16 19:15

Lab Sample ID: 460-126112-5

Matrix: Water

Method: 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	1.1	J	2.0	0.16	ug/L	—		01/03/17 15:07	1

Client Sample ID: PbTRI03B

Date Collected: 12/28/16 08:56

Date Received: 12/28/16 19:15

Lab Sample ID: 460-126112-6

Matrix: Water

Method: 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	1.5	J	2.0	0.16	ug/L	—		01/03/17 15:10	1

Client Sample ID: PbTRI04A

Date Collected: 12/28/16 08:57

Date Received: 12/28/16 19:15

Lab Sample ID: 460-126112-7

Matrix: Water

Method: 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	0.75	J	2.0	0.16	ug/L	—		01/03/17 15:13	1

Client Sample Results

Client: Pennoni Associates, Inc.
Project/Site: Rowan Univ. RCFM1614

TestAmerica Job ID: 460-126112-1

Client Sample ID: PbTRI04B

Date Collected: 12/28/16 08:57

Date Received: 12/28/16 19:15

Lab Sample ID: 460-126112-8

Matrix: Water

Method: 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	2.6		2.0	0.16	ug/L	—		01/03/17 15:15	1

Client Sample ID: PbTRI05A

Date Collected: 12/28/16 08:59

Date Received: 12/28/16 19:15

Lab Sample ID: 460-126112-9

Matrix: Water

Method: 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	3.1		2.0	0.16	ug/L	—		01/03/17 15:18	1

Client Sample ID: PbTRI05B

Date Collected: 12/28/16 08:59

Date Received: 12/28/16 19:15

Lab Sample ID: 460-126112-10

Matrix: Water

Method: 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	79.0		2.0	0.16	ug/L	—		01/03/17 15:21	1

Client Sample ID: PbTRI06A

Date Collected: 12/28/16 09:01

Date Received: 12/28/16 19:15

Lab Sample ID: 460-126112-11

Matrix: Water

Method: 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	13.5		2.0	0.16	ug/L	—		01/03/17 15:24	1

Client Sample ID: PbTRI06B

Date Collected: 12/28/16 09:01

Date Received: 12/28/16 19:15

Lab Sample ID: 460-126112-12

Matrix: Water

Method: 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	74.3		2.0	0.16	ug/L	—	01/03/17 13:52	01/04/17 15:45	1

Client Sample ID: PbTRI07A

Date Collected: 12/28/16 09:03

Date Received: 12/28/16 19:15

Lab Sample ID: 460-126112-13

Matrix: Water

Method: 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	0.91	J	2.0	0.16	ug/L	—		01/03/17 15:27	1

Client Sample ID: PbTRI07B

Date Collected: 12/28/16 09:03

Date Received: 12/28/16 19:15

Lab Sample ID: 460-126112-14

Matrix: Water

Method: 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	31.0		2.0	0.16	ug/L	—		01/03/17 15:30	1

Client Sample Results

Client: Pennoni Associates, Inc.
Project/Site: Rowan Univ. RCFM1614

TestAmerica Job ID: 460-126112-1

Client Sample ID: PbTRI08A

Date Collected: 12/28/16 09:05

Date Received: 12/28/16 19:15

Lab Sample ID: 460-126112-15

Matrix: Water

Method: 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	1.1	J	2.0	0.16	ug/L	—		01/03/17 15:44	1

Client Sample ID: PbTRI08B

Date Collected: 12/28/16 09:05

Date Received: 12/28/16 19:15

Lab Sample ID: 460-126112-16

Matrix: Water

Method: 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	5.5		2.0	0.16	ug/L	—		01/03/17 15:47	1

Client Sample ID: PbTRI09A

Date Collected: 12/28/16 09:07

Date Received: 12/28/16 19:15

Lab Sample ID: 460-126112-17

Matrix: Water

Method: 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	4.3		2.0	0.16	ug/L	—		01/03/17 15:50	1

Client Sample ID: PbTRI09B

Date Collected: 12/28/16 09:07

Date Received: 12/28/16 19:15

Lab Sample ID: 460-126112-18

Matrix: Water

Method: 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	10		2.0	0.16	ug/L	—		01/03/17 15:53	1

Client Sample ID: PbTRI10A

Date Collected: 12/28/16 09:08

Date Received: 12/28/16 19:15

Lab Sample ID: 460-126112-19

Matrix: Water

Method: 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	0.53	J	2.0	0.16	ug/L	—		01/03/17 15:56	1

Client Sample ID: PbTRI10B

Date Collected: 12/28/16 09:08

Date Received: 12/28/16 19:15

Lab Sample ID: 460-126112-20

Matrix: Water

Method: 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	8.5		2.0	0.16	ug/L	—		01/03/17 15:59	1

Client Sample ID: PbTRI11A

Date Collected: 12/28/16 09:10

Date Received: 12/28/16 19:15

Lab Sample ID: 460-126112-21

Matrix: Water

Method: 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	0.79	J	2.0	0.16	ug/L	—		01/03/17 16:01	1

Client Sample Results

Client: Pennoni Associates, Inc.
Project/Site: Rowan Univ. RCFM1614

TestAmerica Job ID: 460-126112-1

Client Sample ID: PbTRI11B

Date Collected: 12/28/16 09:10

Date Received: 12/28/16 19:15

Lab Sample ID: 460-126112-22

Matrix: Water

Method: 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	29.1		2.0	0.16	ug/L		01/03/17 13:52	01/04/17 15:51	1

Client Sample ID: PbTRI12A

Date Collected: 12/28/16 09:12

Date Received: 12/28/16 19:15

Lab Sample ID: 460-126112-23

Matrix: Water

Method: 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	6.8		2.0	0.16	ug/L		01/03/17 13:52	01/04/17 15:53	1

Client Sample ID: PbTRI12B

Date Collected: 12/28/16 09:12

Date Received: 12/28/16 19:15

Lab Sample ID: 460-126112-24

Matrix: Water

Method: 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	4.5		2.0	0.16	ug/L			01/03/17 16:33	1

Client Sample ID: PbTRI13A

Date Collected: 12/28/16 09:14

Date Received: 12/28/16 19:15

Lab Sample ID: 460-126112-25

Matrix: Water

Method: 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	0.38	J	2.0	0.16	ug/L			01/03/17 16:27	1

Client Sample ID: PbTRI13B

Date Collected: 12/28/16 09:14

Date Received: 12/28/16 19:15

Lab Sample ID: 460-126112-26

Matrix: Water

Method: 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	0.40	J	2.0	0.16	ug/L			01/03/17 16:36	1

Client Sample ID: PbTRI14A

Date Collected: 12/28/16 09:16

Date Received: 12/28/16 19:15

Lab Sample ID: 460-126112-27

Matrix: Water

Method: 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	1.3	J	2.0	0.16	ug/L			01/03/17 16:45	1

Client Sample ID: PbTRI14B

Date Collected: 12/28/16 09:16

Date Received: 12/28/16 19:15

Lab Sample ID: 460-126112-28

Matrix: Water

Method: 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	1.5	J	2.0	0.16	ug/L			01/03/17 16:47	1

Client Sample Results

Client: Pennoni Associates, Inc.
Project/Site: Rowan Univ. RCFM1614

TestAmerica Job ID: 460-126112-1

Client Sample ID: PbTRI15A

Date Collected: 12/28/16 09:18

Date Received: 12/28/16 19:15

Lab Sample ID: 460-126112-29

Matrix: Water

Method: 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	0.88	J	2.0	0.16	ug/L	—		01/03/17 16:50	1

Client Sample ID: PbTRI15B

Date Collected: 12/28/16 09:18

Date Received: 12/28/16 19:15

Lab Sample ID: 460-126112-30

Matrix: Water

Method: 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	23.6		2.0	0.16	ug/L	—		01/03/17 16:53	1

Client Sample ID: PbTRI16A

Date Collected: 12/28/16 09:20

Date Received: 12/28/16 19:15

Lab Sample ID: 460-126112-31

Matrix: Water

Method: 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	0.68	J	2.0	0.16	ug/L	—		01/03/17 16:56	1

Client Sample ID: PbTRI16B

Date Collected: 12/28/16 09:20

Date Received: 12/28/16 19:15

Lab Sample ID: 460-126112-32

Matrix: Water

Method: 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	32.8		2.0	0.16	ug/L	—		01/03/17 16:59	1

Client Sample ID: PbTRI17A

Date Collected: 12/28/16 09:22

Date Received: 12/28/16 19:15

Lab Sample ID: 460-126112-33

Matrix: Water

Method: 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	0.64	J	2.0	0.16	ug/L	—		01/03/17 17:02	1

Client Sample ID: PbTRI17B

Date Collected: 12/28/16 09:22

Date Received: 12/28/16 19:15

Lab Sample ID: 460-126112-34

Matrix: Water

Method: 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	24.7		2.0	0.16	ug/L	—		01/03/17 17:05	1

Client Sample ID: PbTRI18A

Date Collected: 12/28/16 09:24

Date Received: 12/28/16 19:15

Lab Sample ID: 460-126112-35

Matrix: Water

Method: 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	5.3		2.0	0.16	ug/L	—		01/03/17 17:08	1

Client Sample Results

Client: Pennoni Associates, Inc.
Project/Site: Rowan Univ. RCFM1614

TestAmerica Job ID: 460-126112-1

Client Sample ID: PbTRI18B

Date Collected: 12/28/16 09:24

Date Received: 12/28/16 19:15

Lab Sample ID: 460-126112-36

Matrix: Water

Method: 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	2.3		2.0	0.16	ug/L			01/03/17 17:22	1

Client Sample ID: PbTRI19A

Date Collected: 12/28/16 09:25

Date Received: 12/28/16 19:15

Lab Sample ID: 460-126112-37

Matrix: Water

Method: 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	0.53	J	2.0	0.16	ug/L			01/03/17 17:25	1

Client Sample ID: PbTRI19B

Date Collected: 12/28/16 09:25

Date Received: 12/28/16 19:15

Lab Sample ID: 460-126112-38

Matrix: Water

Method: 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	0.41	J	2.0	0.16	ug/L			01/03/17 17:28	1

Client Sample ID: PbTRI20A

Date Collected: 12/28/16 09:28

Date Received: 12/28/16 19:15

Lab Sample ID: 460-126112-39

Matrix: Water

Method: 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	10.5		2.0	0.16	ug/L			01/03/17 17:31	1

Client Sample ID: PbTRI20B

Date Collected: 12/28/16 09:28

Date Received: 12/28/16 19:15

Lab Sample ID: 460-126112-40

Matrix: Water

Method: 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	0.38	J	2.0	0.16	ug/L			01/03/17 17:34	1

Client Sample ID: PbTRI21A

Date Collected: 12/28/16 08:37

Date Received: 12/28/16 19:15

Lab Sample ID: 460-126112-41

Matrix: Water

Method: 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	1.8	J	2.0	0.16	ug/L			01/03/17 17:37	1

Client Sample ID: PbTRI21B

Date Collected: 12/28/16 08:37

Date Received: 12/28/16 19:15

Lab Sample ID: 460-126112-42

Matrix: Water

Method: 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	4.0		2.0	0.16	ug/L			01/03/17 17:40	1

Client Sample Results

Client: Pennoni Associates, Inc.
Project/Site: Rowan Univ. RCFM1614

TestAmerica Job ID: 460-126112-1

Client Sample ID: PbTRI22A

Date Collected: 12/28/16 08:38

Date Received: 12/28/16 19:15

Lab Sample ID: 460-126112-43

Matrix: Water

Method: 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	0.75	J	2.0	0.16	ug/L	—		01/03/17 17:59	1

Client Sample ID: PbTRI22B

Date Collected: 12/28/16 08:38

Date Received: 12/28/16 19:15

Lab Sample ID: 460-126112-44

Matrix: Water

Method: 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	9.0		2.0	0.16	ug/L	—		01/03/17 18:32	1

Client Sample ID: PbTRI23A

Date Collected: 12/28/16 08:40

Date Received: 12/28/16 19:15

Lab Sample ID: 460-126112-45

Matrix: Water

Method: 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	2.1		2.0	0.16	ug/L	—		01/03/17 18:41	1

Client Sample ID: PbTRI23B

Date Collected: 12/28/16 08:40

Date Received: 12/28/16 19:15

Lab Sample ID: 460-126112-46

Matrix: Water

Method: 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	23.4		2.0	0.16	ug/L	—		01/03/17 18:50	1

Client Sample ID: PbTRI24A

Date Collected: 12/28/16 08:42

Date Received: 12/28/16 19:15

Lab Sample ID: 460-126112-47

Matrix: Water

Method: 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	1.7	J	2.0	0.16	ug/L	—		01/03/17 18:26	1

Client Sample ID: PbTRI24B

Date Collected: 12/28/16 08:42

Date Received: 12/28/16 19:15

Lab Sample ID: 460-126112-48

Matrix: Water

Method: 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	7.6		2.0	0.16	ug/L	—		01/03/17 18:52	1

Client Sample ID: PbTRI25A

Date Collected: 12/28/16 08:44

Date Received: 12/28/16 19:15

Lab Sample ID: 460-126112-49

Matrix: Water

Method: 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	1.1	J	2.0	0.16	ug/L	—		01/03/17 18:55	1

Client Sample Results

Client: Pennoni Associates, Inc.
Project/Site: Rowan Univ. RCFM1614

TestAmerica Job ID: 460-126112-1

Client Sample ID: PbTRI25B

Date Collected: 12/28/16 08:44

Date Received: 12/28/16 19:15

Lab Sample ID: 460-126112-50

Matrix: Water

Method: 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	2.5		2.0	0.16	ug/L			01/03/17 18:58	1

Client Sample ID: PbTRI26A

Date Collected: 12/28/16 08:46

Date Received: 12/28/16 19:15

Lab Sample ID: 460-126112-51

Matrix: Water

Method: 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	0.51	J	2.0	0.16	ug/L			01/03/17 19:01	1

Client Sample ID: PbTRI26B

Date Collected: 12/28/16 08:46

Date Received: 12/28/16 19:15

Lab Sample ID: 460-126112-52

Matrix: Water

Method: 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	16.2		2.0	0.16	ug/L			01/09/17 22:22	1

Client Sample ID: PbTRI27A

Date Collected: 12/28/16 08:48

Date Received: 12/28/16 19:15

Lab Sample ID: 460-126112-53

Matrix: Water

Method: 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	1.0	J	2.0	0.16	ug/L			01/03/17 19:18	1

Client Sample ID: PbTRI27B

Date Collected: 12/28/16 08:48

Date Received: 12/28/16 19:15

Lab Sample ID: 460-126112-54

Matrix: Water

Method: 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	13.1		2.0	0.16	ug/L			01/03/17 19:21	1

Client Sample ID: PbTRI28A

Date Collected: 12/28/16 08:49

Date Received: 12/28/16 19:15

Lab Sample ID: 460-126112-55

Matrix: Water

Method: 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	1.2	J	2.0	0.16	ug/L			01/09/17 22:25	1

Client Sample ID: PbTRI28B

Date Collected: 12/28/16 08:49

Date Received: 12/28/16 19:15

Lab Sample ID: 460-126112-56

Matrix: Water

Method: 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	1.0	J	2.0	0.16	ug/L			01/09/17 22:28	1

Client Sample Results

Client: Pennoni Associates, Inc.
Project/Site: Rowan Univ. RCFM1614

TestAmerica Job ID: 460-126112-1

Client Sample ID: PbTRI29A

Date Collected: 12/28/16 08:51

Date Received: 12/28/16 19:15

Lab Sample ID: 460-126112-57

Matrix: Water

Method: 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	7.4		2.0	0.16	ug/L	—		01/09/17 22:31	1

Client Sample ID: PbTRI29B

Date Collected: 12/28/16 08:51

Date Received: 12/28/16 19:15

Lab Sample ID: 460-126112-58

Matrix: Water

Method: 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	12.2		2.0	0.16	ug/L	—		01/09/17 22:34	1

Client Sample ID: PbTRI30A

Date Collected: 12/28/16 08:36

Date Received: 12/28/16 19:15

Lab Sample ID: 460-126112-59

Matrix: Water

Method: 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	24.7		2.0	0.16	ug/L	—		01/09/17 22:37	1

Client Sample ID: PbTRI30B

Date Collected: 12/28/16 08:37

Date Received: 12/28/16 19:15

Lab Sample ID: 460-126112-60

Matrix: Water

Method: 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	5.1		2.0	0.16	ug/L	—		01/09/17 21:58	1

Client Sample ID: PbTRI31A

Date Collected: 12/28/16 08:42

Date Received: 12/28/16 19:15

Lab Sample ID: 460-126112-61

Matrix: Water

Method: 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	81.8		2.0	0.16	ug/L	—		01/09/17 22:40	1

Client Sample ID: PbTRI31B

Date Collected: 12/28/16 08:43

Date Received: 12/28/16 19:15

Lab Sample ID: 460-126112-62

Matrix: Water

Method: 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	11.4		2.0	0.16	ug/L	—		01/09/17 22:43	1

Client Sample ID: PbTRI32A

Date Collected: 12/28/16 08:52

Date Received: 12/28/16 19:15

Lab Sample ID: 460-126112-63

Matrix: Water

Method: 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	3.1		2.0	0.16	ug/L	—		01/09/17 22:53	1

Client Sample Results

Client: Pennoni Associates, Inc.
Project/Site: Rowan Univ. RCFM1614

TestAmerica Job ID: 460-126112-1

Client Sample ID: PbTRI32B

Date Collected: 12/28/16 08:53

Date Received: 12/28/16 19:15

Lab Sample ID: 460-126112-64

Matrix: Water

Method: 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	6.9		2.0	0.16	ug/L	—		01/09/17 22:56	1

Client Sample ID: PbTRI33A

Date Collected: 12/28/16 09:01

Date Received: 12/28/16 19:15

Lab Sample ID: 460-126112-65

Matrix: Water

Method: 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	38.9		2.0	0.16	ug/L	—	01/03/17 13:52	01/04/17 15:41	1

Client Sample ID: PbTRI33B

Date Collected: 12/28/16 09:02

Date Received: 12/28/16 19:15

Lab Sample ID: 460-126112-66

Matrix: Water

Method: 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	3.3		2.0	0.16	ug/L	—		01/09/17 22:06	1

Client Sample ID: PbTRI34A

Date Collected: 12/28/16 08:59

Date Received: 12/28/16 19:15

Lab Sample ID: 460-126112-67

Matrix: Water

Method: 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	32.1		2.0	0.16	ug/L	—		01/09/17 23:13	1

Client Sample ID: PbTRI34B

Date Collected: 12/28/16 09:00

Date Received: 12/28/16 19:15

Lab Sample ID: 460-126112-68

Matrix: Water

Method: 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	35.4		2.0	0.16	ug/L	—		01/03/17 20:59	1

Client Sample ID: PbTRI35A

Date Collected: 12/28/16 08:55

Date Received: 12/28/16 19:15

Lab Sample ID: 460-126112-69

Matrix: Water

Method: 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	64.9		2.0	0.16	ug/L	—		01/03/17 21:01	1

Client Sample ID: PbTRI35B

Date Collected: 12/28/16 08:56

Date Received: 12/28/16 19:15

Lab Sample ID: 460-126112-70

Matrix: Water

Method: 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	90.2		2.0	0.16	ug/L	—		01/03/17 21:04	1

Client Sample Results

Client: Pennoni Associates, Inc.
Project/Site: Rowan Univ. RCFM1614

TestAmerica Job ID: 460-126112-1

Client Sample ID: PbTRI36A

Date Collected: 12/28/16 08:49

Date Received: 12/28/16 19:15

Lab Sample ID: 460-126112-71

Matrix: Water

Method: 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	11.1		2.0	0.16	ug/L	—		01/03/17 21:07	1

Client Sample ID: PbTRI36B

Date Collected: 12/28/16 08:50

Date Received: 12/28/16 19:15

Lab Sample ID: 460-126112-72

Matrix: Water

Method: 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	3.4		2.0	0.16	ug/L	—		01/03/17 21:10	1

Client Sample ID: PbTRI37A

Date Collected: 12/28/16 08:45

Date Received: 12/28/16 19:15

Lab Sample ID: 460-126112-73

Matrix: Water

Method: 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	2.0		2.0	0.16	ug/L	—		01/03/17 21:13	1

Client Sample ID: PbTRI37B

Date Collected: 12/28/16 08:46

Date Received: 12/28/16 19:15

Lab Sample ID: 460-126112-74

Matrix: Water

Method: 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	2.7		2.0	0.16	ug/L	—		01/03/17 21:18	1

Client Sample ID: PbTRI38A

Date Collected: 12/28/16 08:40

Date Received: 12/28/16 19:15

Lab Sample ID: 460-126112-75

Matrix: Water

Method: 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	1.6	J	2.0	0.16	ug/L	—		01/03/17 21:20	1

Client Sample ID: PbTRI38B

Date Collected: 12/28/16 08:41

Date Received: 12/28/16 19:15

Lab Sample ID: 460-126112-76

Matrix: Water

Method: 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	3.3		2.0	0.16	ug/L	—		01/03/17 21:23	1

Client Sample ID: PbTRI39A

Date Collected: 12/28/16 09:13

Date Received: 12/28/16 19:15

Lab Sample ID: 460-126112-77

Matrix: Water

Method: 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	60.1		2.0	0.16	ug/L	—	01/03/17 13:52	01/04/17 15:55	1

Client Sample Results

Client: Pennoni Associates, Inc.
Project/Site: Rowan Univ. RCFM1614

TestAmerica Job ID: 460-126112-1

Client Sample ID: PbTRI39B

Date Collected: 12/28/16 09:14

Date Received: 12/28/16 19:15

Lab Sample ID: 460-126112-78

Matrix: Water

Method: 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	2.9		2.0	0.16	ug/L	—		01/03/17 21:38	1

Client Sample ID: PbTRI40A

Date Collected: 12/28/16 09:15

Date Received: 12/28/16 19:15

Lab Sample ID: 460-126112-79

Matrix: Water

Method: 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	14.0		2.0	0.16	ug/L	—		01/03/17 21:41	1

Client Sample ID: PbTRI40B

Date Collected: 12/28/16 09:16

Date Received: 12/28/16 19:15

Lab Sample ID: 460-126112-80

Matrix: Water

Method: 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	1.5	J	2.0	0.16	ug/L	—		01/03/17 21:52	1

Client Sample ID: PbTRI41A

Date Collected: 12/28/16 09:24

Date Received: 12/28/16 19:15

Lab Sample ID: 460-126112-81

Matrix: Water

Method: 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	7.3		2.0	0.16	ug/L	—		01/03/17 21:55	1

Client Sample ID: PbTRI41B

Date Collected: 12/28/16 09:25

Date Received: 12/28/16 19:15

Lab Sample ID: 460-126112-82

Matrix: Water

Method: 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	4.7		2.0	0.16	ug/L	—		01/03/17 21:57	1

Client Sample ID: PbTRI42A

Date Collected: 12/28/16 09:31

Date Received: 12/28/16 19:15

Lab Sample ID: 460-126112-83

Matrix: Water

Method: 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	87.4		2.0	0.16	ug/L	—	01/03/17 15:45	01/04/17 17:37	1

Client Sample ID: PbTRI42B

Date Collected: 12/28/16 09:32

Date Received: 12/28/16 19:15

Lab Sample ID: 460-126112-84

Matrix: Water

Method: 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	3.7		2.0	0.16	ug/L	—		01/03/17 22:00	1

Client Sample Results

Client: Pennoni Associates, Inc.
Project/Site: Rowan Univ. RCFM1614

TestAmerica Job ID: 460-126112-1

Client Sample ID: PbTRI43A

Date Collected: 12/28/16 09:35

Date Received: 12/28/16 19:15

Lab Sample ID: 460-126112-85

Matrix: Water

Method: 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	131		2.0	0.16	ug/L	—		01/03/17 22:03	1

Client Sample ID: PbTRI43B

Date Collected: 12/28/16 09:36

Date Received: 12/28/16 19:15

Lab Sample ID: 460-126112-86

Matrix: Water

Method: 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	19.0		2.0	0.16	ug/L	—		01/03/17 22:06	1

Client Sample ID: PbTRI44A

Date Collected: 12/28/16 09:28

Date Received: 12/28/16 19:15

Lab Sample ID: 460-126112-87

Matrix: Water

Method: 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	497		2.0	0.16	ug/L	—		01/03/17 22:38	1

Client Sample ID: PbTRI44B

Date Collected: 12/28/16 09:29

Date Received: 12/28/16 19:15

Lab Sample ID: 460-126112-88

Matrix: Water

Method: 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	82.2		2.0	0.16	ug/L	—		01/03/17 22:41	1

Client Sample ID: PbTRI45A

Date Collected: 12/28/16 09:21

Date Received: 12/28/16 19:15

Lab Sample ID: 460-126112-89

Matrix: Water

Method: 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	158		2.0	0.16	ug/L	—		01/03/17 22:32	1

Client Sample ID: PbTRI45B

Date Collected: 12/28/16 09:22

Date Received: 12/28/16 19:15

Lab Sample ID: 460-126112-90

Matrix: Water

Method: 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	11.5		2.0	0.16	ug/L	—		01/03/17 22:49	1

Client Sample ID: PbTRI46A

Date Collected: 12/28/16 09:17

Date Received: 12/28/16 19:15

Lab Sample ID: 460-126112-91

Matrix: Water

Method: 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	2.7		2.0	0.16	ug/L	—		01/03/17 22:52	1

Client Sample Results

Client: Pennoni Associates, Inc.
Project/Site: Rowan Univ. RCFM1614

TestAmerica Job ID: 460-126112-1

Client Sample ID: PbTRI46B

Date Collected: 12/28/16 09:18

Date Received: 12/28/16 19:15

Lab Sample ID: 460-126112-92

Matrix: Water

Method: 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	51.9		2.0	0.16	ug/L	—		01/03/17 22:55	1

Client Sample ID: PbTRI47A

Date Collected: 12/28/16 09:09

Date Received: 12/28/16 19:15

Lab Sample ID: 460-126112-93

Matrix: Water

Method: 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	42.7		2.0	0.16	ug/L	—	01/03/17 14:12	01/04/17 15:56	1

Client Sample ID: PbTRI47B

Date Collected: 12/28/16 09:10

Date Received: 12/28/16 19:15

Lab Sample ID: 460-126112-94

Matrix: Water

Method: 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	1.5	J	2.0	0.16	ug/L	—		01/03/17 22:58	1

Client Sample ID: PbTRI48A

Date Collected: 12/28/16 09:05

Date Received: 12/28/16 19:15

Lab Sample ID: 460-126112-95

Matrix: Water

Method: 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	29.2		2.0	0.16	ug/L	—		01/03/17 23:01	1

Client Sample ID: PbTRI48B

Date Collected: 12/28/16 09:06

Date Received: 12/28/16 19:15

Lab Sample ID: 460-126112-96

Matrix: Water

Method: 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	11.5		2.0	0.16	ug/L	—		01/03/17 23:10	1

Client Sample ID: PbTRI49A

Date Collected: 12/28/16 09:47

Date Received: 12/28/16 19:15

Lab Sample ID: 460-126112-97

Matrix: Water

Method: 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	563		2.0	0.16	ug/L	—		01/03/17 23:13	1

Client Sample ID: PbTRI49B

Date Collected: 12/28/16 09:48

Date Received: 12/28/16 19:15

Lab Sample ID: 460-126112-98

Matrix: Water

Method: 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	30.1		2.0	0.16	ug/L	—		01/03/17 23:15	1

Client Sample Results

Client: Pennoni Associates, Inc.
Project/Site: Rowan Univ. RCFM1614

TestAmerica Job ID: 460-126112-1

Client Sample ID: PbTRI50A

Lab Sample ID: 460-126112-99

Date Collected: 12/28/16 09:52

Matrix: Water

Date Received: 12/28/16 19:15

Method: 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	4.7		2.0	0.16	ug/L			01/03/17 23:24	1

Client Sample ID: PbTRI50B

Lab Sample ID: 460-126112-100

Date Collected: 12/28/16 09:53

Matrix: Water

Date Received: 12/28/16 19:15

Method: 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	6.3		2.0	0.16	ug/L			01/03/17 23:31	1

Client Sample ID: PbTRI51A

Lab Sample ID: 460-126112-101

Date Collected: 12/28/16 09:57

Matrix: Water

Date Received: 12/28/16 19:15

Method: 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	22.8		2.0	0.16	ug/L			01/03/17 23:34	1

Client Sample ID: PbTRI51B

Lab Sample ID: 460-126112-102

Date Collected: 12/28/16 09:58

Matrix: Water

Date Received: 12/28/16 19:15

Method: 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	7.2		2.0	0.16	ug/L			01/03/17 23:37	1

Client Sample ID: PbTRI52A

Lab Sample ID: 460-126112-103

Date Collected: 12/28/16 10:04

Matrix: Water

Date Received: 12/28/16 19:15

Method: 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	189		2.0	0.16	ug/L			01/03/17 23:40	1

Client Sample ID: PbTRI52B

Lab Sample ID: 460-126112-104

Date Collected: 12/28/16 10:05

Matrix: Water

Date Received: 12/28/16 19:15

Method: 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	30.8		2.0	0.16	ug/L			01/03/17 23:42	1

Client Sample ID: PbTRI53A

Lab Sample ID: 460-126112-105

Date Collected: 12/28/16 10:17

Matrix: Water

Date Received: 12/28/16 19:15

Method: 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	8.8		2.0	0.16	ug/L			01/03/17 23:45	1

TestAmerica Edison

Client Sample Results

Client: Pennoni Associates, Inc.
Project/Site: Rowan Univ. RCFM1614

TestAmerica Job ID: 460-126112-1

Client Sample ID: PbTRI53B

Date Collected: 12/28/16 10:18

Date Received: 12/28/16 19:15

Lab Sample ID: 460-126112-106

Matrix: Water

Method: 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	3.4		2.0	0.16	ug/L			01/03/17 23:48	1

Client Sample ID: PbTRI54A

Date Collected: 12/28/16 10:07

Date Received: 12/28/16 19:15

Lab Sample ID: 460-126112-107

Matrix: Water

Method: 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	225		2.0	0.16	ug/L			01/03/17 23:51	1

Client Sample ID: PbTRI54B

Date Collected: 12/28/16 10:08

Date Received: 12/28/16 19:15

Lab Sample ID: 460-126112-108

Matrix: Water

Method: 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	3.5		2.0	0.16	ug/L			01/04/17 00:17	1

Client Sample ID: PbTRI55A

Date Collected: 12/28/16 10:00

Date Received: 12/28/16 19:15

Lab Sample ID: 460-126112-109

Matrix: Water

Method: 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	18.3		2.0	0.16	ug/L			01/04/17 00:23	1

Client Sample ID: PbTRI55B

Date Collected: 12/28/16 10:01

Date Received: 12/28/16 19:15

Lab Sample ID: 460-126112-110

Matrix: Water

Method: 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	3.3		2.0	0.16	ug/L			01/04/17 00:26	1

Client Sample ID: PbTRI56A

Date Collected: 12/28/16 09:54

Date Received: 12/28/16 19:15

Lab Sample ID: 460-126112-111

Matrix: Water

Method: 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	35.1		2.0	0.16	ug/L		01/03/17 14:31	01/04/17 15:58	1

Client Sample ID: PbTRI56B

Date Collected: 12/28/16 09:55

Date Received: 12/28/16 19:15

Lab Sample ID: 460-126112-112

Matrix: Water

Method: 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	1.0	J	2.0	0.16	ug/L			01/09/17 23:17	1

Client Sample Results

Client: Pennoni Associates, Inc.
Project/Site: Rowan Univ. RCFM1614

TestAmerica Job ID: 460-126112-1

Client Sample ID: PbTRI57A

Date Collected: 12/28/16 09:49

Date Received: 12/28/16 19:15

Lab Sample ID: 460-126112-113

Matrix: Water

Method: 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	43.7		2.0	0.16	ug/L			01/04/17 00:38	1

Client Sample ID: PbTRI57B

Date Collected: 12/28/16 09:50

Date Received: 12/28/16 19:15

Lab Sample ID: 460-126112-114

Matrix: Water

Method: 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	0.84	J	2.0	0.16	ug/L			01/04/17 00:41	1

Client Sample ID: PbTRI58A

Date Collected: 12/28/16 10:12

Date Received: 12/28/16 19:15

Lab Sample ID: 460-126112-115

Matrix: Water

Method: 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	6.7		2.0	0.16	ug/L			01/04/17 00:43	1

Client Sample ID: PbTRI58B

Date Collected: 12/28/16 10:12

Date Received: 12/28/16 19:15

Lab Sample ID: 460-126112-116

Matrix: Water

Method: 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	1.7	J	2.0	0.16	ug/L			01/04/17 00:46	1

Client Sample ID: PbTRI59A

Date Collected: 12/28/16 10:14

Date Received: 12/28/16 19:15

Lab Sample ID: 460-126112-117

Matrix: Water

Method: 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	242		6.0	0.47	ug/L		01/03/17 14:49	01/04/17 17:39	3

Client Sample ID: PbTRI59B

Date Collected: 12/28/16 10:15

Date Received: 12/28/16 19:15

Lab Sample ID: 460-126112-118

Matrix: Water

Method: 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	28.5		2.0	0.16	ug/L			01/04/17 00:49	1

Client Sample ID: PbTRI60A

Date Collected: 12/28/16 10:16

Date Received: 12/28/16 19:15

Lab Sample ID: 460-126112-119

Matrix: Water

Method: 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	23.4		2.0	0.16	ug/L		01/03/17 14:49	01/04/17 16:02	1

Client Sample Results

Client: Pennoni Associates, Inc.
Project/Site: Rowan Univ. RCFM1614

TestAmerica Job ID: 460-126112-1

Client Sample ID: PbTRI60B

Lab Sample ID: 460-126112-120

Date Collected: 12/28/16 10:17

Matrix: Water

Date Received: 12/28/16 19:15

Method: 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	1.5	J	2.0	0.16	ug/L	—		01/04/17 00:58	1

Client Sample ID: PbTRI61A

Lab Sample ID: 460-126112-121

Date Collected: 12/28/16 10:20

Matrix: Water

Date Received: 12/28/16 19:15

Method: 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	51.6		2.0	0.16	ug/L	—		01/04/17 01:01	1

Client Sample ID: PbTRI61B

Lab Sample ID: 460-126112-122

Date Collected: 12/28/16 10:20

Matrix: Water

Date Received: 12/28/16 19:15

Method: 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	2.8		2.0	0.16	ug/L	—		01/04/17 01:10	1

Client Sample ID: PbTRI62A

Lab Sample ID: 460-126112-123

Date Collected: 12/28/16 10:23

Matrix: Water

Date Received: 12/28/16 19:15

Method: 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	37.5		2.0	0.16	ug/L	—		01/04/17 01:13	1

Client Sample ID: PbTRI62B

Lab Sample ID: 460-126112-124

Date Collected: 12/28/16 10:24

Matrix: Water

Date Received: 12/28/16 19:15

Method: 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	13.3		2.0	0.16	ug/L	—		01/04/17 01:16	1

Client Sample ID: PbTRI63A

Lab Sample ID: 460-126112-125

Date Collected: 12/28/16 10:26

Matrix: Water

Date Received: 12/28/16 19:15

Method: 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	133		2.0	0.16	ug/L	—		01/04/17 01:19	1

Client Sample ID: PbTRI63B

Lab Sample ID: 460-126112-126

Date Collected: 12/28/16 10:27

Matrix: Water

Date Received: 12/28/16 19:15

Method: 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	73.7		2.0	0.16	ug/L	—		01/04/17 01:22	1

Client Sample Results

Client: Pennoni Associates, Inc.
Project/Site: Rowan Univ. RCFM1614

TestAmerica Job ID: 460-126112-1

Client Sample ID: PbTRI64A

Date Collected: 12/28/16 10:29

Date Received: 12/28/16 19:15

Lab Sample ID: 460-126112-127

Matrix: Water

Method: 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	72.7		2.0	0.16	ug/L	—		01/04/17 01:25	1

Client Sample ID: PbTRI64B

Date Collected: 12/28/16 10:30

Date Received: 12/28/16 19:15

Lab Sample ID: 460-126112-128

Matrix: Water

Method: 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	3.2		2.0	0.16	ug/L	—		01/04/17 01:28	1

Client Sample ID: PbTRI65A

Date Collected: 12/28/16 10:28

Date Received: 12/28/16 19:15

Lab Sample ID: 460-126112-129

Matrix: Water

Method: 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	18.9		2.0	0.16	ug/L	—		01/04/17 01:31	1

Client Sample ID: PbTRI65B

Date Collected: 12/28/16 10:29

Date Received: 12/28/16 19:15

Lab Sample ID: 460-126112-130

Matrix: Water

Method: 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	1.0	J	2.0	0.16	ug/L	—		01/04/17 01:34	1

Client Sample ID: PbTRI66A

Date Collected: 12/28/16 10:25

Date Received: 12/28/16 19:15

Lab Sample ID: 460-126112-131

Matrix: Water

Method: 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	7.7		2.0	0.16	ug/L	—		01/04/17 02:35	1

Client Sample ID: PbTRI66B

Date Collected: 12/28/16 10:26

Date Received: 12/28/16 19:15

Lab Sample ID: 460-126112-132

Matrix: Water

Method: 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	1.2	J	2.0	0.16	ug/L	—		01/04/17 02:41	1

Client Sample ID: PbTRI67A

Date Collected: 12/28/16 09:06

Date Received: 12/28/16 19:15

Lab Sample ID: 460-126112-133

Matrix: Water

Method: 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	183		2.0	0.16	ug/L	—		01/04/17 03:21	1

Client Sample Results

Client: Pennoni Associates, Inc.
Project/Site: Rowan Univ. RCFM1614

TestAmerica Job ID: 460-126112-1

Client Sample ID: PbTRI67B

Date Collected: 12/28/16 09:06

Date Received: 12/28/16 19:15

Lab Sample ID: 460-126112-134

Matrix: Water

Method: 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	221		2.0	0.16	ug/L	—		01/04/17 03:24	1

Client Sample ID: PbTRI68A

Date Collected: 12/28/16 09:09

Date Received: 12/28/16 19:15

Lab Sample ID: 460-126112-135

Matrix: Water

Method: 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	224		2.0	0.16	ug/L	—		01/04/17 03:27	1

Client Sample ID: PbTRI68B

Date Collected: 12/28/16 09:10

Date Received: 12/28/16 19:15

Lab Sample ID: 460-126112-136

Matrix: Water

Method: 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	8.4		2.0	0.16	ug/L	—		01/04/17 03:30	1

Client Sample ID: PbTRI69A

Date Collected: 12/28/16 09:12

Date Received: 12/28/16 19:15

Lab Sample ID: 460-126112-137

Matrix: Water

Method: 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	50.3		2.0	0.16	ug/L	—	01/03/17 14:49	01/04/17 16:04	1

Client Sample ID: PbTRI69B

Date Collected: 12/28/16 09:13

Date Received: 12/28/16 19:15

Lab Sample ID: 460-126112-138

Matrix: Water

Method: 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	152		2.0	0.16	ug/L	—		01/04/17 03:33	1

Client Sample ID: PbTRI70A

Date Collected: 12/28/16 09:15

Date Received: 12/28/16 19:15

Lab Sample ID: 460-126112-139

Matrix: Water

Method: 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	273		2.0	0.16	ug/L	—		01/04/17 03:36	1

Client Sample ID: PbTRI70B

Date Collected: 12/28/16 09:16

Date Received: 12/28/16 19:15

Lab Sample ID: 460-126112-140

Matrix: Water

Method: 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	1210		40.0	3.1	ug/L	—	01/03/17 14:59	01/04/17 17:43	20

Client Sample Results

Client: Pennoni Associates, Inc.
Project/Site: Rowan Univ. RCFM1614

TestAmerica Job ID: 460-126112-1

Client Sample ID: PbTRI71A

Date Collected: 12/28/16 09:18

Date Received: 12/28/16 19:15

Lab Sample ID: 460-126112-141

Matrix: Water

Method: 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	97.6		2.0	0.16	ug/L			01/04/17 03:39	1

Client Sample ID: PbTRI71B

Date Collected: 12/28/16 09:19

Date Received: 12/28/16 19:15

Lab Sample ID: 460-126112-142

Matrix: Water

Method: 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	180		2.0	0.16	ug/L			01/04/17 03:42	1

Client Sample ID: PbTRI72A

Date Collected: 12/28/16 09:21

Date Received: 12/28/16 19:15

Lab Sample ID: 460-126112-143

Matrix: Water

Method: 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	61.1		2.0	0.16	ug/L		01/03/17 14:59	01/04/17 17:26	1

Client Sample ID: PbTRI72B

Date Collected: 12/28/16 09:22

Date Received: 12/28/16 19:15

Lab Sample ID: 460-126112-144

Matrix: Water

Method: 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	95.0		2.0	0.16	ug/L			01/04/17 03:45	1

Client Sample ID: PbTRI73A

Date Collected: 12/28/16 09:25

Date Received: 12/28/16 19:15

Lab Sample ID: 460-126112-145

Matrix: Water

Method: 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	119		2.0	0.16	ug/L			01/04/17 03:53	1

Client Sample ID: PbTRI73B

Date Collected: 12/28/16 09:25

Date Received: 12/28/16 19:15

Lab Sample ID: 460-126112-146

Matrix: Water

Method: 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	15.6		2.0	0.16	ug/L			01/04/17 03:56	1

Client Sample ID: PbTRI74A

Date Collected: 12/28/16 09:29

Date Received: 12/28/16 19:15

Lab Sample ID: 460-126112-147

Matrix: Water

Method: 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	26.0		2.0	0.16	ug/L			01/04/17 03:59	1

Client Sample Results

Client: Pennoni Associates, Inc.
Project/Site: Rowan Univ. RCFM1614

TestAmerica Job ID: 460-126112-1

Client Sample ID: PbTRI74B

Date Collected: 12/28/16 09:30

Date Received: 12/28/16 19:15

Lab Sample ID: 460-126112-148

Matrix: Water

Method: 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	6.7		2.0	0.16	ug/L			01/04/17 04:02	1

Client Sample ID: PbTRI75A

Date Collected: 12/28/16 09:31

Date Received: 12/28/16 19:15

Lab Sample ID: 460-126112-149

Matrix: Water

Method: 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	72.2		2.0	0.16	ug/L			01/04/17 04:05	1

Client Sample ID: PbTRI75B

Date Collected: 12/28/16 09:32

Date Received: 12/28/16 19:15

Lab Sample ID: 460-126112-150

Matrix: Water

Method: 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	3.5		2.0	0.16	ug/L			01/04/17 04:08	1

Client Sample ID: PbTRI76A

Date Collected: 12/28/16 09:40

Date Received: 12/28/16 19:15

Lab Sample ID: 460-126112-151

Matrix: Water

Method: 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	2840		2.0	0.16	ug/L			01/04/17 04:11	1

Client Sample ID: PbTRI76B

Date Collected: 12/28/16 09:41

Date Received: 12/28/16 19:15

Lab Sample ID: 460-126112-152

Matrix: Water

Method: 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	23.3		2.0	0.16	ug/L			01/04/17 04:14	1

Client Sample ID: PbTRI77A

Date Collected: 12/28/16 09:44

Date Received: 12/28/16 19:15

Lab Sample ID: 460-126112-153

Matrix: Water

Method: 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	37.2		2.0	0.16	ug/L		01/03/17 15:38	01/04/17 17:32	1

Client Sample ID: PbTRI77B

Date Collected: 12/28/16 09:45

Date Received: 12/28/16 19:15

Lab Sample ID: 460-126112-154

Matrix: Water

Method: 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	3.7		2.0	0.16	ug/L			01/04/17 04:17	1

Client Sample Results

Client: Pennoni Associates, Inc.
Project/Site: Rowan Univ. RCFM1614

TestAmerica Job ID: 460-126112-1

Client Sample ID: PbTRI78A

Date Collected: 12/28/16 09:48

Date Received: 12/28/16 19:15

Lab Sample ID: 460-126112-155

Matrix: Water

Method: 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	28.6		2.0	0.16	ug/L	—		01/04/17 13:38	1

Client Sample ID: PbTRI78B

Date Collected: 12/28/16 09:48

Date Received: 12/28/16 19:15

Lab Sample ID: 460-126112-156

Matrix: Water

Method: 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	9.8		2.0	0.16	ug/L	—		01/04/17 13:47	1

Client Sample ID: PbTRI79A

Date Collected: 12/28/16 09:50

Date Received: 12/28/16 19:15

Lab Sample ID: 460-126112-157

Matrix: Water

Method: 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	30.7		2.0	0.16	ug/L	—		01/04/17 13:50	1

Client Sample ID: PbTRI79B

Date Collected: 12/28/16 09:51

Date Received: 12/28/16 19:15

Lab Sample ID: 460-126112-158

Matrix: Water

Method: 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	38.6		2.0	0.16	ug/L	—		01/04/17 13:58	1

Client Sample ID: PbTRI80A

Date Collected: 12/28/16 09:52

Date Received: 12/28/16 19:15

Lab Sample ID: 460-126112-159

Matrix: Water

Method: 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	36.8		2.0	0.16	ug/L	—		01/04/17 14:02	1

Client Sample ID: PbTRI80B

Date Collected: 12/28/16 09:53

Date Received: 12/28/16 19:15

Lab Sample ID: 460-126112-160

Matrix: Water

Method: 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	140		2.0	0.16	ug/L	—		01/04/17 14:05	1

Client Sample ID: PbTRI81A

Date Collected: 12/28/16 09:55

Date Received: 12/28/16 19:15

Lab Sample ID: 460-126112-161

Matrix: Water

Method: 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	161		2.0	0.16	ug/L	—	01/03/17 15:38	01/04/17 17:34	1

Client Sample Results

Client: Pennoni Associates, Inc.
Project/Site: Rowan Univ. RCFM1614

TestAmerica Job ID: 460-126112-1

Client Sample ID: PbTRI81B

Lab Sample ID: 460-126112-162

Date Collected: 12/28/16 09:56

Matrix: Water

Date Received: 12/28/16 19:15

Method: 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	116		2.0	0.16	ug/L	—		01/04/17 14:07	1

Client Sample ID: PbTRI82A

Lab Sample ID: 460-126112-163

Date Collected: 12/28/16 09:58

Matrix: Water

Date Received: 12/28/16 19:15

Method: 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	248		2.0	0.16	ug/L	—		01/04/17 14:10	1

Client Sample ID: PbTRI82B

Lab Sample ID: 460-126112-164

Date Collected: 12/28/16 09:59

Matrix: Water

Date Received: 12/28/16 19:15

Method: 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	5.3		2.0	0.16	ug/L	—		01/04/17 14:13	1

Client Sample ID: PbTRI83A

Lab Sample ID: 460-126112-165

Date Collected: 12/28/16 10:01

Matrix: Water

Date Received: 12/28/16 19:15

Method: 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	5.8		2.0	0.16	ug/L	—		01/04/17 14:16	1

Client Sample ID: PbTRI83B

Lab Sample ID: 460-126112-166

Date Collected: 12/28/16 10:02

Matrix: Water

Date Received: 12/28/16 19:15

Method: 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	19.9		2.0	0.16	ug/L	—		01/04/17 14:19	1

Client Sample ID: PbTRI84A

Lab Sample ID: 460-126112-167

Date Collected: 12/28/16 10:04

Matrix: Water

Date Received: 12/28/16 19:15

Method: 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	325		2.0	0.16	ug/L	—		01/04/17 14:22	1

Client Sample ID: PbTRI84B

Lab Sample ID: 460-126112-168

Date Collected: 12/28/16 10:05

Matrix: Water

Date Received: 12/28/16 19:15

Method: 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	22.3		2.0	0.16	ug/L	—		01/04/17 14:25	1

Client Sample Results

Client: Pennoni Associates, Inc.
Project/Site: Rowan Univ. RCFM1614

TestAmerica Job ID: 460-126112-1

Client Sample ID: PbTRI85A

Date Collected: 12/28/16 09:34

Date Received: 12/28/16 19:15

Lab Sample ID: 460-126112-169

Matrix: Water

Method: 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	6.4		2.0	0.16	ug/L	—		01/04/17 14:39	1

Client Sample ID: PbTRI85B

Date Collected: 12/28/16 09:35

Date Received: 12/28/16 19:15

Lab Sample ID: 460-126112-170

Matrix: Water

Method: 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	328		2.0	0.16	ug/L	—		01/04/17 14:42	1

Client Sample ID: PbTRI86A

Date Collected: 12/28/16 09:35

Date Received: 12/28/16 19:15

Lab Sample ID: 460-126112-171

Matrix: Water

Method: 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	839		2.0	0.16	ug/L	—		01/04/17 16:48	1

Client Sample ID: PbTRI86B

Date Collected: 12/28/16 09:35

Date Received: 12/28/16 19:15

Lab Sample ID: 460-126112-172

Matrix: Water

Method: 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	14.3		2.0	0.16	ug/L	—		01/04/17 14:48	1

Client Sample ID: PbTRI87A

Date Collected: 12/28/16 09:37

Date Received: 12/28/16 19:15

Lab Sample ID: 460-126112-173

Matrix: Water

Method: 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	120		2.0	0.16	ug/L	—		01/04/17 14:50	1

Client Sample ID: PbTRI87B

Date Collected: 12/28/16 09:37

Date Received: 12/28/16 19:15

Lab Sample ID: 460-126112-174

Matrix: Water

Method: 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	50.9		2.0	0.16	ug/L	—		01/04/17 14:53	1

Client Sample ID: PbTRI88A

Date Collected: 12/28/16 09:39

Date Received: 12/28/16 19:15

Lab Sample ID: 460-126112-175

Matrix: Water

Method: 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	7.7		2.0	0.16	ug/L	—		01/04/17 14:56	1

Client Sample Results

Client: Pennoni Associates, Inc.
Project/Site: Rowan Univ. RCFM1614

TestAmerica Job ID: 460-126112-1

Client Sample ID: PbTRI88B

Lab Sample ID: 460-126112-176

Date Collected: 12/28/16 09:39

Matrix: Water

Date Received: 12/28/16 19:15

Method: 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	13.6		2.0	0.16	ug/L			01/04/17 15:22	1

Client Sample ID: PbTRI89A

Lab Sample ID: 460-126112-177

Date Collected: 12/28/16 09:41

Matrix: Water

Date Received: 12/28/16 19:15

Method: 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	63.7		2.0	0.16	ug/L			01/04/17 15:28	1

Client Sample ID: PbTRI89B

Lab Sample ID: 460-126112-178

Date Collected: 12/28/16 09:41

Matrix: Water

Date Received: 12/28/16 19:15

Method: 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	86.2		2.0	0.16	ug/L			01/04/17 15:31	1

Client Sample ID: PbTRI90A

Lab Sample ID: 460-126112-179

Date Collected: 12/28/16 09:43

Matrix: Water

Date Received: 12/28/16 19:15

Method: 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	704		2.0	0.16	ug/L			01/04/17 16:57	1

Client Sample ID: PbTRI90B

Lab Sample ID: 460-126112-180

Date Collected: 12/28/16 09:43

Matrix: Water

Date Received: 12/28/16 19:15

Method: 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	138		2.0	0.16	ug/L			01/04/17 17:00	1

Client Sample ID: PbTRI91A

Lab Sample ID: 460-126112-181

Date Collected: 12/28/16 09:45

Matrix: Water

Date Received: 12/28/16 19:15

Method: 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	305		10.0	0.79	ug/L			01/04/17 21:58	5

Client Sample ID: PbTRI91B

Lab Sample ID: 460-126112-182

Date Collected: 12/28/16 09:45

Matrix: Water

Date Received: 12/28/16 19:15

Method: 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	88.1		2.0	0.16	ug/L			01/04/17 17:05	1

Client Sample Results

Client: Pennoni Associates, Inc.
Project/Site: Rowan Univ. RCFM1614

TestAmerica Job ID: 460-126112-1

Client Sample ID: PbTRI92A

Date Collected: 12/28/16 09:48

Date Received: 12/28/16 19:15

Lab Sample ID: 460-126112-183

Matrix: Water

Method: 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	261		10.0	0.79	ug/L			01/04/17 22:01	5

Client Sample ID: PbTRI92B

Date Collected: 12/28/16 09:48

Date Received: 12/28/16 19:15

Lab Sample ID: 460-126112-184

Matrix: Water

Method: 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	153		2.0	0.16	ug/L			01/04/17 17:11	1

Client Sample ID: PbTRI93A

Date Collected: 12/28/16 09:46

Date Received: 12/28/16 19:15

Lab Sample ID: 460-126112-185

Matrix: Water

Method: 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	71.2		2.0	0.16	ug/L		01/03/17 15:43	01/04/17 17:35	1

Client Sample ID: PbTRI93B

Date Collected: 12/28/16 09:46

Date Received: 12/28/16 19:15

Lab Sample ID: 460-126112-186

Matrix: Water

Method: 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	2.5		2.0	0.16	ug/L			01/04/17 17:20	1

Client Sample ID: PbTRI94A

Date Collected: 12/28/16 09:50

Date Received: 12/28/16 19:15

Lab Sample ID: 460-126112-187

Matrix: Water

Method: 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	99.8		2.0	0.16	ug/L			01/04/17 17:23	1

Client Sample ID: PbTRI94B

Date Collected: 12/28/16 09:50

Date Received: 12/28/16 19:15

Lab Sample ID: 460-126112-188

Matrix: Water

Method: 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	98.2		2.0	0.16	ug/L			01/04/17 17:26	1

Client Sample ID: PbTRI95A

Date Collected: 12/28/16 09:56

Date Received: 12/28/16 19:15

Lab Sample ID: 460-126112-189

Matrix: Water

Method: 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	188		2.0	0.16	ug/L			01/04/17 17:28	1

Client Sample Results

Client: Pennoni Associates, Inc.
Project/Site: Rowan Univ. RCFM1614

TestAmerica Job ID: 460-126112-1

Client Sample ID: PbTRI95B

Lab Sample ID: 460-126112-190

Date Collected: 12/28/16 09:56

Matrix: Water

Date Received: 12/28/16 19:15

Method: 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	5.1		2.0	0.16	ug/L			01/04/17 16:28	1

Client Sample ID: PbTRI96A

Lab Sample ID: 460-126112-191

Date Collected: 12/28/16 09:58

Matrix: Water

Date Received: 12/28/16 19:15

Method: 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	442		2.0	0.16	ug/L			01/04/17 16:31	1

Client Sample ID: PbTRI96B

Lab Sample ID: 460-126112-192

Date Collected: 12/28/16 09:58

Matrix: Water

Date Received: 12/28/16 19:15

Method: 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	9.8		2.0	0.16	ug/L			01/04/17 16:34	1

Client Sample ID: PbTRI97A

Lab Sample ID: 460-126112-193

Date Collected: 12/28/16 10:00

Matrix: Water

Date Received: 12/28/16 19:15

Method: 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	2070		2.0	0.16	ug/L			01/04/17 16:37	1

Client Sample ID: PbTRI97B

Lab Sample ID: 460-126112-194

Date Collected: 12/28/16 10:00

Matrix: Water

Date Received: 12/28/16 19:15

Method: 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	72.1		2.0	0.16	ug/L			01/04/17 16:40	1

Client Sample ID: PbTRI98A

Lab Sample ID: 460-126112-195

Date Collected: 12/28/16 10:02

Matrix: Water

Date Received: 12/28/16 19:15

Method: 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	32.3		2.0	0.16	ug/L			01/04/17 16:43	1

Client Sample ID: PbTRI98B

Lab Sample ID: 460-126112-196

Date Collected: 12/28/16 10:02

Matrix: Water

Date Received: 12/28/16 19:15

Method: 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	2.3		2.0	0.16	ug/L			01/04/17 16:45	1

Client Sample Results

Client: Pennoni Associates, Inc.
Project/Site: Rowan Univ. RCFM1614

TestAmerica Job ID: 460-126112-1

Client Sample ID: PbTRI99A

Date Collected: 12/28/16 10:04

Date Received: 12/28/16 19:15

Lab Sample ID: 460-126112-197

Matrix: Water

Method: 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	67.8		2.0	0.16	ug/L	—		01/04/17 17:54	1

Client Sample ID: PbTRI99B

Date Collected: 12/28/16 10:04

Date Received: 12/28/16 19:15

Lab Sample ID: 460-126112-198

Matrix: Water

Method: 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	50.4		2.0	0.16	ug/L	—		01/04/17 18:00	1

Client Sample ID: PbTRI100A

Date Collected: 12/28/16 10:06

Date Received: 12/28/16 19:15

Lab Sample ID: 460-126112-199

Matrix: Water

Method: 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	75.6		2.0	0.16	ug/L	—		01/04/17 18:03	1

Client Sample ID: PbTRI100B

Date Collected: 12/28/16 10:06

Date Received: 12/28/16 19:15

Lab Sample ID: 460-126112-200

Matrix: Water

Method: 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	39.8		2.0	0.16	ug/L	—		01/04/17 18:12	1

Client Sample ID: PbTRI101A

Date Collected: 12/28/16 10:08

Date Received: 12/28/16 19:15

Lab Sample ID: 460-126112-201

Matrix: Water

Method: 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	154		2.0	0.16	ug/L	—		01/04/17 18:15	1

Client Sample ID: PbTRI101B

Date Collected: 12/28/16 10:08

Date Received: 12/28/16 19:15

Lab Sample ID: 460-126112-202

Matrix: Water

Method: 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	16.3		2.0	0.16	ug/L	—		01/04/17 18:17	1

Client Sample ID: PbTRI102A

Date Collected: 12/28/16 10:10

Date Received: 12/28/16 19:15

Lab Sample ID: 460-126112-203

Matrix: Water

Method: 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	165		20.0	1.6	ug/L	—	01/04/17 13:49	01/05/17 14:41	10

Client Sample Results

Client: Pennoni Associates, Inc.
Project/Site: Rowan Univ. RCFM1614

TestAmerica Job ID: 460-126112-1

Client Sample ID: PbTRI102B

Lab Sample ID: 460-126112-204

Date Collected: 12/28/16 10:10

Matrix: Water

Date Received: 12/28/16 19:15

Method: 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	82.1		2.0	0.16	ug/L	—		01/04/17 18:20	1

Client Sample ID: PbTRI103A

Lab Sample ID: 460-126112-205

Date Collected: 12/28/16 10:12

Matrix: Water

Date Received: 12/28/16 19:15

Method: 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	70.8		2.0	0.16	ug/L	—		01/04/17 18:23	1

Client Sample ID: PbTRI103B

Lab Sample ID: 460-126112-206

Date Collected: 12/28/16 10:12

Matrix: Water

Date Received: 12/28/16 19:15

Method: 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	114		2.0	0.16	ug/L	—		01/04/17 18:26	1

Client Sample ID: PbTRI104A

Lab Sample ID: 460-126112-207

Date Collected: 12/28/16 10:16

Matrix: Water

Date Received: 12/28/16 19:15

Method: 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	26.6		2.0	0.16	ug/L	—		01/04/17 18:35	1

Client Sample ID: PbTRI104B

Lab Sample ID: 460-126112-208

Date Collected: 12/28/16 10:16

Matrix: Water

Date Received: 12/28/16 19:15

Method: 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	5.9		2.0	0.16	ug/L	—		01/04/17 18:38	1

Client Sample ID: PbTRI105A

Lab Sample ID: 460-126112-209

Date Collected: 12/28/16 10:18

Matrix: Water

Date Received: 12/28/16 19:15

Method: 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	327		2.0	0.16	ug/L	—		01/04/17 18:46	1

Client Sample ID: PbTRI105B

Lab Sample ID: 460-126112-210

Date Collected: 12/28/16 10:18

Matrix: Water

Date Received: 12/28/16 19:15

Method: 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	24.0		2.0	0.16	ug/L	—		01/04/17 18:49	1

Client Sample Results

Client: Pennoni Associates, Inc.
Project/Site: Rowan Univ. RCFM1614

TestAmerica Job ID: 460-126112-1

Client Sample ID: PbTRI106A

Date Collected: 12/28/16 10:20

Date Received: 12/28/16 19:15

Lab Sample ID: 460-126112-211

Matrix: Water

Method: 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	45.8		2.0	0.16	ug/L		01/04/17 13:49	01/05/17 14:44	1

Client Sample ID: PbTRI106B

Date Collected: 12/28/16 10:20

Date Received: 12/28/16 19:15

Lab Sample ID: 460-126112-212

Matrix: Water

Method: 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	0.97	J	2.0	0.16	ug/L			01/04/17 18:52	1

Client Sample ID: PbTRI107A

Date Collected: 12/28/16 10:22

Date Received: 12/28/16 19:15

Lab Sample ID: 460-126112-213

Matrix: Water

Method: 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	75.7		2.0	0.16	ug/L			01/04/17 18:55	1

Client Sample ID: PbTRI107B

Date Collected: 12/28/16 10:22

Date Received: 12/28/16 19:15

Lab Sample ID: 460-126112-214

Matrix: Water

Method: 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	21.8		2.0	0.16	ug/L			01/04/17 18:58	1

Client Sample ID: PbTRI108A

Date Collected: 12/28/16 10:24

Date Received: 12/28/16 19:15

Lab Sample ID: 460-126112-215

Matrix: Water

Method: 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	119		2.0	0.16	ug/L		01/04/17 13:49	01/05/17 14:50	1

Client Sample ID: PbTRI108B

Date Collected: 12/28/16 10:24

Date Received: 12/28/16 19:15

Lab Sample ID: 460-126112-216

Matrix: Water

Method: 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	8.8		2.0	0.16	ug/L			01/04/17 19:02	1

Client Sample ID: PbTRI109A

Date Collected: 12/28/16 10:26

Date Received: 12/28/16 19:15

Lab Sample ID: 460-126112-217

Matrix: Water

Method: 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	34.0		2.0	0.16	ug/L			01/04/17 19:05	1

Client Sample Results

Client: Pennoni Associates, Inc.
Project/Site: Rowan Univ. RCFM1614

TestAmerica Job ID: 460-126112-1

Client Sample ID: PbTRI109B

Lab Sample ID: 460-126112-218

Date Collected: 12/28/16 10:26

Matrix: Water

Date Received: 12/28/16 19:15

Method: 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	1.9	J	2.0	0.16	ug/L	—		01/04/17 19:08	1

Client Sample ID: PbTRI110A

Lab Sample ID: 460-126112-219

Date Collected: 12/28/16 10:30

Matrix: Water

Date Received: 12/28/16 19:15

Method: 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	232		2.0	0.16	ug/L	—		01/04/17 21:00	1

Client Sample ID: PbTRI110B

Lab Sample ID: 460-126112-220

Date Collected: 12/28/16 10:30

Matrix: Water

Date Received: 12/28/16 19:15

Method: 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	88.4		2.0	0.16	ug/L	—		01/04/17 19:43	1

Client Sample ID: PbTRI111A

Lab Sample ID: 460-126112-221

Date Collected: 12/28/16 10:28

Matrix: Water

Date Received: 12/28/16 19:15

Method: 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	192		2.0	0.16	ug/L	—		01/04/17 19:46	1

Client Sample ID: PbTRI111B

Lab Sample ID: 460-126112-222

Date Collected: 12/28/16 10:28

Matrix: Water

Date Received: 12/28/16 19:15

Method: 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	5.8		2.0	0.16	ug/L	—		01/04/17 19:54	1

Client Sample ID: PbTRI112A

Lab Sample ID: 460-126112-223

Date Collected: 12/28/16 10:32

Matrix: Water

Date Received: 12/28/16 19:15

Method: 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	646		2.0	0.16	ug/L	—		01/04/17 19:37	1

Client Sample ID: PbTRI112B

Lab Sample ID: 460-126112-224

Date Collected: 12/28/16 10:32

Matrix: Water

Date Received: 12/28/16 19:15

Method: 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	23.2		2.0	0.16	ug/L	—		01/04/17 19:57	1

Client Sample Results

Client: Pennoni Associates, Inc.
Project/Site: Rowan Univ. RCFM1614

TestAmerica Job ID: 460-126112-1

Client Sample ID: PbTRI113A

Lab Sample ID: 460-126112-225

Date Collected: 12/28/16 09:51

Matrix: Water

Date Received: 12/28/16 19:15

Method: 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	418		10.0	0.79	ug/L	—		01/04/17 22:04	5

Client Sample ID: PbTRI113B

Lab Sample ID: 460-126112-226

Date Collected: 12/28/16 09:51

Matrix: Water

Date Received: 12/28/16 19:15

Method: 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	143		2.0	0.16	ug/L	—		01/04/17 20:03	1