Rowan University Water-Quality Test Results

Report: Sept. 1, 2017 - Summary of Technical/Lab Results

Below is a summary of the techinical/lab results posted at www.rowan.edu/home/water-quality/test-results/technical-data. The U.S. EPA requires that action be taken when the level of lead in water reaches 15 parts per billion (ppb). Buildings are listed alphabetically. Two samples were taken from each outlet (A&B), following national protocols for testing water for lead. There were also times when C&D, E&F or even G&H samples were taken from the same outlet. Please visit www.rowan.edu/water for information about action taken.

Sample ID	Building	Room/Location	Sample Location	Sample No.	Draw	Result (ug/L)	Date	Draw	Result (ug/L)	Date	Draw	Result (ug/L)	Date	Draw	Result (ug/L)	Date	Notes
Pb301	301 High Street	Room 103	sink	2	A	1.1	11/10/16										
Pb301	301 High Street	Room 103	sink	2	B	0.34	11/10/16										
Pb301	301 High Street	Room 206	water fountain	3	A	0.26	11/10/16										
Pb301	301 High Street	Room 206	water fountain	3	B	0.09	11/10/16										
Pb301	301 High Street	Room 306	sink	4	A	0.52	11/10/16										
Pb301	301 High Street	Room 306	sink	4	B	0.09	11/10/16										
Pb301	301 High Street	Room 308	water fountain	5	A	0.37	11/10/16										
Pb301	301 High Street	Room 308	water fountain	5	B	0.09	11/10/16										
PbSHP	Alvin Shpeen	Room 103	sink	2	A	1	11/3/16										
PbSHP	Alvin Shpeen	Room 103	sink	2	B	0.74	11/3/16										
PbSHP	Alvin Shpeen	Room 103	fridge water dispenser	3	A	0.94	11/3/16										
PbSHP	Alvin Shpeen	Room 103	fridge water dispenser	3	B	0.21	11/3/16										
PbSHP	Alvin Shpeen	Room 230	sink	4	A	2.2	11/3/16										
PbSHP	Alvin Shpeen	Room 230	sink	4	B	1	11/3/16										
PbSHP	Alvin Shpeen	Room 230	fridge water dispenser	5	A	0.16	11/3/16										
PbSHP	Alvin Shpeen	Room 332	sink	6	A	1.3	11/3/16										
PbSHP	Alvin Shpeen	Room 332	sink	6	B	0.65	11/3/16										
PbBOL	Bole Admin.	Room 100G	sink	2	A	0.56	11/1/16										
PbBOL	Bole Admin.	Room 100G	sink	2	B	0.42	11/1/16										
PbBOL	Bole Admin.	Room 110	sink	3	A	0.69	11/1/16										
PbBOL	Bole Admin.	Room 110	sink	3	B	0.23	11/1/16										
PbBOL	Bole Admin.	Hall by Room 108	water fountain	4	A	0.16	11/1/16										
PbBOL	Bole Admin.	Hall by Room 108	water fountain	4	B	0.16	11/1/16										
PbBOLA	Bole Annex	L100	water fountain	2	A	0.16	11/15/16										
PbBOLA	Bole Annex	L100	water fountain	2	B	0.16	11/15/16										
PbBOZ	Bozorth Admin	Room H107	water fountain	2	A	0.16	11/1/16										
PbBOZ	Bozorth Admin	Room H107	water fountain	2	B	0.16	11/1/16										
PbBOZ	Bozorth Admin	Room H105	water fountain	3	A	0.16	11/1/16										
PbBOZ	Bozorth Admin	Room H105	water fountain	3	B	0.16	11/1/16										
PbBOZ	Bozorth Admin	Room H103	water fountain	4	A	0.59	11/1/16										
PbBOZ	Bozorth Admin	Room H103	water fountain	4	B	0.33	11/1/16										
PbBUN	Bunce Hall	Room 162	water fountain	2	A	0.31	11/1/16										
PbBUN	Bunce Hall	Room 162	water fountain	2	B	0.16	11/1/16										
PbBUN	Bunce Hall	Room 105	water fountain	3	A	0.22	11/1/16										
PbBUN	Bunce Hall	Room 105	water fountain	3	B	0.16	11/1/16										
PbBUN	Bunce Hall	Room 206	water fountain	4	A	3.4	11/1/16										
PbBUN	Bunce Hall	Room 206	water fountain	4	B	0.6	11/1/16										
PbBUN	Bunce Hall	Room 252	water fountain	5	A	0.19	11/1/16										
PbBUN	Bunce Hall	Room 252	water fountain	5	B	0.16	11/1/16										
PbBUN	Bunce Hall	Room 347	water fountain	6	A	0.74	11/1/16										
PbBUN	Bunce Hall	Room 347	water fountain	6	B	0.16	11/1/16										
PbBUN	Bunce Hall	Room 304	water fountain	7	A	0.82	11/1/16										
PbBUN	Bunce Hall	Room 304	water fountain	7	B	0.16	11/1/16										
PbCAM	Campbell Library	Room 114	sink	2	A	0.63	11/8/16										

Sample ID	Building	Room/Location	Sample Location	Sample No.	Draw	Result (ug/L)	Date	Draw	Result (ug/L)	Date	Draw	Result (ug/L)	Date	Draw	Result (ug/L)	Date	Notes
PbCAM	Campbell Library	Room 114	sink	2	B	0.22	11/8/16										
PbCAM	Campbell Library	Room 115	water fountain	3	A	0.09	11/8/16										
PbCAM	Campbell Library	Room 115	water fountain	3	B	0.09	11/8/16										
PbCAM	Campbell Library	Room H217	water fountain	4	A	0.23	11/8/16										
PbCAM	Campbell Library	Room H217	water fountain	4	B	0.09	11/8/16										
PbCAM	Campbell Library	Room 253	sink	5	A	0.96	11/8/16										
PbCAM	Campbell Library	Room 253	sink	5	B	0.32	11/8/16										
PbCAM	Campbell Library	Room 310	water fountain	6	A	0.48	11/8/16										
PbCAM	Campbell Library	Room 310	water fountain	6	B	0.27	11/8/16										
PbCAM	Campbell Library	Room W303	sink	7	A	2.6	11/8/16										
PbCAM	Campbell Library	Room W303	sink	7	B	0.36	11/8/16										
PbCAM	Campbell Library	Room W303	sink	8	A	0.39	11/8/16										
PbCAM	Campbell Library	Room W303	sink	8	B	0.25	11/8/16										
PbCAM	Campbell Library	Room 324A	sink	9	A	0.33	11/8/16										
PbCAM	Campbell Library	Room 324A	sink	9	B	0.35	11/8/16										
PbCAM	Campbell Library	Room 324A	fridge water dispenser	11	A	7.5	11/8/16										
PbCAM	Campbell Library	Room 324A	fridge water dispenser	11	B	0.89	11/8/16										
PbCAM	Campbell Library	Room 326A	sink	12	A	33.4	11/8/16	C	0.16	2/28/17							
PbCAM	Campbell Library	Room 326A	sink	12	B	1.6	11/8/16	D	0.16	2/28/17							
PbCAM	Campbell Library	Room 303	sink	13	A	0.78	11/8/16										
PbCAM	Campbell Library	Room 303	sink	13	B	0.37	11/8/16										
PbCAM	Campbell Library	Room 303	fridge water dispenser	14	A	0.09	11/8/16										
PbCAM	Campbell Library	Room 303	fridge water dispenser	14	B	0.44	11/8/16										
PbCAM	Campbell Library	Room 410	water fountain	15	A	0.55	11/8/16										
PbCAM	Campbell Library	Room 410	water fountain	15	B	0.24	11/8/16										
PbCAM	Campbell Library	Room 503	sink	16	A	2.1	11/8/16										
PbCAM	Campbell Library	Room 503	sink	16	B	0.38	11/8/16										
PbCAM	Campbell Library	Room 603	sink	17	A	1.8	11/8/16										
PbCAM	Campbell Library	Room 603	sink	17	B	0.22	11/8/16										
PbCAM	Campbell Library	Room 603	sink	17	A	1.8	11/8/16										
PbCAM	Campbell Library	Room 603	sink	17	B	0.22	11/8/16										
PbCAM	Campbell Library	Room 550	sink	18	A	1.1	11/8/16										
PbCAM	Campbell Library	Room 550	sink	18	B	0.49	11/8/16										
PbCAM	Campbell Library	Room 521	water fountain	19	A	1.6	11/8/16										
PbCAM	Campbell Library	Room 521	water fountain	19	B	0.41	11/8/16										
PbCAR	Carriage House	Room 202	sink	2	A	0.16	11/3/16										
PbCAR	Carriage House	Room 202	sink	2	B	0.16	11/3/16										
PbCAS	Cassady Facilities	Room 107B	backflow preventer	1	A	1280	11/15/16	C	445	2/23/17							Although water tested at backflow preventer (where water first enters the building) shows a high concentation of lead, faucets throughout the buildings fall below the 15ppb threshold.
PbCAS	Cassady Facilities	Room 107B	backflow preventer	1	B	105	11/15/16	D	88.8	2/23/17							Although water tested at backflow preventer (where water first enters the building) shows a high concentation of lead, faucets throughout the buildings fall below the 15ppb threshold.
PbCAS	Cassady Facilities	Room 107	water fountain	3	A	1	11/15/16										
PbCAS	Cassady Facilities	Room 107	water fountain	3	B	0.51	11/15/16										
PbCAS	Cassady Facilities	Room 107	coffee pot/ water disp	4	A	1.7	11/15/16										
PbCAS	Cassady Facilities	Room 107	coffee pot/ water disp	4	B	0.41	11/15/16										
PbCAS	Cassady Facilities	Room 112	water fountain	5	A	0.19	11/15/16										
PbCAS	Cassady Facilities	Room 112	water fountain	5	B	0.16	11/15/16										
PbCAS	Cassady Facilities	Room 106	water fountain	6	A	0.56	11/15/16										
PbCAS	Cassady Facilities	Room 106	water fountain	6	B	0.22	11/15/16										
PbCAS	Cassady Facilities	Room 110	water fountain	7	A	0.47	11/15/16										
PbCAS	Cassady Facilities	Room 110	water fountain	7	B	0.41	11/15/16										
PbCAS	Cassady Facilities	Room MZ110	sink	8	A	2.1	11/15/16										
PbCAS	Cassady Facilities	Room MZ110	sink	8	B	0.63	11/15/16										
PbCAS	Cassady Facilities	Room 111A	sink	9	A	5.5	11/15/16										
PbCAS	Cassady Facilities	Room 111A	sink	9	B	0.51	11/15/16										

Sample ID	Building	Room/Location	Sample Location	Sample No.	Draw	Result (ug/L)	Date	Draw	Result (ug/L)	Date	Draw	Result (ug/L)	Date	Draw	Result (ug/L)	Date	Notes
PbCAS	Cassady Facilities	Room 105 B2	water fountain	10	A	0.29	11/15/16										
PbCAS	Cassady Facilities	Room 105 B2	water fountain	10	B	0.26	11/15/16										
PbCAS	Cassady Facilities	Room 105 B2	coffee pot/ water disp	11	A	77.5	11/15/16	C	4.3	2/23/17							
PbCAS	Cassady Facilities	Room 105 B2	coffee pot/ water disp	11	B	25.5	11/15/16	D	1.2	2/23/17							
PbCAS	Cassady Facilities	Room V100	water fountain	12	A	0.16	11/15/16										
PbCAS	Cassady Facilities	Room V100	water fountain	12	B	0.16	11/15/16										
PbCAS	Cassady Facilities	Room 105 B2 Mezz	sink	13	A	2.4	11/15/16										
PbCAS	Cassady Facilities	Room 105 B2 Mezz	sink	13	B	2.8	11/15/16										
PbCCT	Community Center Townhouse	Room 106MR	Sink off main	1	A	173	1/31/17	C	0.93	3/10/17							
PbCCT	Community Center Townhouse	Room 106MR	Sink off main	1	B	17.7	1/31/17	D	0.27	3/10/17							
PbCCT	Community Center Townhouse	Room 110BA	Sink	2	A	0.16	1/31/17										
PbCCT	Community Center Townhouse	Room 110BA	Sink	2	B	0.16	1/31/17										
PbCCT	Community Center Townhouse	Room L103	Starbucks Machine	3	A	1.3	1/31/17										
PbCCT	Community Center Townhouse	Room L103	Starbucks Machine	3	B	0.29	1/31/17										
PbCCT	Community Center Townhouse	Room L103	Pepsi Machine	4	A	0.16	1/31/17										
PbCCT	Community Center Townhouse	Room L103	Pepsi Machine	4	B	0.81	1/31/17										
PbCCT	Community Center Townhouse	Room L103	Sink adj. to Pepsi Machine	5	A	5.5	1/31/17										
PbCCT	Community Center Townhouse	Room L103	Sink adj. to Pepsi Machine	5	B	0.24	1/31/17										
PbCCT	Community Center Townhouse	Room 119	Kitchen Sink	6	A	1.7	1/31/17										
PbCCT	Community Center Townhouse	Room 119	Kitchen Sink	6	B	0.28	1/31/17										
PbCHE	Chestnut Hall	Room 006MR	Spigot Outside	1	A	69.8	1/3/17										Although water tested at backflow preventer (where water first enters the building) shows a high concentation of lead, faucets throughout the buildings fall below the 15ppb threshold.
PbCHE	Chestnut Hall	Room 006MR	Spigot Outside	1	B	36	1/3/17										Although water tested at backflow preventer (where water first enters the building) shows a high concentation of lead, faucets throughout the buildings fall below the 15ppb threshold.
PbCHE	Chestnut Hall	Room 114BA	sink	2	A	132	1/3/17	C	0.16	3/15/17	E	1.8	7/28/17				
PbCHE	Chestnut Hall	Room 114BA	sink	2	B	16.3	1/3/17	D	0.16	3/15/17	F	1.1	7/28/17				
PbCHE	Chestnut Hall	Room 113BA	sink	3	A	20.9	1/3/17	C	0.16	3/15/17							
PbCHE	Chestnut Hall	Room 113BA	sink	3	B	0.86	1/3/17	D	0.16	3/15/17							
PbCHE	Chestnut Hall	Room 112BA	sink	4	A	4.2	1/3/17	C	0.16	3/15/17							
PbCHE	Chestnut Hall	Room 112BA	sink	4	B	0.87	1/3/17	D	0.16	3/15/17							
PbCHE	Chestnut Hall	Room 111BA	sink	5	A	10.2	1/3/17	C	0.16	3/15/17							
PbCHE	Chestnut Hall	Room 111BA	sink	5	B	4	1/3/17	D	0.16	3/15/17							
PbCHE	Chestnut Hall	Room 110BA	sink	6	A	8.4	1/3/17	C	0.16	3/15/17							
PbCHE	Chestnut Hall	Room 110BA	sink	6	B	1.1	1/3/17	D	0.16	3/15/17							
PbCHE	Chestnut Hall	Room 109a	sink	7	A	5.6	1/3/17	C	1.6	3/15/17							
PbCHE	Chestnut Hall	Room 109a	sink	7	B	0.75	1/3/17	D	0.16	3/15/17							
PbCHE	Chestnut Hall	Room 108BA	sink	8	A	2.7	1/3/17	C	0.16	3/15/17							
PbCHE	Chestnut Hall	Room 108BA	sink	8	B	0.66	1/3/17	D	0.16	3/15/17							
PbCHE	Chestnut Hall	Room H107	water fountain	10	A	0.16	1/3/17	C	0.16	3/15/17							
PbCHE	Chestnut Hall	Room H107	water fountain	10	B	0.16	1/3/17	D	0.16	3/15/17							
PbCHE	Chestnut Hall	Room 142BA	sink	11	A	2.7	1/3/17	C	0.16	3/15/17							
PbCHE	Chestnut Hall	Room 142BA	sink	11	B	1.1	1/3/17	D	0.16	3/15/17							
PbCHE	Chestnut Hall	Room 142KN	sink	12	A	8.5	1/3/17	C	0.16	4/27/17							
PbCHE	Chestnut Hall	Room 142KN	sink	12	B	8.4	1/3/17	D	0.16	4/27/17							
PbCHE	Chestnut Hall	Room 141BA	sink	13	A	5.8	1/3/17	C	0.16	3/15/17							
PbCHE	Chestnut Hall	Room 141BA	sink	13	B	1.1	1/3/17	D	0.16	3/15/17							
PbCHE	Chestnut Hall	Room 140BA	sink	14	A	3.4	1/3/17	C	0.16	3/15/17							
PbCHE	Chestnut Hall	Room 140BA	sink	14	B	1.2	1/3/17	D	0.16	3/15/17							
PbCHE	Chestnut Hall	Room 140KN	sink	15	A	201	1/3/17	C	0.22	4/27/17							
PbCHE	Chestnut Hall	Room 140KN	sink	15	B	536	1/3/17	D	0.16	4/27/17							
PbCHE	Chestnut Hall	Room 106BA	sink	16	A	7.2	1/3/17	C	0.16	3/15/17							
PbCHE	Chestnut Hall	Room 106BA	sink	16	B	0.56	1/3/17	D	0.16	3/15/17							
PbCHE	Chestnut Hall	Room 105BA	sink	17	A	4	1/3/17	C	0.16	3/15/17							

Sample ID	Building	Room/Location	Sample Location	Sample No.	Draw	Result (ug/L)	Date	Draw	Result (ug/L)	Date	Draw	Result (ug/L)	Date	Draw	Result (ug/L)	Date	Notes
PbCHE	Chestnut Hall	Room 105BA	sink	17	B	1.4	1/3/17	D	0.16	3/15/17							
PbCHE	Chestnut Hall	Room 104BA	sink	18	A	6.8	1/3/17	C	0.16	3/15/17							
PbCHE	Chestnut Hall	Room 104BA	sink	18	B	0.94	1/3/17	D	0.16	3/15/17							
PbCHE	Chestnut Hall	Room 100BA	sink	19	A	14	1/3/17	C	1	3/15/17							
PbCHE	Chestnut Hall	Room 100BA	sink	19	B	4.8	1/3/17	D	12.4	3/15/17							
PbCHE	Chestnut Hall	Room 101BA	sink	20	A	7.6	1/3/17	C	0.16	3/15/17							
PbCHE	Chestnut Hall	Room 101BA	sink	20	B	0.63	1/3/17	D	0.16	3/15/17							
PbCHE	Chestnut Hall	Room 102BA	sink	21	A	10.2	1/3/17	C	0.16	3/15/17							
PbCHE	Chestnut Hall	Room 102BA	sink	21	B	1.1	1/3/17	D	0.16	3/15/17							
PbCHE	Chestnut Hall	Room 214BA	sink	22	A	312	1/3/17	C	0.37	3/15/17	E	2.1	7/28/17				
PbCHE	Chestnut Hall	Room 214BA	sink	22	B	3	1/3/17	D	0.16	3/15/17	F	0.39	7/28/17				
PbCHE	Chestnut Hall	Room 213BA	sink	23	A	150	1/3/17	C	0.23	3/15/17							
PbCHE	Chestnut Hall	Room 213BA	sink	23	B	12.2	1/3/17	D	0.16	3/15/17							
PbCHE	Chestnut Hall	Room 212BA	sink	24	A	4.7	1/3/17	C	0.17	3/15/17							
PbCHE	Chestnut Hall	Room 212BA	sink	24	B	0.89	1/3/17	D	0.16	3/15/17							
PbCHE	Chestnut Hall	Room 211BA	sink	25	A	3.4	1/3/17	C	0.78	3/15/17							
PbCHE	Chestnut Hall	Room 211BA	sink	25	B	1.7	1/3/17	D	0.16	3/15/17							
PbCHE	Chestnut Hall	Room 210BA	sink	26	A	5.4	1/3/17	C	0.19	3/15/17							
PbCHE	Chestnut Hall	Room 210BA	sink	26	B	0.89	1/3/17	D	0.16	3/15/17							
PbCHE	Chestnut Hall	Room 209BA	sink	27	A	15.8	1/3/17	C	0.16	3/15/17							
PbCHE	Chestnut Hall	Room 209BA	sink	27	B	0.86	1/3/17	D	0.16	3/15/17							
PbCHE	Chestnut Hall	Room 208BA	sink	28	A	28.9	1/3/17	C	0.75	3/15/17	E	0.55	7/28/17				
PbCHE	Chestnut Hall	Room 208BA	sink	28	B	2.2	1/3/17	D	0.16	3/15/17	F	0.26	7/28/17				
PbCHE	Chestnut Hall	Room 207BA	sink	29	A	1.3	1/3/17	C	0.16	3/15/17							
PbCHE	Chestnut Hall	Room 207BA	sink	29	B	0.36	1/3/17	D	0.16	3/15/17							
PbCHE	Chestnut Hall	Room 206BA	sink	30	A	5	1/3/17	C	0.16	3/15/17							
PbCHE	Chestnut Hall	Room 206BA	sink	30	B	0.45	1/3/17	D	0.16	3/15/17							
PbCHE	Chestnut Hall	Room 205BA	sink	31	A	48.6	1/3/17	C	0.16	3/15/17							
PbCHE	Chestnut Hall	Room 205BA	sink	31	B	2	1/3/17	D	0.16	3/15/17							
PbCHE	Chestnut Hall	Room 204BA	sink	32	A	14.3	1/3/17	C	0.16	3/15/17							
PbCHE	Chestnut Hall	Room 204BA	sink	32	B	4.7	1/3/17	D	0.16	3/15/17							
PbCHE	Chestnut Hall	Room 203BA	sink	33	A	7.2	1/3/17	C	0.16	3/15/17							
PbCHE	Chestnut Hall	Room 203BA	sink	33	B	1.2	1/3/17	D	0.16	3/15/17							
PbCHE	Chestnut Hall	Room 202BA	sink	34	A	3.9	1/3/17	C	0.16	3/15/17							
PbCHE	Chestnut Hall	Room 202BA	sink	34	B	0.87	1/3/17	D	0.16	3/15/17							
PbCHE	Chestnut Hall	Room 201BA	sink	35	A	4.2	1/3/17	C	0.18	3/15/17							
PbCHE	Chestnut Hall	Room 201BA	sink	35	B	0.58	1/3/17	D	0.16	3/15/17							
PbCHE	Chestnut Hall	Room 200BA	sink	36	A	2.1	1/3/17	C	0.16	3/15/17							
PbCHE	Chestnut Hall	Room 200BA	sink	36	B	0.49	1/3/17	D	0.16	3/15/17							
PbCHE	Chestnut Hall	Room 314BA	sink	37	A	1.9	1/3/17	C	0.16	3/15/17							
PbCHE	Chestnut Hall	Room 314BA	sink	37	B	0.68	1/3/17	D	0.16	3/15/17							
PbCHE	Chestnut Hall	Room 313BA	sink	38	A	4.1	1/3/17	C	0.16	3/15/17							
PbCHE	Chestnut Hall	Room 313BA	sink	38	B	1.7	1/3/17	D	0.16	3/15/17							
PbCHE	Chestnut Hall	Room 312BA	sink	39	A	2.8	1/3/17	C	0.16	3/15/17							
PbCHE	Chestnut Hall	Room 312BA	sink	39	B	0.75	1/3/17	D	0.16	3/15/17							
PbCHE	Chestnut Hall	Room 311Ba	sink	40	A	2.2	1/3/17	C	0.16	3/15/17							
PbCHE	Chestnut Hall	Room 311Ba	sink	40	B	1.3	1/3/17	D	0.16	3/15/17							
PbCHE	Chestnut Hall	Room 310BA	sink	41	A	1	1/3/17	C	0.16	3/15/17							
PbCHE	Chestnut Hall	Room 310BA	sink	41	B	0.72	1/3/17	D	0.16	3/15/17							
PbCHE	Chestnut Hall	Room 309BA	sink	42	A	2.4	1/3/17	C	0.16	3/15/17							
PbCHE	Chestnut Hall	Room 309BA	sink	42	B	0.72	1/3/17	D	0.16	3/15/17							
PbCHE	Chestnut Hall	Room 308BA	sink	43	A	2.7	1/3/17	C	0.17	3/15/17							
PbCHE	Chestnut Hall	Room 308BA	sink	43	B	1.6	1/3/17	D	0.16	3/15/17							
PbCHE	Chestnut Hall	Room 307BA	sink	44	A	0.3	1/3/17	C	0.16	3/15/17							
PbCHE	Chestnut Hall	Room 307BA	sink	44	B	0.44	1/3/17	D	0.16	3/15/17							
PbCHE	Chestnut Hall	Room 306BA	sink	45	A	1.8	1/3/17	C	0.17	3/15/17							
PbCHE	Chestnut Hall	Room 306BA	sink	45	B	0.7	1/3/17	D	0.16	3/15/17							

Sample ID	Building	Room/Location	Sample Location	Sample No.	Draw	Result (ug/L)	Date	Draw	Result (ug/L)	Date	Draw	Result (ug/L)	Date	Draw	Result (ug/L)	Date	Notes
PbCHE	Chestnut Hall	Room 305BA	sink	46	A	0.81	1/3/17	C	0.16	3/15/17							
PbCHE	Chestnut Hall	Room 305BA	sink	46	B	0.62	1/3/17	D	0.16	3/15/17							
PbCHE	Chestnut Hall	Room 304BA	sink	47	A	1.7	1/3/17	C	0.16	3/15/17							
PbCHE	Chestnut Hall	Room 304BA	sink	47	B	0.45	1/3/17	D	0.16	3/15/17							
PbCHE	Chestnut Hall	Room 303BA	sink	48	A	4.6	1/3/17	C	0.16	3/15/17							
PbCHE	Chestnut Hall	Room 303BA	sink	48	B	0.77	1/3/17	D	0.16	3/15/17							
PbCHE	Chestnut Hall	Room 302BA	sink	49	A	1.9	1/3/17	C	0.16	3/15/17							
PbCHE	Chestnut Hall	Room 302BA	sink	49	B	1.3	1/3/17	D	0.16	3/15/17							
PbCHE	Chestnut Hall	Room 301BA	sink	50	A	1.4	1/3/17	C	0.16	3/15/17							
PbCHE	Chestnut Hall	Room 301BA	sink	50	B	0.67	1/3/17	D	0.16	3/15/17							
PbCHE	Chestnut Hall	Room 300BA	sink	51	A	1.5	1/3/17	C	0.16	3/15/17							
PbCHE	Chestnut Hall	Room 300BA	sink	51	B	0.53	1/3/17	D	0.16	3/15/17							
PbCHE	Chestnut Hall	Room 103BA	sink	52	A	48.8	1/3/17	C	1.3	3/15/17	E	1.9	7/28/17				
PbCHE	Chestnut Hall	Room 103BA	sink	52	B	2	1/3/17	D	0.16	3/15/17	F	0.91	7/28/17				
PbEPA2	Edgewood Park Apartments 200	Room 201KN	Sink	2	A	2.3	12/29/16	C	0.16	3/18/17							
PbEPA2	Edgewood Park Apartments 200	Room 201KN	Sink	2	B	5.3	12/29/16	D	0.16	3/18/17							
PbEPA2	Edgewood Park Apartments 200	Room 203KN	Sink	3	A	1.5	12/29/16	C	0.16	3/18/17							
PbEPA2	Edgewood Park Apartments 200	Room 203KN	Sink	3	B	1.1	12/29/16	D	0.16	3/18/17							
PbEPA2	Edgewood Park Apartments 200	Room 204KN	Sink	4	A	1.6	12/29/16	C	0.16	3/18/17							
PbEPA2	Edgewood Park Apartments 200	Room 204KN	Sink	4	B	2	12/29/16	D	0.16	3/18/17							
PbEPA2	Edgewood Park Apartments 200	Room 202KN	Sink	5	A	1.6	12/29/16	C	0.16	3/18/17							
PbEPA2	Edgewood Park Apartments 200	Room 202KN	Sink	5	B	4.8	12/29/16	D	0.16	3/18/17							
PbEPA2	Edgewood Park Apartments 200	Room 205KN	Sink	6	A	1.9	12/29/16	C	0.16	3/18/17							
PbEPA2	Edgewood Park Apartments 200	Room 205KN	Sink	6	B	1.1	12/29/16	D	0.16	3/18/17							
PbEPA2	Edgewood Park Apartments 200	Room 207KN	Sink	7	A	4.1	12/29/16	C	0.16	3/18/17							
PbEPA2	Edgewood Park Apartments 200	Room 207KN	Sink	7	B	0.49	12/29/16	D	0.16	3/18/17							
PbEPA2	Edgewood Park Apartments 200	Room 208KN	Sink	8	A	2.5	12/29/16	C	0.16	3/18/17							
PbEPA2	Edgewood Park Apartments 200	Room 208KN	Sink	8	B	4.2	12/29/16	D	0.16	3/18/17							
PbEPA2	Edgewood Park Apartments 200	Room 206KN	Sink	9	A	3.5	12/29/16	C	0.16	3/18/17							
PbEPA2	Edgewood Park Apartments 200	Room 206KN	Sink	9	B	3.9	12/29/16	D	0.16	3/18/17							
PbEPA2	Edgewood Park Apartments 200	Room 209KN	Sink	10	A	1.9	12/29/16	C	0.16	3/18/17							
PbEPA2	Edgewood Park Apartments 200	Room 209KN	Sink	10	B	0.58	12/29/16	D	0.16	3/18/17							
PbEPA2	Edgewood Park Apartments 200	Room 211KN	Sink	11	A	1.5	12/29/16	C	0.16	3/18/17							
PbEPA2	Edgewood Park Apartments 200	Room 211KN	Sink	11	B	0.18	12/29/16	D	0.16	3/18/17							
PbEPA2	Edgewood Park Apartments 200	Room 212KN	Sink	12	A	2.2	12/29/16	C	0.16	3/18/17	E	1.6	7/28/17				
PbEPA2	Edgewood Park Apartments 200	Room 212KN	Sink	12	B	21	12/29/16	D	0.16	3/18/17	F	0.16	7/28/17				
PbEPA2	Edgewood Park Apartments 200	Room 210KN	Sink	13	A	6.1	12/29/16	C	0.16	3/18/17							
PbEPA2	Edgewood Park Apartments 200	Room 210KN	Sink	13	B	1.5	12/29/16	D	0.16	3/18/17							
PbEPA2	Edgewood Park Apartments 200	Room 213KN	Sink	14	A	0.9	12/29/16	C	0.16	3/18/17							
PbEPA2	Edgewood Park Apartments 200	Room 213KN	Sink	14	B	3.5	12/29/16	D	0.16	3/18/17							
PbEPA2	Edgewood Park Apartments 200	Room 215KN	Sink	15	A	2.4	12/29/16	C	0.16	3/18/17							
PbEPA2	Edgewood Park Apartments 200	Room 215KN	Sink	15	B	3	12/29/16	D	0.16	3/18/17							
PbEPA2	Edgewood Park Apartments 200	Room 216KN	Sink	16	A	2.7	12/29/16	C	0.16	3/18/17							
PbEPA2	Edgewood Park Apartments 200	Room 216KN	Sink	16	B	1.4	12/29/16	D	0.16	3/18/17							
PbEPA2	Edgewood Park Apartments 200	Room 214KN	Sink	17	A	0.98	12/29/16	C	0.16	3/18/17							
PbEPA2	Edgewood Park Apartments 200	Room 214KN	Sink	17	B	3.5	12/29/16	D	0.16	3/18/17							
PbEPA2	Edgewood Park Apartments 200	Room 217KN	Sink	18	A	2.2	12/29/16	C	0.16	3/18/17							
PbEPA2	Edgewood Park Apartments 200	Room 217KN	Sink	18	B	5.6	12/29/16	D	0.16	3/18/17							
PbEPA2	Edgewood Park Apartments 200	Room 219KN	Sink	19	A	2.7	12/29/16	C	0.16	3/18/17							
PbEPA2	Edgewood Park Apartments 200	Room 219KN	Sink	19	B	2	12/29/16	D	0.16	3/18/17							
PbEPA2	Edgewood Park Apartments 200	Room 220KN	Sink	20	A	1.4	12/29/16	C	0.16	3/18/17							
PbEPA2	Edgewood Park Apartments 200	Room 220KN	Sink	20	B	0.82	12/29/16	D	0.16	3/18/17							
PbEPA2	Edgewood Park Apartments 200	Room 218KN	Sink	21	A	2.2	12/29/16	C	0.16	3/18/17							
PbEPA2	Edgewood Park Apartments 200	Room 218KN	Sink	21	B	0.7	12/29/16	D	0.16	3/18/17							
PbEPA2	Edgewood Park Apartments 200	Room 221KN	Sink	22	A	2.8	12/29/16	C	0.16	3/18/17							
PbEPA2	Edgewood Park Apartments 200	Room 221KN	Sink	22	B	3.3	12/29/16	D	0.16	3/18/17							

Sample ID	Building	Room/Location	Sample Location	Sample No.	Draw	Result (ug/L)	Date	Draw	Result (ug/L)	Date	Draw	Result (ug/L)	Date	Draw	Result (ug/L)	Date	Notes
PbEPA2	Edgewood Park Apartments 200	Room 223KN	Sink	23	A	2.7	12/29/16	C	0.16	3/18/17							
PbEPA2	Edgewood Park Apartments 200	Room 223KN	Sink	23	B	2.6	12/29/16	D	0.16	3/18/17							
PbEPA2	Edgewood Park Apartments 200	Room 224KN	Sink	24	A	2.3	12/29/16	C	0.16	3/18/17							
PbEPA2	Edgewood Park Apartments 200	Room 224KN	Sink	24	B	0.53	12/29/16	D	0.16	3/18/17							
PbEPA2	Edgewood Park Apartments 200	Room 222KN	Sink	25	A	3.6	12/29/16	C	0.16	3/18/17							
PbEPA2	Edgewood Park Apartments 200	Room 222KN	Sink	25	B	1.2	12/29/16	D	0.16	3/18/17							
PbEPA2	Edgewood Park Apartments 200	Room 201BA	Sink	26	A	0.16	3/18/17										
PbEPA2	Edgewood Park Apartments 200	Room 201BA	Sink	26	B	0.16	3/18/17										
PbEPA2	Edgewood Park Apartments 200	Room 203BA	Sink	27	A	0.16	3/18/17										
PbEPA2	Edgewood Park Apartments 200	Room 203BA	Sink	27	B	0.16	3/18/17										
PbEPA2	Edgewood Park Apartments 200	Room 204BA	Sink	28	A	0.16	3/18/17										
PbEPA2	Edgewood Park Apartments 200	Room 204BA	Sink	28	B	0.16	3/18/17										
PbEPA2	Edgewood Park Apartments 200	Room 202BA	Sink	29	A	0.16	3/18/17										
PbEPA2	Edgewood Park Apartments 200	Room 202BA	Sink	29	B	0.16	3/18/17										
PbEPA2	Edgewood Park Apartments 200	Room 205BA	Sink	30	A	0.16	3/18/17										
PbEPA2	Edgewood Park Apartments 200	Room 205BA	Sink	30	B	0.16	3/18/17										
PbEPA2	Edgewood Park Apartments 200	Room 207BA	Sink	31	A	0.16	3/18/17										
PbEPA2	Edgewood Park Apartments 200	Room 207BA	Sink	31	B	0.16	3/18/17										
PbEPA2	Edgewood Park Apartments 200	Room 208BA	Sink	32	A	0.16	3/18/17										
PbEPA2	Edgewood Park Apartments 200	Room 208BA	Sink	32	B	0.16	3/18/17										
PbEPA2	Edgewood Park Apartments 200	Room 206BA	Sink	33	A	0.16	3/18/17										
PbEPA2	Edgewood Park Apartments 200	Room 206BA	Sink	33	B	0.16	3/18/17										
PbEPA2	Edgewood Park Apartments 200	Room 209BA	Sink	34	A	0.16	3/18/17										
PbEPA2	Edgewood Park Apartments 200	Room 209BA	Sink	34	B	0.16	3/18/17										
PbEPA2	Edgewood Park Apartments 200	Room 211BA	Sink	35	A	0.16	3/18/17										
PbEPA2	Edgewood Park Apartments 200	Room 211BA	Sink	35	B	0.16	3/18/17										
PbEPA2	Edgewood Park Apartments 200	Room 212BA	Sink	36	A	0.16	3/18/17										
PbEPA2	Edgewood Park Apartments 200	Room 212BA	Sink	36	B	0.16	3/18/17										
PbEPA2	Edgewood Park Apartments 200	Room 210BA	Sink	37	A	0.16	3/18/17										
PbEPA2	Edgewood Park Apartments 200	Room 210BA	Sink	37	B	0.16	3/18/17										
PbEPA2	Edgewood Park Apartments 200	Room 213BA	Sink	38	A	0.16	3/18/17										
PbEPA2	Edgewood Park Apartments 200	Room 213BA	Sink	38	B	0.16	3/18/17										
PbEPA2	Edgewood Park Apartments 200	Room 215BA	Sink	39	A	0.16	3/18/17										
PbEPA2	Edgewood Park Apartments 200	Room 215BA	Sink	39	B	0.16	3/18/17										
PbEPA2	Edgewood Park Apartments 200	Room 216BA	Sink	40	A	0.16	3/18/17										
PbEPA2	Edgewood Park Apartments 200	Room 216BA	Sink	40	B	0.16	3/18/17										
PbEPA2	Edgewood Park Apartments 200	Room 214BA	Sink	41	A	0.16	3/18/17										
PbEPA2	Edgewood Park Apartments 200	Room 214BA	Sink	41	B	0.16	3/18/17										
PbEPA2	Edgewood Park Apartments 200	Room 217BA	Sink	42	A	0.16	3/18/17										
PbEPA2	Edgewood Park Apartments 200	Room 217BA	Sink	42	B	0.16	3/18/17										
PbEPA2	Edgewood Park Apartments 200	Room 219BA	Sink	43	A	0.16	3/18/17										
PbEPA2	Edgewood Park Apartments 200	Room 219BA	Sink	43	B	0.16	3/18/17										
PbEPA2	Edgewood Park Apartments 200	Room 220BA	Sink	44	A	0.16	3/18/17										
PbEPA2	Edgewood Park Apartments 200	Room 220BA	Sink	44	B	0.16	3/18/17										
PbEPA2	Edgewood Park Apartments 200	Room 218BA	Sink	45	A	0.16	3/18/17										
PbEPA2	Edgewood Park Apartments 200	Room 218BA	Sink	45	B	0.16	3/18/17										
PbEPA2	Edgewood Park Apartments 200	Room 221BA	Sink	46	A	0.16	3/18/17										
PbEPA2	Edgewood Park Apartments 200	Room 221BA	Sink	46	B	0.16	3/18/17										
PbEPA2	Edgewood Park Apartments 200	Room 223BA	Sink	47	A	0.16	3/18/17										
PbEPA2	Edgewood Park Apartments 200	Room 223BA	Sink	47	B	0.16	3/18/17										
PbEPA2	Edgewood Park Apartments 200	Room 224BA	Sink	48	A	0.16	3/18/17										
PbEPA2	Edgewood Park Apartments 200	Room 224BA	Sink	48	B	0.16	3/18/17										
PbEPA2	Edgewood Park Apartments 200	Room 222BA	Sink	49	A	0.16	3/18/17										
PbEPA2	Edgewood Park Apartments 200	Room 222BA	Sink	49	B	0.16	3/18/17										
PbEPA3	Edgewood Park Apartments 300	Room 301KN	Sink	2	A	1.1	12/29/16	C	0.16	3/18/17							
PbEPA3	Edgewood Park Apartments 300	Room 301KN	Sink	2	B	5	12/29/16	D	0.16	3/18/17							

Sample ID	Building	Room/Location	Sample Location	Sample No.	Draw	Result (ug/L)	Date	Draw	Result (ug/L)	Date	Draw	Result (ug/L)	Date	Draw	Result (ug/L)	Date	Notes
PbEPA3	Edgewood Park Apartments 300	Room 303KN	Sink	3	A	1.4	12/29/16	C	0.16	3/18/17							
PbEPA3	Edgewood Park Apartments 300	Room 303KN	Sink	3	B	4.2	12/29/16	D	0.16	3/18/17							
PbEPA3	Edgewood Park Apartments 300	Room 304KN	Sink	4	A	1.5	12/29/16	C	0.16	3/18/17							
PbEPA3	Edgewood Park Apartments 300	Room 304KN	Sink	4	B	0.52	12/29/16	D	0.16	3/18/17							
PbEPA3	Edgewood Park Apartments 300	Room 302KN	Sink	5	A	1.4	12/29/16	C	0.16	3/18/17							
PbEPA3	Edgewood Park Apartments 300	Room 302KN	Sink	5	B	2.2	12/29/16	D	0.16	3/18/17							
PbEPA3	Edgewood Park Apartments 300	Room 305KN	Sink	6	A	61.1	12/29/16	C	0.16	3/18/17							
PbEPA3	Edgewood Park Apartments 300	Room 305KN	Sink	6	B	11.3	12/29/16	D	0.16	3/18/17							
PbEPA3	Edgewood Park Apartments 300	Room 307KN	Sink	7	A	12.5	12/29/16	C	0.16	3/18/17							
PbEPA3	Edgewood Park Apartments 300	Room 307KN	Sink	7	B	6.1	12/29/16	D	0.16	3/18/17							
PbEPA3	Edgewood Park Apartments 300	Room 308KN	Sink	8	A	1.6	12/29/16	C	0.16	3/18/17							
PbEPA3	Edgewood Park Apartments 300	Room 308KN	Sink	8	B	4.8	12/29/16	D	0.16	3/18/17							
PbEPA3	Edgewood Park Apartments 300	Room 306KN	Sink	9	A	2.5	12/29/16	C	0.16	3/18/17							
PbEPA3	Edgewood Park Apartments 300	Room 306KN	Sink	9	B	3.7	12/29/16	D	0.16	3/18/17							
PbEPA3	Edgewood Park Apartments 300	Room 309KN	Sink	10	A	1	12/29/16	C	0.16	3/18/17							
PbEPA3	Edgewood Park Apartments 300	Room 309KN	Sink	10	B	9.8	12/29/16	D	0.16	3/18/17							
PbEPA3	Edgewood Park Apartments 300	Room 311KN	Sink	11	A	5.9	12/29/16	C	0.16	3/18/17							
PbEPA3	Edgewood Park Apartments 300	Room 311KN	Sink	11	B	6.5	12/29/16	D	0.16	3/18/17							
PbEPA3	Edgewood Park Apartments 300	Room 312KN	Sink	12	A	2.5	12/29/16	C	0.16	3/18/17							
PbEPA3	Edgewood Park Apartments 300	Room 312KN	Sink	12	B	1.8	12/29/16	D	0.16	3/18/17							
PbEPA3	Edgewood Park Apartments 300	Room 310KN	Sink	13	A	5.6	12/29/16	C	0.16	3/18/17							
PbEPA3	Edgewood Park Apartments 300	Room 310KN	Sink	13	B	3.3	12/29/16	D	0.16	3/18/17							
PbEPA3	Edgewood Park Apartments 300	Room 313KN	Sink	14	A	2.3	12/29/16	C	0.16	3/18/17							
PbEPA3	Edgewood Park Apartments 300	Room 313KN	Sink	14	B	3.7	12/29/16	D	0.16	3/18/17							
PbEPA3	Edgewood Park Apartments 300	Room 315KN	Sink	15	A	3.8	12/29/16	C	0.16	3/18/17							
PbEPA3	Edgewood Park Apartments 300	Room 315KN	Sink	15	B	6.4	12/29/16	D	0.16	3/18/17							
PbEPA3	Edgewood Park Apartments 300	Room 316KN	Sink	16	A	3	12/29/16	C	0.16	3/18/17							
PbEPA3	Edgewood Park Apartments 300	Room 316KN	Sink	16	B	4.9	12/29/16	D	0.16	3/18/17							
PbEPA3	Edgewood Park Apartments 300	Room 314KN	Sink	17	A	2.1	12/29/16	C	0.16	3/18/17							
PbEPA3	Edgewood Park Apartments 300	Room 314KN	Sink	17	B	17.4	12/29/16	D	0.16	3/18/17							
PbEPA3	Edgewood Park Apartments 300	Room 317KN	Sink	18	A	1.7	12/29/16	C	0.16	3/18/17							
PbEPA3	Edgewood Park Apartments 300	Room 317KN	Sink	18	B	2.5	12/29/16	D	0.16	3/18/17							
PbEPA3	Edgewood Park Apartments 300	Room 319KN	Sink	19	A	2.3	12/29/16	C	0.16	3/18/17							
PbEPA3	Edgewood Park Apartments 300	Room 319KN	Sink	19	B	2.7	12/29/16	D	0.16	3/18/17							
PbEPA3	Edgewood Park Apartments 300	Room 320KN	Sink	20	A	25.8	12/29/16	C	0.16	3/18/17							
PbEPA3	Edgewood Park Apartments 300	Room 320KN	Sink	20	B	10.6	12/29/16	D	0.16	3/18/17							
PbEPA3	Edgewood Park Apartments 300	Room 318KN	Sink	21	A	1.4	12/29/16	C	0.16	3/18/17							
PbEPA3	Edgewood Park Apartments 300	Room 318KN	Sink	21	B	60.7	12/29/16	D	0.16	3/18/17							
PbEPA3	Edgewood Park Apartments 300	Room 321KN	Sink	22	A	1.9	12/29/16	C	0.16	3/18/17							
PbEPA3	Edgewood Park Apartments 300	Room 321KN	Sink	22	B	6.8	12/29/16	D	0.16	3/18/17							
PbEPA3	Edgewood Park Apartments 300	Room 323KN	Sink	23	A	2.4	12/29/16	C	0.16	3/18/17							
PbEPA3	Edgewood Park Apartments 300	Room 323KN	Sink	23	B	10.4	12/29/16	D	0.16	3/18/17							
PbEPA3	Edgewood Park Apartments 300	Room 322KN	Sink	24	A	2.7	12/29/16	C	0.16	3/18/17							
PbEPA3	Edgewood Park Apartments 300	Room 322KN	Sink	24	B	0.35	12/29/16	D	0.16	3/18/17							
PbEPA3	Edgewood Park Apartments 300	Room 324KN	Sink	25	A	1.8	12/29/16	C	0.16	3/18/17							
PbEPA3	Edgewood Park Apartments 300	Room 324KN	Sink	25	B	2.3	12/29/16	D	0.16	3/18/17							
PbEPA3	Edgewood Park Apartments 300	Room 301BA	Sink	26	A	0.16	3/18/17										
PbEPA3	Edgewood Park Apartments 300	Room 301BA	Sink	26	B	0.16	3/18/17										
PbEPA3	Edgewood Park Apartments 300	Room 303BA	Sink	27	A	0.16	3/18/17										
PbEPA3	Edgewood Park Apartments 300	Room 303BA	Sink	27	B	0.16	3/18/17										
PbEPA3	Edgewood Park Apartments 300	Room 304BA	Sink	28	A	0.16	3/18/17										
PbEPA3	Edgewood Park Apartments 300	Room 304BA	Sink	28	B	0.16	3/18/17										
PbEPA3	Edgewood Park Apartments 300	Room 302BA	Sink	29	A	0.16	3/18/17										
PbEPA3	Edgewood Park Apartments 300	Room 302BA	Sink	29	B	0.16	3/18/17										
PbEPA3	Edgewood Park Apartments 300	Room 305BA	Sink	30	A	0.16	3/18/17										
PbEPA3	Edgewood Park Apartments 300	Room 305BA	Sink	30	B	0.16	3/18/17										
PbEPA3	Edgewood Park Apartments 300	Room 307BA	Sink	31	A	0.16	3/18/17										

Sample ID	Building	Room/Location	Sample Location	Sample No.	Draw	Result (ug/L)	Date	Draw	Result (ug/L)	Date	Draw	Result (ug/L)	Date	Draw	Result (ug/L)	Date	Notes
PbEPA3	Edgewood Park Apartments 300	Room 307BA	Sink	31	B	0.16	3/18/17										
PbEPA3	Edgewood Park Apartments 300	Room 308BA	Sink	32	A	0.16	3/18/17										
PbEPA3	Edgewood Park Apartments 300	Room 308BA	Sink	32	B	0.16	3/18/17										
PbEPA3	Edgewood Park Apartments 300	Room 306BA	Sink	33	A	0.16	3/18/17										
PbEPA3	Edgewood Park Apartments 300	Room 306BA	Sink	33	B	0.16	3/18/17										
PbEPA3	Edgewood Park Apartments 300	Room 309BA	Sink	34	A	0.16	3/18/17										
PbEPA3	Edgewood Park Apartments 300	Room 309BA	Sink	34	B	0.16	3/18/17										
PbEPA3	Edgewood Park Apartments 300	Room 311BA	Sink	35	A	0.16	3/18/17										
PbEPA3	Edgewood Park Apartments 300	Room 311BA	Sink	35	B	0.16	3/18/17										
PbEPA3	Edgewood Park Apartments 300	Room 312BA	Sink	36	A	0.16	3/18/17										
PbEPA3	Edgewood Park Apartments 300	Room 312BA	Sink	36	B	0.16	3/18/17										
PbEPA3	Edgewood Park Apartments 300	Room 310BA	Sink	37	A	0.16	3/18/17										
PbEPA3	Edgewood Park Apartments 300	Room 310BA	Sink	37	B	0.16	3/18/17										
PbEPA3	Edgewood Park Apartments 300	Room 313BA	Sink	38	A	0.16	3/18/17										
PbEPA3	Edgewood Park Apartments 300	Room 313BA	Sink	38	B	0.16	3/18/17										
PbEPA3	Edgewood Park Apartments 300	Room 315BA	Sink	39	A	0.16	3/18/17										
PbEPA3	Edgewood Park Apartments 300	Room 315BA	Sink	39	B	0.16	3/18/17										
PbEPA3	Edgewood Park Apartments 300	Room 316BA	Sink	40	A	0.16	3/18/17										
PbEPA3	Edgewood Park Apartments 300	Room 316BA	Sink	40	B	0.16	3/18/17										
PbEPA3	Edgewood Park Apartments 300	Room 314BA	Sink	41	A	0.16	3/18/17										
PbEPA3	Edgewood Park Apartments 300	Room 314BA	Sink	41	B	0.16	3/18/17										
PbEPA3	Edgewood Park Apartments 300	Room 317BA	Sink	42	A	0.16	3/18/17										
PbEPA3	Edgewood Park Apartments 300	Room 317BA	Sink	42	B	0.16	3/18/17										
PbEPA3	Edgewood Park Apartments 300	Room 319BA	Sink	43	A	0.16	3/18/17										
PbEPA3	Edgewood Park Apartments 300	Room 319BA	Sink	43	B	0.16	3/18/17										
PbEPA3	Edgewood Park Apartments 300	Room 320BA	Sink	44	A	0.16	3/18/17										
PbEPA3	Edgewood Park Apartments 300	Room 320BA	Sink	44	B	0.16	3/18/17										
PbEPA3	Edgewood Park Apartments 300	Room 318BA	Sink	45	A	0.16	3/18/17										
PbEPA3	Edgewood Park Apartments 300	Room 318BA	Sink	45	B	0.16	3/18/17										
PbEPA3	Edgewood Park Apartments 300	Room 321BA	Sink	46	A	0.16	3/18/17										
PbEPA3	Edgewood Park Apartments 300	Room 321BA	Sink	46	B	0.16	3/18/17										
PbEPA3	Edgewood Park Apartments 300	Room 323BA	Sink	47	A	0.16	3/18/17										
PbEPA3	Edgewood Park Apartments 300	Room 323BA	Sink	47	B	0.16	3/18/17										
PbEPA3	Edgewood Park Apartments 300	Room 322BA	Sink	48	A	0.16	3/18/17										
PbEPA3	Edgewood Park Apartments 300	Room 322BA	Sink	48	B	0.16	3/18/17										
PbEPA3	Edgewood Park Apartments 300	Room 324BA	Sink	49	A	0.16	3/18/17										
PbEPA3	Edgewood Park Apartments 300	Room 324BA	Sink	49	B	0.16	3/18/17										
PbEPA4	Edgewater Park Apartments 400	Room 414	Water Main - nearest sink to main	1	A	0.92	12/29/16										
PbEPA4	Edgewater Park Apartments 400	Room 414	Water Main - nearest sink to main	1	B	26.9	12/29/16										Although water tested at backflow preventer (where water first enters the building) shows a high concentation of lead, faucets throughout the buildings fall below the 15ppb threshold.
PbEPA4	Edgewood Park Apartments 400	Room 401KN	Sink	2	A	1.2	12/29/16	C	0.16	3/18/17							
PbEPA4	Edgewood Park Apartments 400	Room 401KN	Sink	2	B	0.16	12/29/16	D	0.16	3/18/17							
PbEPA4	Edgewood Park Apartments 400	Room 403KN	Sink	3	A	0.59	12/29/16	C	0.16	3/18/17							
PbEPA4	Edgewood Park Apartments 400	Room 403KN	Sink	3	B	0.16	12/29/16	D	0.16	3/18/17							
PbEPA4	Edgewood Park Apartments 400	Room 404KN	Sink	4	A	2.2	12/29/16	C	0.16	3/18/17							
PbEPA4	Edgewood Park Apartments 400	Room 404KN	Sink	4	B	0.6	12/29/16	D	0.16	3/18/17							
PbEPA4	Edgewood Park Apartments 400	Room 402KN	Sink	5	A	2	12/29/16	C	0.16	3/18/17							
PbEPA4	Edgewood Park Apartments 400	Room 402KN	Sink	5	B	3.5	12/29/16	D	0.16	3/18/17							
PbEPA4	Edgewood Park Apartments 400	Room 407KN	Sink	6	A	0.37	12/29/16	C	0.16	3/18/17							
PbEPA4	Edgewood Park Apartments 400	Room 407KN	Sink	6	B	0.16	12/29/16	D	0.16	3/18/17							
PbEPA4	Edgewood Park Apartments 400	Room 405KN	Sink	7	A	0.99	12/29/16	C	0.16	3/18/17							
PbEPA4	Edgewood Park Apartments 400	Room 405KN	Sink	7	B	0.16	12/29/16	D	0.16	3/18/17							
PbEPA4	Edgewood Park Apartments 400	Room 408KN	Sink	8	A	1.2	12/29/16	C	0.16	3/18/17							
PbEPA4	Edgewood Park Apartments 400	Room 408KN	Sink	8	B	1	12/29/16	D	0.16	3/18/17							
PbEPA4	Edgewood Park Apartments 400	Room 406KN	Sink	9	A	1.6	12/29/16	C	0.16	3/18/17							

Sample ID	Building	Room/Location	Sample Location	Sample No.	Draw	Result (ug/L)	Date	Draw	Result (ug/L)	Date	Draw	Result (ug/L)	Date	Draw	Result (ug/L)	Date	Notes
PbEPA4	Edgewood Park Apartments 400	Room 406KN	Sink	9	B	1.2	12/29/16	D	0.16	3/18/17							
PbEPA4	Edgewood Park Apartments 400	Room 411KN	Sink	10	A	1.2	12/29/16	C	0.16	3/18/17							
PbEPA4	Edgewood Park Apartments 400	Room 411KN	Sink	10	B	0.29	12/29/16	D	0.16	3/18/17							
PbEPA4	Edgewood Park Apartments 400	Room 409KN	Sink	11	A	2.1	12/29/16	C	0.16	3/18/17							
PbEPA4	Edgewood Park Apartments 400	Room 409KN	Sink	11	B	0.22	12/29/16	D	0.16	3/18/17							
PbEPA4	Edgewood Park Apartments 400	Room 412KN	Sink	12	A	1.9	12/29/16	C	0.16	3/18/17							
PbEPA4	Edgewood Park Apartments 400	Room 412KN	Sink	12	B	0.2	12/29/16	D	0.16	3/18/17							
PbEPA4	Edgewood Park Apartments 400	Room 410KN	Sink	13	A	11.9	12/29/16	C	0.16	3/18/17							
PbEPA4	Edgewood Park Apartments 400	Room 410KN	Sink	13	B	1.8	12/29/16	D	0.16	3/18/17							
PbEPA4	Edgewood Park Apartments 400	Room 413KN	Sink	14	A	1.3	12/29/16	C	0.16	3/18/17							
PbEPA4	Edgewood Park Apartments 400	Room 413KN	Sink	14	B	2.7	12/29/16	D	0.16	3/18/17							
PbEPA4	Edgewood Park Apartments 400	Room 415KN	Sink	15	A	0.94	12/29/16	C	0.16	3/18/17							
PbEPA4	Edgewood Park Apartments 400	Room 415KN	Sink	15	B	0.68	12/29/16	D	0.16	3/18/17							
PbEPA4	Edgewood Park Apartments 400	Room 416KN	Sink	16	A	4	12/29/16	C	0.16	3/18/17							
PbEPA4	Edgewood Park Apartments 400	Room 416KN	Sink	16	B	2.4	12/29/16	D	0.16	3/18/17							
PbEPA4	Edgewood Park Apartments 400	Room 414KN	Sink	17	A	0.77	12/29/16	C	0.16	3/18/17	E	1.9	7/28/17				
PbEPA4	Edgewood Park Apartments 400	Room 414KN	Sink	17	B	33.9	12/29/16	D	0.16	3/18/17	F	0.16	7/28/17				
PbEPA4	Edgewood Park Apartments 400	Room 417KN	Sink	18	A	2.1	12/29/16	C	0.16	3/18/17							
PbEPA4	Edgewood Park Apartments 400	Room 417KN	Sink	18	B	5.3	12/29/16	D	0.16	3/18/17							
PbEPA4	Edgewood Park Apartments 400	Room 419KN	Sink	19	A	2	12/29/16	C	0.16	3/18/17							
PbEPA4	Edgewood Park Apartments 400	Room 419KN	Sink	19	B	3.5	12/29/16	D	0.16	3/18/17							
PbEPA4	Edgewood Park Apartments 400	Room 420KN	Sink	20	A	1.5	12/29/16	C	0.16	3/18/17							
PbEPA4	Edgewood Park Apartments 400	Room 420KN	Sink	20	B	0.61	12/29/16	D	0.16	3/18/17							
PbEPA4	Edgewood Park Apartments 400	Room 418KN	Sink	21	A	1.2	12/29/16	C	0.16	3/18/17							
PbEPA4	Edgewood Park Apartments 400	Room 418KN	Sink	21	B	0.25	12/29/16	D	0.16	3/18/17							
PbEPA4	Edgewood Park Apartments 400	Room 421KN	Sink	22	A	1.1	12/29/16	C	0.16	3/18/17							
PbEPA4	Edgewood Park Apartments 400	Room 421KN	Sink	22	B	5.1	12/29/16	D	0.16	3/18/17							
PbEPA4	Edgewood Park Apartments 400	Room 423KN	Sink	23	A	1.4	12/29/16	C	0.16	3/18/17							
PbEPA4	Edgewood Park Apartments 400	Room 423KN	Sink	23	B	3.3	12/29/16	D	0.16	3/18/17							
PbEPA4	Edgewood Park Apartments 400	Room 424KN	Sink	24	A	4.6	12/29/16	C	0.16	3/18/17							
PbEPA4	Edgewood Park Apartments 400	Room 424KN	Sink	24	B	0.6	12/29/16	D	0.16	3/18/17							
PbEPA4	Edgewood Park Apartments 400	Room 425KN	Sink	25	A	4.1	12/29/16	C	0.16	3/18/17							
PbEPA4	Edgewood Park Apartments 400	Room 425KN	Sink	25	B	0.62	12/29/16	D	0.16	3/18/17							
PbEPA4	Edgewood Park Apartments 400	Room 401BA	Sink	26	A	0.16	3/18/17										
PbEPA4	Edgewood Park Apartments 400	Room 401BA	Sink	26	B	0.16	3/18/17										
PbEPA4	Edgewood Park Apartments 400	Room 403BA	Sink	27	A	0.16	3/18/17										
PbEPA4	Edgewood Park Apartments 400	Room 403BA	Sink	27	B	0.16	3/18/17										
PbEPA4	Edgewood Park Apartments 400	Room 404BA	Sink	28	A	0.16	3/18/17										
PbEPA4	Edgewood Park Apartments 400	Room 404BA	Sink	28	B	0.16	3/18/17										
PbEPA4	Edgewood Park Apartments 400	Room 402BA	Sink	29	A	0.16	3/18/17										
PbEPA4	Edgewood Park Apartments 400	Room 402BA	Sink	29	B	0.16	3/18/17										
PbEPA4	Edgewood Park Apartments 400	Room 407BA	Sink	30	A	0.16	3/18/17										
PbEPA4	Edgewood Park Apartments 400	Room 407BA	Sink	30	B	0.16	3/18/17										
PbEPA4	Edgewood Park Apartments 400	Room 405BA	Sink	31	A	0.16	3/18/17										
PbEPA4	Edgewood Park Apartments 400	Room 405BA	Sink	31	B	0.16	3/18/17										
PbEPA4	Edgewood Park Apartments 400	Room 408BA	Sink	32	A	0.16	3/18/17										
PbEPA4	Edgewood Park Apartments 400	Room 408BA	Sink	32	B	0.16	3/18/17										
PbEPA4	Edgewood Park Apartments 400	Room 406BA	Sink	33	A	0.16	3/18/17										
PbEPA4	Edgewood Park Apartments 400	Room 406BA	Sink	33	B	0.16	3/18/17										
PbEPA4	Edgewood Park Apartments 400	Room 411BA	Sink	34	A	0.16	3/18/17										
PbEPA4	Edgewood Park Apartments 400	Room 411BA	Sink	34	B	0.16	3/18/17										
PbEPA4	Edgewood Park Apartments 400	Room 409BA	Sink	35	A	0.16	3/18/17										
PbEPA4	Edgewood Park Apartments 400	Room 409BA	Sink	35	B	0.16	3/18/17										
PbEPA4	Edgewood Park Apartments 400	Room 412BA	Sink	36	A	0.16	3/18/17										
PbEPA4	Edgewood Park Apartments 400	Room 412BA	Sink	36	B	0.16	3/18/17										
PbEPA4	Edgewood Park Apartments 400	Room 410BA	Sink	37	A	0.16	3/18/17										
PbEPA4	Edgewood Park Apartments 400	Room 410BA	Sink	37	B	0.16	3/18/17										

Sample ID	Building	Room/Location	Sample Location	Sample No.	Draw	Result (ug/L)	Date	Draw	Result (ug/L)	Date	Draw	Result (ug/L)	Date	Draw	Result (ug/L)	Date	Notes
PbEPA4	Edgewood Park Apartments 400	Room 413BA	Sink	38	A	0.16	3/18/17										
PbEPA4	Edgewood Park Apartments 400	Room 413BA	Sink	38	B	0.16	3/18/17										
PbEPA4	Edgewood Park Apartments 400	Room 415BA	Sink	39	A	0.16	3/18/17										
PbEPA4	Edgewood Park Apartments 400	Room 415BA	Sink	39	B	0.16	3/18/17										
PbEPA4	Edgewood Park Apartments 400	Room 416BA	Sink	40	A	0.16	3/18/17										
PbEPA4	Edgewood Park Apartments 400	Room 416BA	Sink	40	B	0.16	3/18/17										
PbEPA4	Edgewood Park Apartments 400	Room 414BA	Sink	41	A	0.16	3/18/17										
PbEPA4	Edgewood Park Apartments 400	Room 414BA	Sink	41	B	0.16	3/18/17										
PbEPA4	Edgewood Park Apartments 400	Room 417BA	Sink	42	A	0.16	3/18/17										
PbEPA4	Edgewood Park Apartments 400	Room 417BA	Sink	42	B	0.16	3/18/17										
PbEPA4	Edgewood Park Apartments 400	Room 419BA	Sink	43	A	0.16	3/18/17										
PbEPA4	Edgewood Park Apartments 400	Room 419BA	Sink	43	B	0.16	3/18/17										
PbEPA4	Edgewood Park Apartments 400	Room 420BA	Sink	44	A	0.16	3/18/17										
PbEPA4	Edgewood Park Apartments 400	Room 420BA	Sink	44	B	0.16	3/18/17										
PbEPA4	Edgewood Park Apartments 400	Room 418BA	Sink	45	A	0.16	3/18/17										
PbEPA4	Edgewood Park Apartments 400	Room 418BA	Sink	45	B	0.16	3/18/17										
PbEPA4	Edgewood Park Apartments 400	Room 421BA	Sink	46	A	0.16	3/18/17										
PbEPA4	Edgewood Park Apartments 400	Room 421BA	Sink	46	B	0.16	3/18/17										
PbEPA4	Edgewood Park Apartments 400	Room 423BA	Sink	47	A	0.16	3/18/17										
PbEPA4	Edgewood Park Apartments 400	Room 423BA	Sink	47	B	0.16	3/18/17										
PbEPA4	Edgewood Park Apartments 400	Room 424BA	Sink	48	A	0.16	3/18/17										
PbEPA4	Edgewood Park Apartments 400	Room 424BA	Sink	48	B	0.16	3/18/17										
PbEPA4	Edgewood Park Apartments 400	Room 425BA	Sink	49	A	0.16	3/18/17										
PbEPA4	Edgewood Park Apartments 400	Room 425BA	Sink	49	B	0.16	3/18/17										
PbEPA5	Edgewater Park Apartments 500	Room 514	Water Main - nearest sink to main	1	A	72	12/29/16										Although water tested at backflow preventer (where water first enters the building) shows a high concentation of lead, faucets throughout the buildings fall below the 15ppb threshold.
PbEPA5	Edgewater Park Apartments 500	Room 514	Water Main - nearest sink to main	1	B	14.4	12/29/16										
PbEPA5	Edgewood Park Apartments 500	Room 501KN	Sink	2	A	2.1	12/29/16	C	0.16	3/18/17							
PbEPA5	Edgewood Park Apartments 500	Room 501KN	Sink	2	B	2	12/29/16	D	0.16	3/18/17							
PbEPA5	Edgewood Park Apartments 500	Room 503KN	Sink	3	A	1.3	12/29/16	C	0.16	3/18/17							
PbEPA5	Edgewood Park Apartments 500	Room 503KN	Sink	3	B	2.7	12/29/16	D	0.16	3/18/17							
PbEPA5	Edgewood Park Apartments 500	Room 504KN	Sink	4	A	0.67	12/29/16	C	0.16	3/18/17							
PbEPA5	Edgewood Park Apartments 500	Room 504KN	Sink	4	B	3.2	12/29/16	D	0.16	3/18/17							
PbEPA5	Edgewood Park Apartments 500	Room 502KN	Sink	5	A	2.1	12/29/16	C	0.16	3/18/17							
PbEPA5	Edgewood Park Apartments 500	Room 502KN	Sink	5	B	1.8	12/29/16	D	0.16	3/18/17							
PbEPA5	Edgewood Park Apartments 500	Room 507KN	Sink	6	A	5.6	12/29/16	C	0.16	3/18/17							
PbEPA5	Edgewood Park Apartments 500	Room 507KN	Sink	6	B	2.3	12/29/16	D	0.16	3/18/17							
PbEPA5	Edgewood Park Apartments 500	Room 505KN	Sink	7	A	4.8	12/29/16	C	0.16	3/18/17							
PbEPA5	Edgewood Park Apartments 500	Room 505KN	Sink	7	B	5.3	12/29/16	D	0.16	3/18/17							
PbEPA5	Edgewood Park Apartments 500	Room 508KN	Sink	8	A	2.9	12/29/16	C	0.16	3/18/17							
PbEPA5	Edgewood Park Apartments 500	Room 508KN	Sink	8	B	10.2	12/29/16	D	0.16	3/18/17							
PbEPA5	Edgewood Park Apartments 500	Room 506KN	Sink	9	A	5.7	12/29/16	C	0.16	3/18/17							
PbEPA5	Edgewood Park Apartments 500	Room 506KN	Sink	9	B	5.2	12/29/16	D	0.16	3/18/17							
PbEPA5	Edgewood Park Apartments 500	Room 511KN	Sink	10	A	2	12/29/16	C	0.16	3/18/17							
PbEPA5	Edgewood Park Apartments 500	Room 511KN	Sink	10	B	5	12/29/16	D	0.16	3/18/17							
PbEPA5	Edgewood Park Apartments 500	Room 509KN	Sink	11	A	2.7	12/29/16	C	0.16	3/18/17							
PbEPA5	Edgewood Park Apartments 500	Room 509KN	Sink	11	B	7.1	12/29/16	D	0.16	3/18/17							
PbEPA5	Edgewood Park Apartments 500	Room 512KN	Sink	12	A	6.6	12/29/16	C	0.16	3/18/17	E	0.77	7/28/17				
PbEPA5	Edgewood Park Apartments 500	Room 512KN	Sink	12	B	44.8	12/29/16	D	0.16	3/18/17	F	0.16	7/28/17				
PbEPA5	Edgewood Park Apartments 500	Room 510KN	Sink	13	A	6.9	12/29/16	C	0.16	3/18/17							
PbEPA5	Edgewood Park Apartments 500	Room 510KN	Sink	13	B	5.8	12/29/16	D	0.16	3/18/17							
PbEPA5	Edgewood Park Apartments 500	Room 513KN	Sink	14	A	1.2	12/29/16	C	0.16	3/18/17							
PbEPA5	Edgewood Park Apartments 500	Room 513KN	Sink	14	B	5.6	12/29/16	D	0.16	3/18/17							
PbEPA5	Edgewood Park Apartments 500	Room 515KN	Sink	15	A	1.2	12/29/16	C	0.16	3/18/17							
PbEPA5	Edgewood Park Apartments 500	Room 515KN	Sink	15	B	8.4	12/29/16	D	0.16	3/18/17							

Sample ID	Building	Room/Location	Sample Location	Sample No.	Draw	Result (ug/L)	Date	Draw	Result (ug/L)	Date	Draw	Result (ug/L)	Date	Draw	Result (ug/L)	Date	Notes
PbEPA5	Edgewood Park Apartments 500	Room 516KN	Sink	16	A	2.8	12/29/16	C	0.16	3/18/17	E	1.9	7/28/17				
PbEPA5	Edgewood Park Apartments 500	Room 516KN	Sink	16	B	19.1	12/29/16	D	0.16	3/18/17	F	0.16	7/28/17				
PbEPA5	Edgewood Park Apartments 500	Room 514KN	Sink	17	A	1.4	12/29/16	C	0.16	3/18/17							
PbEPA5	Edgewood Park Apartments 500	Room 514KN	Sink	17	B	12.6	12/29/16	D	0.16	3/18/17							
PbEPA5	Edgewood Park Apartments 500	Room 517KN	Sink	18	A	2.8	12/29/16	C	0.16	3/18/17							
PbEPA5	Edgewood Park Apartments 500	Room 517KN	Sink	18	B	0.59	12/29/16	D	0.16	3/18/17							
PbEPA5	Edgewood Park Apartments 500	Room 519KN	Sink	19	A	2.1	12/29/16	C	0.16	3/18/17							
PbEPA5	Edgewood Park Apartments 500	Room 519KN	Sink	19	B	0.46	12/29/16	D	0.16	3/18/17							
PbEPA5	Edgewood Park Apartments 500	Room 520KN	Sink	20	A	1	12/29/16	C	0.16	3/18/17							
PbEPA5	Edgewood Park Apartments 500	Room 520KN	Sink	20	B	0.22	12/29/16	D	0.16	3/18/17							
PbEPA5	Edgewood Park Apartments 500	Room 518KN	Sink	21	A	3.5	12/29/16	C	0.16	3/18/17	E	12.1	7/28/17				
PbEPA5	Edgewood Park Apartments 500	Room 518KN	Sink	21	B	24.4	12/29/16	D	0.16	3/18/17	F	0.16	7/28/17				
PbEPA5	Edgewood Park Apartments 500	Room 521KN	Sink	22	A	4.3	12/29/16	C	0.16	3/18/17							
PbEPA5	Edgewood Park Apartments 500	Room 521KN	Sink	22	B	0.64	12/29/16	D	0.16	3/18/17							
PbEPA5	Edgewood Park Apartments 500	Room 523KN	Sink	23	A	1.5	12/29/16	C	0.16	3/18/17							
PbEPA5	Edgewood Park Apartments 500	Room 523KN	Sink	23	B	0.53	12/29/16	D	0.16	3/18/17							
PbEPA5	Edgewood Park Apartments 500	Room 524KN	Sink	24	A	1.1	12/29/16	C	0.16	3/18/17							
PbEPA5	Edgewood Park Apartments 500	Room 524KN	Sink	24	B	16.9	12/29/16	D	0.16	3/18/17							
PbEPA5	Edgewood Park Apartments 500	Room 522KN	Sink	25	A	0.68	12/29/16	C	0.16	3/18/17							
PbEPA5	Edgewood Park Apartments 500	Room 522KN	Sink	25	B	26.5	12/29/16	D	0.16	3/18/17							
PbEPA5	Edgewood Park Apartments 500	Room 501BA	Sink	26	A	0.16	3/18/17										
PbEPA5	Edgewood Park Apartments 500	Room 501BA	Sink	26	B	0.16	3/18/17										
PbEPA5	Edgewood Park Apartments 500	Room 503BA	Sink	27	A	0.16	3/18/17										
PbEPA5	Edgewood Park Apartments 500	Room 503BA	Sink	27	B	0.16	3/18/17										
PbEPA5	Edgewood Park Apartments 500	Room 504BA	Sink	28	A	0.16	3/18/17										
PbEPA5	Edgewood Park Apartments 500	Room 504BA	Sink	28	B	0.16	3/18/17										
PbEPA5	Edgewood Park Apartments 500	Room 502BA	Sink	29	A	0.16	3/18/17										
PbEPA5	Edgewood Park Apartments 500	Room 502BA	Sink	29	B	0.16	3/18/17										
PbEPA5	Edgewood Park Apartments 500	Room 507BA	Sink	30	A	0.16	3/18/17										
PbEPA5	Edgewood Park Apartments 500	Room 507BA	Sink	30	B	0.16	3/18/17										
PbEPA5	Edgewood Park Apartments 500	Room 505BA	Sink	31	A	0.16	3/18/17										
PbEPA5	Edgewood Park Apartments 500	Room 505BA	Sink	31	B	0.16	3/18/17										
PbEPA5	Edgewood Park Apartments 500	Room 508BA	Sink	32	A	0.16	3/18/17										
PbEPA5	Edgewood Park Apartments 500	Room 508BA	Sink	32	B	0.16	3/18/17										
PbEPA5	Edgewood Park Apartments 500	Room 506BA	Sink	33	A	0.16	3/18/17										
PbEPA5	Edgewood Park Apartments 500	Room 506BA	Sink	33	B	0.16	3/18/17										
PbEPA5	Edgewood Park Apartments 500	Room 511BA	Sink	34	A	0.16	3/18/17										
PbEPA5	Edgewood Park Apartments 500	Room 511BA	Sink	34	B	0.16	3/18/17										
PbEPA5	Edgewood Park Apartments 500	Room 509BA	Sink	35	A	0.16	3/18/17										
PbEPA5	Edgewood Park Apartments 500	Room 509BA	Sink	35	B	0.16	3/18/17										
PbEPA5	Edgewood Park Apartments 500	Room 512BA	Sink	36	A	0.16	3/18/17										
PbEPA5	Edgewood Park Apartments 500	Room 512BA	Sink	36	B	0.16	3/18/17										
PbEPA5	Edgewood Park Apartments 500	Room 510BA	Sink	37	A	0.16	3/18/17										
PbEPA5	Edgewood Park Apartments 500	Room 510BA	Sink	37	B	0.16	3/18/17										
PbEPA5	Edgewood Park Apartments 500	Room 513BA	Sink	38	A	0.16	3/18/17										
PbEPA5	Edgewood Park Apartments 500	Room 513BA	Sink	38	B	0.16	3/18/17										
PbEPA5	Edgewood Park Apartments 500	Room 515BA	Sink	39	A	0.16	3/18/17										
PbEPA5	Edgewood Park Apartments 500	Room 515BA	Sink	39	B	0.16	3/18/17										
PbEPA5	Edgewood Park Apartments 500	Room 516BA	Sink	40	A	0.16	3/18/17										
PbEPA5	Edgewood Park Apartments 500	Room 516BA	Sink	40	B	0.16	3/18/17										
PbEPA5	Edgewood Park Apartments 500	Room 514BA	Sink	41	A	0.16	3/18/17										
PbEPA5	Edgewood Park Apartments 500	Room 514BA	Sink	41	B	0.16	3/18/17										
PbEPA5	Edgewood Park Apartments 500	Room 517BA	Sink	42	A	0.16	3/18/17										
PbEPA5	Edgewood Park Apartments 500	Room 517BA	Sink	42	B	0.16	3/18/17										
PbEPA5	Edgewood Park Apartments 500	Room 519BA	Sink	43	A	0.16	3/18/17										
PbEPA5	Edgewood Park Apartments 500	Room 519BA	Sink	43	B	0.16	3/18/17										
PbEPA5	Edgewood Park Apartments 500	Room 520BA	Sink	44	A	0.16	3/18/17										

Sample ID	Building	Room/Location	Sample Location	Sample No.	Draw	Result (ug/L)	Date	Draw	Result (ug/L)	Date	Draw	Result (ug/L)	Date	Draw	Result (ug/L)	Date	Notes
PbEPA5	Edgewood Park Apartments 500	Room 520BA	Sink	44	B	0.16	3/18/17										
PbEPA5	Edgewood Park Apartments 500	Room 518BA	Sink	45	A	0.16	3/18/17										
PbEPA5	Edgewood Park Apartments 500	Room 518BA	Sink	45	B	0.16	3/18/17										
PbEPA5	Edgewood Park Apartments 500	Room 521BA	Sink	46	A	0.16	3/18/17										
PbEPA5	Edgewood Park Apartments 500	Room 521BA	Sink	46	B	0.16	3/18/17										
PbEPA5	Edgewood Park Apartments 500	Room 523BA	Sink	47	A	0.16	3/18/17										
PbEPA5	Edgewood Park Apartments 500	Room 523BA	Sink	47	B	0.16	3/18/17										
PbEPA5	Edgewood Park Apartments 500	Room 524BA	Sink	48	A	0.16	3/18/17										
PbEPA5	Edgewood Park Apartments 500	Room 524BA	Sink	48	B	0.16	3/18/17										
PbEPA5	Edgewood Park Apartments 500	Room 522BA	Sink	49	A	0.16	3/18/17										
PbEPA5	Edgewood Park Apartments 500	Room 522BA	Sink	49	B	0.16	3/18/17										
PbESB	Esbjornson Gym	Room 007B	Ice Machine	1	A	6.5	12/23/16										
PbESB	Esbjornson Gym	Room 007B	Ice Machine	1	B	2.5	12/23/16										
PbESB	Esbjornson Gym	Room H001	Water Fountain	2	A	1.1	12/23/16										
PbESB	Esbjornson Gym	Room H001	Water Fountain	2	B	0.18	12/23/16										
PbESB	Esbjornson Gym	Room H002	Water Fountain	3	A	0.16	12/23/16										
PbESB	Esbjornson Gym	Room H002	Water Fountain	3	B	0.16	12/23/16										
PbESB	Esbjornson Gym	Room 105	Sink	4	A	1.8	12/23/16										
PbESB	Esbjornson Gym	Room 105	Sink	4	B	0.83	12/23/16										
PbESB	Esbjornson Gym	Room H102	Water Fountain	5	A	0.16	12/23/16										
PbESB	Esbjornson Gym	Room H102	Water Fountain	5	B	0.16	12/23/16										
PbESB	Esbjornson Gym	Room 103	Sink	6	A	6.9	12/23/16										
PbESB	Esbjornson Gym	Room 103	Sink	6	B	2.1	12/23/16										
PbESB	Esbjornson Gym	Room 115A	Water Fountain	7	A	58.9	12/23/16										Sample above action level. Fountain taken offline
PbESB	Esbjornson Gym	Room 115A	Water Fountain	7	B	0.58	12/23/16										
PbEVE	Evergreen	Room 002MR	Backflow Preventer	1	A	4440	1/4/17										Although water tested at backflow preventer (where water first enters the building) shows a high concentation of lead, faucets throughout the buildings fall below the 15ppb threshold.
PbEVE	Evergreen	Room 002MR	Backflow Preventer	1	B	28.5	1/4/17										Although water tested at backflow preventer (where water first enters the building) shows a high concentation of lead, faucets throughout the buildings fall below the 15ppb threshold.
PbEVE	Evergreen	Room 121/123	Sink	2	A	27.1	1/4/17	C	0.16	3/15/17	E	2.2	7/28/17				
PbEVE	Evergreen	Room 121/123	Sink	2	B	4.2	1/4/17	D	0.16	3/15/17	F	0.29	7/28/17				
PbEVE	Evergreen	Room 124/126	Sink	3	A	11.5	1/4/17	C	0.16	3/15/17							
PbEVE	Evergreen	Room 124/126	Sink	3	B	4.4	1/4/17	D	0.16	3/15/17							
PbEVE	Evergreen	Room 127/129	Sink	4	A	6.2	1/4/17	C	0.16	3/15/17							
PbEVE	Evergreen	Room 127/129	Sink	4	B	2.5	1/4/17	D	0.16	3/15/17							
PbEVE	Evergreen	Room 131/133	Sink	5	A	7.5	1/4/17	C	0.16	3/15/17							
PbEVE	Evergreen	Room 131/133	Sink	5	B	2.6	1/4/17	D	0.16	3/15/17							
PbEVE	Evergreen	Room 134/136	Sink	6	A	2.4	1/4/17	C	0.16	3/15/17							
PbEVE	Evergreen	Room 134/136	Sink	6	B	5.4	1/4/17	D	0.16	3/15/17							
PbEVE	Evergreen	Room 102/104	Sink	7	A	4.2	1/4/17	C	0.16	3/15/17							
PbEVE	Evergreen	Room 102/104	Sink	7	B	2.4	1/4/17	D	0.16	3/15/17							
PbEVE	Evergreen	Room 106K	Sink	8	A	10	1/4/17										
PbEVE	Evergreen	Room 106K	Sink	8	B	2.4	1/4/17										
PbEVE	Evergreen	Room 106B	Sink	9	A	20.1	1/4/17	C	0.16	3/15/17	E	2	7/28/17				
PbEVE	Evergreen	Room 106B	Sink	9	B	3	1/4/17	D	0.16	3/15/17	F	0.33	7/28/17				
PbEVE	Evergreen	Room 109/111	Sink	10	A	3.4	1/4/17	C	0.16	3/15/17							
PbEVE	Evergreen	Room 109/111	Sink	10	B	2.9	1/4/17	D	0.16	3/15/17							
PbEVE	Evergreen	Room 114/116	Sink	11	A	4.4	1/4/17	C	0.16	3/15/17							
PbEVE	Evergreen	Room 114/116	Sink	11	B	3.1	1/4/17	D	0.16	3/15/17							
PbEVE	Evergreen	Room 119-KIT	Sink	12	A	6.3	1/4/17										
PbEVE	Evergreen	Room 119-KIT	Sink	12	B	5.2	1/4/17										
PbEVE	Evergreen	Room 119-BR	Sink	13	A	4.8	1/4/17	C	0.16	3/15/17							
PbEVE	Evergreen	Room 119-BR	Sink	13	B	7.2	1/4/17	D	0.16	3/15/17							

Sample ID	Building	Room/Location	Sample Location	Sample No.	Draw	Result (ug/L)	Date	Draw	Result (ug/L)	Date	Draw	Result (ug/L)	Date	Draw	Result (ug/L)	Date	Notes
PbEVE	Evergreen	Room 150/152	Sink	14	A	5.1	1/4/17	C	0.16	3/15/17							
PbEVE	Evergreen	Room 150/152	Sink	14	B	2.9	1/4/17	D	0.16	3/15/17							
PbEVE	Evergreen	Room 154-KIT	Sink	15	A	22.6	1/4/17	C	2.3	7/27/17							
PbEVE	Evergreen	Room 154-KIT	Sink	15	B	3.3	1/4/17	D	0.6	7/27/17							
PbEVE	Evergreen	Room 154-BR	Sink	16	A	4.3	1/4/17	C	0.16	3/15/17							
PbEVE	Evergreen	Room 154-BR	Sink	16	B	3.2	1/4/17	D	0.16	3/15/17							
PbEVE	Evergreen	Room 157/159	Sink	17	A	5.5	1/4/17	C	0.16	3/15/17							
PbEVE	Evergreen	Room 157/159	Sink	17	B	3.3	1/4/17	D	0.16	3/15/17							
PbEVE	Evergreen	Room 162/164	Sink	18	A	48.9	1/4/17	C	0.16	3/15/17	E	3.1	7/28/17				
PbEVE	Evergreen	Room 162/164	Sink	18	B	4.7	1/4/17	D	0.16	3/15/17	F	0.31	7/28/17				
PbEVE	Evergreen	Room 167-KIT	Sink	19	A	7.3	1/4/17										
PbEVE	Evergreen	Room 167-KIT	Sink	19	B	3.1	1/4/17										
PbEVE	Evergreen	Room 167-BR	Sink	20	A	5.9	1/4/17	C	0.16	3/15/17							
PbEVE	Evergreen	Room 167-BR	Sink	20	B	2.7	1/4/17	D	0.16	3/15/17							
PbEVE	Evergreen	Room 169	Sink	21	A	42.9	1/4/17	C	7.7	7/27/17							
PbEVE	Evergreen	Room 169	Sink	21	B	5.4	1/4/17	D	1.2	7/27/17							
PbEVE	Evergreen	Room 172	Sink	22	A	15.8	1/4/17	C	5.8	7/27/17							
PbEVE	Evergreen	Room 172	Sink	22	B	13.3	1/4/17	D	0.52	7/27/17							
PbEVE	Evergreen	Room 137/139	Sink	23	A	35.5	1/4/17	C	0.16	3/15/17							
PbEVE	Evergreen	Room 137/139	Sink	23	B	2.8	1/4/17	D	0.16	3/15/17							
PbEVE	Evergreen	Room 140/142	Sink	24	A	7.4	1/4/17	C	0.16	3/15/17							
PbEVE	Evergreen	Room 140/142	Sink	24	B	3.1	1/4/17	D	0.16	3/15/17							
PbEVE	Evergreen	Room 144/146	Sink	25	A	10.6	1/4/17	C	0.16	3/15/17							
PbEVE	Evergreen	Room 144/146	Sink	25	B	3.4	1/4/17	D	0.16	3/15/17							
PbEVE	Evergreen	Room 147/149	Sink	26	A	27.8	1/4/17	C	0.16	3/15/17							
PbEVE	Evergreen	Room 147/149	Sink	26	B	3.3	1/4/17	D	0.16	3/15/17							
PbEVE	Evergreen	Room 250/252	Sink	27	A	12.2	1/4/17	C	0.16	3/15/17							
PbEVE	Evergreen	Room 250/252	Sink	27	B	3.1	1/4/17	D	0.16	3/15/17							
PbEVE	Evergreen	Room 254/256	Sink	28	A	7.6	1/4/17	C	0.16	3/15/17							
PbEVE	Evergreen	Room 254/256	Sink	28	B	3	1/4/17	D	0.16	3/15/17							
PbEVE	Evergreen	Room 257/259	Sink	29	A	16.5	1/4/17	C	0.16	3/15/17							
PbEVE	Evergreen	Room 257/259	Sink	29	B	2.9	1/4/17	D	0.16	3/15/17							
PbEVE	Evergreen	Room 262/264	Sink	30	A	16	1/4/17	C	0.16	3/15/17							
PbEVE	Evergreen	Room 262/264	Sink	30	B	3.6	1/4/17	D	0.16	3/15/17							
PbEVE	Evergreen	Room 265/267	Sink	31	A	21	1/4/17	C	0.16	3/15/17							
PbEVE	Evergreen	Room 265/267	Sink	31	B	4.4	1/4/17	D	0.16	3/15/17							
PbEVE	Evergreen	Room 269/271	Sink	32	A	10.8	1/4/17	C	0.16	3/15/17							
PbEVE	Evergreen	Room 269/271	Sink	32	B	11.1	1/4/17	D	0.16	3/15/17							
PbEVE	Evergreen	Room 237/239	Sink	33	A	6.7	1/4/17	C	0.16	3/15/17							
PbEVE	Evergreen	Room 237/239	Sink	33	B	2.7	1/4/17	D	0.16	3/15/17							
PbEVE	Evergreen	Room 240/242	Sink	34	A	32.7	1/4/17	C	0.16	3/15/17							
PbEVE	Evergreen	Room 240/242	Sink	34	B	4.2	1/4/17	D	0.16	3/15/17							
PbEVE	Evergreen	Room 244/246	Sink	35	A	68.1	1/4/17	C	0.16	3/15/17	E	5.7	7/28/17				
PbEVE	Evergreen	Room 244/246	Sink	35	B	2.7	1/4/17	D	0.16	3/15/17	F	0.46	7/28/17				
PbEVE	Evergreen	Room 247/249	Sink	36	A	5.5	1/4/17	C	0.16	3/15/17							
PbEVE	Evergreen	Room 247/249	Sink	36	B	2.2	1/4/17	D	0.16	3/15/17							
PbEVE	Evergreen	Room 202/204	Sink	37	A	7.2	1/4/17	C	0.16	3/15/17							
PbEVE	Evergreen	Room 202/204	Sink	37	B	3.6	1/4/17	D	0.16	3/15/17							
PbEVE	Evergreen	Room 206/208	Sink	38	A	15.3	1/4/17	C	0.16	3/15/17							
PbEVE	Evergreen	Room 206/208	Sink	38	B	2.2	1/4/17	D	0.16	3/15/17							
PbEVE	Evergreen	Room 209/211	Sink	39	A	11.2	1/4/17	C	0.16	3/15/17							
PbEVE	Evergreen	Room 209/211	Sink	39	B	2.6	1/4/17	D	0.16	3/15/17							
PbEVE	Evergreen	Room 214/216	Sink	40	A	4.1	1/4/17	C	0.16	3/15/17							
PbEVE	Evergreen	Room 214/216	Sink	40	B	2	1/4/17	D	0.16	3/15/17							
PbEVE	Evergreen	Room 217/219	Sink	41	A	6.8	1/4/17	C	0.16	3/15/17							
PbEVE	Evergreen	Room 217/219	Sink	41	B	3.8	1/4/17	D	0.16	3/15/17							
PbEVE	Evergreen	Room 221/223	Sink	42	A	7.4	1/4/17	C	0.16	3/15/17							

Sample ID	Building	Room/Location	Sample Location	Sample No.	Draw	Result (ug/L)	Date	Draw	Result (ug/L)	Date	Draw	Result (ug/L)	Date	Draw	Result (ug/L)	Date	Notes
PbEVE	Evergreen	Room 221/223	Sink	42	B	5.9	1/4/17	D	0.16	3/15/17							
PbEVE	Evergreen	Room 224/226	Sink	43	A	5.4	1/4/17	C	0.16	3/15/17							
PbEVE	Evergreen	Room 224/226	Sink	43	B	2.3	1/4/17	D	0.16	3/15/17							
PbEVE	Evergreen	Room 227/229	Sink	44	A	7.6	1/4/17	C	0.16	3/15/17							
PbEVE	Evergreen	Room 227/229	Sink	44	B	1.9	1/4/17	D	0.16	3/15/17							
PbEVE	Evergreen	Room 231/233	Sink	45	A	2.5	1/4/17	C	0.16	3/15/17							
PbEVE	Evergreen	Room 231/233	Sink	45	B	1.6	1/4/17	D	0.16	3/15/17							
PbEVE	Evergreen	Room 234/236	Sink	46	A	5.6	1/4/17	C	0.16	3/15/17							
PbEVE	Evergreen	Room 234/236	Sink	46	B	1.9	1/4/17	D	0.16	3/15/17							
PbEVE	Evergreen	Room 350/352	Sink	47	A	17.4	1/4/17	C	0.16	3/15/17							
PbEVE	Evergreen	Room 350/352	Sink	47	B	4.2	1/4/17	D	0.16	3/15/17							
PbEVE	Evergreen	Room 354/356	Sink	48	A	15.1	1/4/17	C	0.16	3/15/17							
PbEVE	Evergreen	Room 354/356	Sink	48	B	3.4	1/4/17	D	0.16	3/15/17							
PbEVE	Evergreen	Room 357/359	Sink	49	A	8.7	1/4/17	C	0.16	3/15/17							
PbEVE	Evergreen	Room 357/359	Sink	49	B	1.4	1/4/17	D	0.16	3/15/17							
PbEVE	Evergreen	Room 362/364	Sink	50	A	16.4	1/4/17	C	0.16	3/15/17							
PbEVE	Evergreen	Room 362/364	Sink	50	B	2.2	1/4/17	D	0.16	3/15/17							
PbEVE	Evergreen	Room 365/367	Sink	51	A	15.4	1/4/17	C	0.16	3/15/17							
PbEVE	Evergreen	Room 365/367	Sink	51	B	7.5	1/4/17	D	0.16	3/15/17							
PbEVE	Evergreen	Room 369/371	Sink	52	A	14.6	1/4/17	C	0.16	3/15/17							
PbEVE	Evergreen	Room 369/371	Sink	52	B	25.1	1/4/17	D	0.16	3/15/17							
PbEVE	Evergreen	Room 337/339	Sink	53	A	11.2	1/4/17	C	0.16	3/15/17							
PbEVE	Evergreen	Room 337/339	Sink	53	B	2.8	1/4/17	D	0.16	3/15/17							
PbEVE	Evergreen	Room 340/342	Sink	54	A	12.9	1/4/17	C	0.16	3/15/17							
PbEVE	Evergreen	Room 340/342	Sink	54	B	2.3	1/4/17	D	0.16	3/15/17							
PbEVE	Evergreen	Room 344/346	Sink	55	A	9.9	1/4/17	C	0.16	3/15/17							
PbEVE	Evergreen	Room 344/346	Sink	55	B	1.2	1/4/17	D	0.16	3/15/17							
PbEVE	Evergreen	Room 347/349	Sink	56	A	857	1/4/17	C	0.16	3/15/17	E	2	7/28/17				
PbEVE	Evergreen	Room 347/349	Sink	56	B	31.3	1/4/17	D	0.16	3/15/17	F	0.26	7/28/17				
PbEVE	Evergreen	Room 180	Sink	57	A	45.2	1/4/17										Room is under construction and sink currently is inoperable.
PbEVE	Evergreen	Room 180	Sink	57	B	8.9	1/4/17										
PbEVE	Evergreen	Room 302/304	Sink	58	A	3.3	1/4/17	C	0.16	3/15/17							
PbEVE	Evergreen	Room 302/304	Sink	58	B	2.6	1/4/17	D	0.16	3/15/17							
PbEVE	Evergreen	Room 306/308	Sink	59	A	5.4	1/4/17	C	0.16	3/15/17							
PbEVE	Evergreen	Room 306/308	Sink	59	B	2.5	1/4/17	D	0.16	3/15/17							
PbEVE	Evergreen	Room 309/311	Sink	60	A	7	1/4/17	C	0.16	3/15/17							
PbEVE	Evergreen	Room 309/311	Sink	60	B	1.4	1/4/17	D	0.16	3/15/17							
PbEVE	Evergreen	Room 314/316	Sink	61	A	19.3	1/4/17	C	0.16	3/15/17							
PbEVE	Evergreen	Room 314/316	Sink	61	B	4	1/4/17	D	0.16	3/15/17							
PbEVE	Evergreen	Room 317/319	Sink	62	A	144	1/4/17	C	0.16	3/15/17	E	1.8	7/28/17				
PbEVE	Evergreen	Room 317/319	Sink	62	B	5	1/4/17	D	0.16	3/15/17	F	0.37	7/28/17				
PbEVE	Evergreen	Room 321/323	Sink	63	A	21.9	1/4/17	C	0.16	3/15/17							
PbEVE	Evergreen	Room 321/323	Sink	63	B	6.5	1/4/17	D	0.16	3/15/17							
PbEVE	Evergreen	Room 324/326	Sink	64	A	7.6	1/4/17	C	0.16	3/15/17							
PbEVE	Evergreen	Room 324/326	Sink	64	B	2.2	1/4/17	D	0.16	3/15/17							
PbEVE	Evergreen	Room 327/329	Sink	65	A	20.6	1/4/17	C	0.16	3/15/17							
PbEVE	Evergreen	Room 327/329	Sink	65	B	1.1	1/4/17	D	0.16	3/15/17							
PbEVE	Evergreen	Room 331/333	Sink	66	A	7.3	1/4/17	C	0.16	3/15/17							
PbEVE	Evergreen	Room 331/333	Sink	66	B	0.77	1/4/17	D	0.16	3/15/17							
PbEVE	Evergreen	Room 334/336	Sink	67	A	11.1	1/4/17	C	0.16	3/15/17							
PbEVE	Evergreen	Room 334/336	Sink	67	B	2.1	1/4/17	D	0.16	3/15/17							
PbEVE	Evergreen	Room 110A	Sink	68	A	44.7	1/4/17	C	0.16	3/15/17							
PbEVE	Evergreen	Room 110A	Sink	68	B	5.6	1/4/17	D	0.16	3/15/17							
PbEVE	Evergreen	Room 101A-KIT	Sink	69	A	9.2	1/4/17										
PbEVE	Evergreen	Room 101A-KIT	Sink	69	B	12.9	1/4/17										
PbEVE	Evergreen	Room 101A-BR	Sink	70	A	37.8	1/4/17	C	0.16	3/15/17							
PbEVE	Evergreen	Room 101A-BR	Sink	70	B	12.2	1/4/17	D	0.16	3/15/17							

Sample ID	Building	Room/Location	Sample Location	Sample No.	Draw	Result (ug/L)	Date	Draw	Result (ug/L)	Date	Draw	Result (ug/L)	Date	Draw	Result (ug/L)	Date	Notes
PbEVE	Evergreen	Room 173KN	Sink	71	A	41.3	1/4/17										Room is under construction and sink currently is inoperable.
PbEVE	Evergreen	Room 173KN	Sink	71	B	3.6	1/4/17										
PbGIR	Girard House	Room 106	Sink	3	A	18.6	11/3/16	C	0.16	2/28/17							
PbGIR	Girard House	Room 106	Sink	3	B	2.4	11/3/16	D	0.16	2/28/17							
PbGIR	Girard House	Room 101C	Sink	4	A	5.4	11/3/16										
PbGIR	Girard House	Room 101C	Sink	4	B	1.8	11/3/16										
PbGIR	Girard House	Room 101C	Fridge water dispenser	5	A	4.7	11/3/16										
PbGIR	Girard House	Room 101C	Fridge water dispenser	5	B	1.9	11/3/16										
PbGIR	Girard House	Room 101C	Coffee Maker	6	A	1.1	11/3/16										
PbGIR	Girard House	Room 101C	Coffee Maker	6	B	1.2	11/3/16										
PbGRE	Sangee Greenhouse	Room 102	Sink	2	A	4.5	11/15/16										
PbGRE	Sangee Greenhouse	Room 102	Sink	2	B	0.51	11/15/16										
PbGTH	John Green Team House	Room 119	Backflow Preventer	1	A	0.23	12/23/16										
PbGTH	John Green Team House	Room 119	Backflow Preventer	1	B	1590	12/23/16										Although water tested at backflow preventer (where water first enters the building) shows a high concentation of lead, faucets throughout the buildings fall below the 15ppb threshold.
PbGTH	John Green Team House	Room H101	Water Fountain	2	A	0.16	12/23/16										
PbGTH	John Green Team House	Room H101	Water Fountain	2	B	0.16	12/23/16										
PbGTH	John Green Team House	Room 100	Ice Machine	3	A	0.18	12/23/16										
PbGTH	John Green Team House	Room 100	Ice Machine	3	B	0.16	12/23/16										
PbGTH	John Green Team House	Room 100	Water Dispenser	4	A	7.5	12/23/16										
PbGTH	John Green Team House	Room 100	Water Dispenser	4	B	0.6	12/23/16										
PbGTH	John Green Team House	Room 109	Water Fountain	5	A	7.2	12/23/16										
PbGTH	John Green Team House	Room 109	Water Fountain	5	B	0.86	12/23/16										
PbGTH	John Green Team House	Room H100	Ice Machine	6	A	0.16	12/23/16										
PbGTH	John Green Team House	Room H100	Ice Machine	6	B	0.16	12/23/16										
PbGTH	John Green Team House	Room H100	Ice Machine	6	B	0.16	12/23/16										
PbGTH	John Green Team House	Room 110	Water Fountain	7	A	20	12/23/16	C	18.8	2/23/17							Sample above action level. Fountain taken offline.
PbGTH	John Green Team House	Room 110	Water Fountain	7	B	2.5	12/23/16	D	1.8	2/23/17							
PbGTH	John Green Team House	Room 114	Water Fountain	8	A	6.3	12/23/16										
PbGTH	John Green Team House	Room 114	Water Fountain	8	B	0.51	12/23/16										
PbGTH	John Green Team House	Corridor	Ice Machine	9	B	0.16	12/23/16										
PbGTH	John Green Team House	Corridor	Ice Machine	9	A	0.5	12/23/16										
PbGTH	John Green Team House	Corridor	Ice Machine	10	A	0.35	12/23/16										
PbGTH	John Green Team House	Corridor	Ice Machine	10	B	2.1	12/23/16										
PbGTH	John Green Team House	Lobby	Water Fountain	11	A	0.16	12/23/16										
PbGTH	John Green Team House	Lobby	Water Fountain	11	B	0.84	12/23/16										
PbHAW	Hawthorn Hall	Room 105	Sink	2	A	10	11/3/16										
PbHAW	Hawthorn Hall	Room 105	Sink	2	B	3.2	11/3/16										
PbHAW	Hawthorn Hall	Room 105	Water Fountain	3	A	0.16	11/3/16										
PbHAW	Hawthorn Hall	Room 105	Water Fountain	3	B	0.16	11/3/16										
PbHAW	Hawthorn Hall	Room 205	Water Fountain	4	A	0.16	11/3/16										
PbHAW	Hawthorn Hall	Room 205	Water Fountain	4	B	0.16	11/3/16										
PbHAW	Hawthorn Hall	Room 307	Water Fountain	5	A	0.16	11/3/16										
PbHAW	Hawthorn Hall	Room 307	Water Fountain	5	B	0.16	11/3/16										
PbHAW	Hawthorn Hall	Room 301	Sink	6	A	3.5	11/3/16										
PbHAW	Hawthorn Hall	Room 301	Sink	6	B	1.8	11/3/16										
PbHER	Hering Heating Plant	Room 115C	Sink	2	A	0.83	11/10/16										
PbHER	Hering Heating Plant	Room 115C	Sink	2	B	0.71	11/10/16										
PbHER	Hering Heating Plant	Chiller room	Sink	3	A	2	12/28/16										
PbHER	Hering Heating Plant	Chiller room	Sink	3	B	0.22	12/28/16										
PbHER	Hering Heating Plant	Room 210	Sink	5	A	0.94	11/10/16										
PbHER	Hering Heating Plant	Room 210	Sink	5	B	0.49	11/10/16										

Sample ID	Building	Room/Location	Sample Location	Sample No.	Draw	Result (ug/L)	Date	Draw	Result (ug/L)	Date	Draw	Result (ug/L)	Date	Draw	Result (ug/L)	Date	Notes
PbHOL	Holly Bush Mansion	Room 107	Sink (Steel)	2	A	3.4	11/15/16										
PbHOL	Holly Bush Mansion	Room 107	Sink (Steel)	2	B	0.55	11/15/16										
PbHOL	Holly Bush Mansion	Room 107	Sink (Ceramic)	3	A	1.6	11/15/16										
PbHOL	Holly Bush Mansion	Room 107	Sink (Ceramic)	3	B	0.9	11/15/16										
PbHPC	HollyPoint Commons	Mechanical Room	Backflow Preventer	1	A	35.7	12/30/16										Although water tested at backflow preventer (where water first enters the building) shows a high concentation of lead, faucets throughout the buildings fall below the 15ppb threshold.
PbHPC	HollyPoint Commons	Mechanical Room	Backflow Preventer	1	B	7	12/30/16										
PbHPC	HollyPoint Commons	Room D105	Sink	2	A	1	12/30/16										
PbHPC	HollyPoint Commons	Room D105	Sink	2	B	1.6	12/30/16										
PbHPC	HollyPoint Commons	Room D115	Water Fountain	3	A	2.8	12/30/16										
PbHPC	HollyPoint Commons	Room D115	Water Fountain	3	B	0.16	12/30/16										
PbHPC	HollyPoint Commons	Room D113	Sink	4	A	1.2	12/30/16										
PbHPC	HollyPoint Commons	Room D113	Sink	4	B	0.57	12/30/16										
PbHPC	HollyPoint Commons	Room D115	Sink	5	A	2	12/30/16										
PbHPC	HollyPoint Commons	Room D115	Sink	5	B	0.85	12/30/16										
PbHPC	HollyPoint Commons	Room D220	Water Fountain	6	A	0.95	12/30/16										
PbHPC	HollyPoint Commons	Room D220	Water Fountain	6	B	0.22	12/30/16										
PbHPC	HollyPoint Commons	Room D204	Sink	7	A	8.8	12/30/16										
PbHPC	HollyPoint Commons	Room D204	Sink	7	B	1.5	12/30/16										
PbHPC	HollyPoint Commons	Room D320	Water Fountain	8	A	0.17	12/30/16										
PbHPC	HollyPoint Commons	Room D320	Water Fountain	8	B	0.17	12/30/16										
PbHPC	HollyPoint Commons	Room D307	Sink	9	B	1.6	12/30/16										
PbHPC	HollyPoint Commons	Room D307	Sink	9	A	2.6	12/30/16										
PbHPC	HollyPoint Commons	Room D420	Water Fountain	10	A	0.27	12/30/16										
PbHPC	HollyPoint Commons	Room D420	Water Fountain	10	B	0.16	12/30/16										
PbHPC	HollyPoint Commons	Room D404	Sink	11	A	0.85	12/30/16										
PbHPC	HollyPoint Commons	Room D404	Sink	11	B	0.26	12/30/16										
PbHPC	HollyPoint Commons	Receiving	Ice Machine	12	A	0.16	12/30/16										
PbHPC	HollyPoint Commons	Receiving	Ice Machine	12	B	0.16	12/30/16										
PbHPC	HollyPoint Commons	Super Office	Prep Sink	13	A	2.4	12/30/16										
PbHPC	HollyPoint Commons	Super Office	Prep Sink	13	B	2.5	12/30/16										
PbHPC	HollyPoint Commons	Ovens	Prep Sink	14	A	11.9	12/30/16										
PbHPC	HollyPoint Commons	Ovens	Prep Sink	14	B	3.2	12/30/16										
PbHPC	HollyPoint Commons	Dish Room	Beverage Station	15	A	0.31	12/30/16										
PbHPC	HollyPoint Commons	Dish Room	Beverage Station	15	B	1.3	12/30/16										
PbHPC	HollyPoint Commons	Curved Wall	Coffee Pot	16	A	550	12/30/16	C	4.3	3/10/17							
PbHPC	HollyPoint Commons	Curved Wall	Coffee Pot	16	B	39.7	12/30/16	D	0.19	3/10/17							
PbHPC	HollyPoint Commons	Curved Wall	Soda Machine	17	A	0.16	12/30/16										
PbHPC	HollyPoint Commons	Curved Wall	Soda Machine	17	B	0.94	12/30/16										
PbHPC	HollyPoint Commons	Grill Prep Station	Sink	18	A	9.8	12/30/16										
PbHPC	HollyPoint Commons	Grill Prep Station	Sink	18	B	0.49	12/30/16										
PbHPC	HollyPoint Commons	Starbucks	Sink	19	A	3.1	12/30/16										
PbHPC	HollyPoint Commons	Starbucks	Sink	19	B	0.47	12/30/16										
PbINT	International House	S1	Water Main Spigot	1	A	7.3	12/30/16										
PbINT	International House	S1	Water Main Spigot	1	B	18.5	12/30/16										Although water tested at backflow preventer (where water first enters the building) shows a high concentation of lead, faucets throughout the buildings fall below the 15ppb threshold.
PbINT	International House	Room 106	Sink	2	A	17.2	12/30/16	C	0.16	2/28/17							
PbINT	International House	Room 106	Sink	2	B	17.8	12/30/16	D	0.16	2/28/17							
PbINT	International House	Room 103	Sink	3	A	1.8	12/30/16										
PbINT	International House	Room 103	Sink	3	B	5.7	12/30/16										
PbINT	International House	Room 204	Sink	4	A	4.1	12/30/16										
PbINT	International House	Room 204	Sink	4	B	11.8	12/30/16										

Sample ID	Building	Room/Location	Sample Location	Sample No.	Draw	Result (ug/L)	Date	Draw	Result (ug/L)	Date	Draw	Result (ug/L)	Date	Draw	Result (ug/L)	Date	Notes
PbINTG	International House Garage	Kitchen	Sink	2	A	0.95	12/30/16										
PbINTG	International House Garage	Kitchen	Sink	2	B	0.29	12/30/16										
PbJAM	James Education	Room 1140	Water Fountain	2	A	0.098	11/10/16										
PbJAM	James Education	Room 1140	Water Fountain	2	B	0.09	11/10/16										
PbJAM	James Education	Room L1002	Sink	3	A	0.49	11/10/16										
PbJAM	James Education	Room L1002	Sink	3	B	0.28	11/10/16										
PbJAM	James Education	Room L1002	Water Dispenser	4	A	0.28	11/10/16										
PbJAM	James Education	Room L1002	Water Dispenser	4	B	0.09	11/10/16										
PbJAM	James Education	Room 1145	Water Fountain	5	A	0.09	11/10/16										
PbJAM	James Education	Room 1145	Water Fountain	5	B	0.09	11/10/16										
PbJAM	James Education	Room 1020	Sink	6	A	0.59	11/10/16										
PbJAM	James Education	Room 1020	Sink	6	B	0.35	11/10/16										
PbJAM	James Education	Room 1087	Water Fountain	7	A	0.23	11/10/16										
PbJAM	James Education	Room 1087	Water Fountain	7	B	0.74	11/10/16										
PbJAM	James Education	Room 1089	Water Fountain	8	A	0.09	11/10/16										
PbJAM	James Education	Room 1089	Water Fountain	8	B	0.09	11/10/16										
PbJAM	James Education	Room 1087	Sink	9	B	0.61	11/10/16										
PbJAM	James Education	Room 1087	Sink	9	A	0.58	11/10/16										
PbJAM	James Education	Room 1091	Sink	10	A	1.2	11/10/16										
PbJAM	James Education	Room 1091	Sink	10	B	0.5	11/10/16										
PbJAM	James Education	Room 2004	Water Fountain	11	A	0.18	11/10/16										
PbJAM	James Education	Room 2004	Water Fountain	11	B	0.09	11/10/16										
PbJAM	James Education	Room 2018	Sink	12	A	0.41	11/10/16										
PbJAM	James Education	Room 2018	Sink	12	B	0.29	11/10/16										
PbJAM	James Education	Room 2018	Water Fountain	13	A	0.17	11/10/16										
PbJAM	James Education	Room 2018	Water Fountain	13	B	0.42	11/10/16										
PbJAM	James Education	Room 2043	Sink	14	A	0.41	11/10/16										
PbJAM	James Education	Room 2043	Sink	14	B	0.26	11/10/16										
PbJAM	James Education	Room 2059	Water Fountain	15	A	0.2	11/10/16										
PbJAM	James Education	Room 2059	Water Fountain	15	B	0.37	11/10/16										
PbJAM	James Education	Room 2059	Sink	16	A	0.41	11/10/16										
PbJAM	James Education	Room 2059	Sink	16	B	0.29	11/10/16										
PbJAM	James Education	Room 2007	Water Fountain	17	A	0.09	11/10/16										
PbJAM	James Education	Room 2007	Water Fountain	17	B	0.09	11/10/16										
PbJAM	James Education	Room 3020	Water Fountain	18	A	0.19	11/10/16										
PbJAM	James Education	Room 3020	Water Fountain	18	B	0.47	11/10/16										
PbJAM	James Education	Room 3017	Sink	19	A	1	11/10/16										
PbJAM	James Education	Room 3017	Sink	19	B	0.3	11/10/16										
PbJAM	James Education	Room 3020	Sink	20	A	1.1	11/10/16										
PbJAM	James Education	Room 3020	Sink	20	B	0.3	11/10/16										
PbJAM	James Education	Room 3069	Sink	21	A	0.37	11/10/16										
PbJAM	James Education	Room 3069	Sink	21	B	0.19	11/10/16										
PbJAM	James Education	Room 3047	Water Fountain	22	A	0.16	11/10/16										
PbJAM	James Education	Room 3047	Water Fountain	22	B	0.23	11/10/16										
PbJAM	James Education	Room 3051	Sink	23	A	0.44	11/10/16										
PbJAM	James Education	Room 3051	Sink	23	B	0.26	11/10/16										
PbJAM	James Education	Room 3108	Water Fountain	24	A	0.39	11/10/16										
PbJAM	James Education	Room 3108	Water Fountain	24	B	0.66	11/10/16										
PbJAM	James Education	Room 3098	Sink	25	A	0.78	11/10/16										
PbJAM	James Education	Room 3098	Sink	25	B	0.51	11/10/16										
PbJAM	James Education	Room 3097	Water Fountain	26	A	0.23	11/10/16										
PbJAM	James Education	Room 3097	Water Fountain	26	B	0.46	11/10/16										
PbJAM	James Education	Room 3007	Water Fountain	27	A	0.21	11/10/16										
PbJAM	James Education	Room 3007	Water Fountain	27	B	0.14	11/10/16										

Sample ID	Building	Room/Location	Sample Location	Sample No.	Draw	Result (ug/L)	Date	Draw	Result (ug/L)	Date	Draw	Result (ug/L)	Date	Draw	Result (ug/L)	Date	Notes
PbLH	Laurel Hall	Room 118BA	Bathroom sink	2	A	0.16	1/5/17										
PbLH	Laurel Hall	Room 118BA	Bathroom sink	2	B	0.16	1/5/17										
PbLH	Laurel Hall	Room 117BA	Bathroom sink	3	A	0.16	1/5/17										
PbLH	Laurel Hall	Room 117BA	Bathroom sink	3	B	0.16	1/5/17										
PbLH	Laurel Hall	Room 108BA	Bathroom sink	4	A	0.16	1/5/17										
PbLH	Laurel Hall	Room 108BA	Bathroom sink	4	B	0.16	1/5/17										
PbLH	Laurel Hall	Room 103BA	Bathroom sink	5	A	0.16	1/5/17										
PbLH	Laurel Hall	Room 103BA	Bathroom sink	5	B	0.16	1/5/17										
PbLH	Laurel Hall	Room 104BA	Bathroom sink	6	A	0.16	1/5/17	C	1.6	7/28/17							
PbLH	Laurel Hall	Room 104BA	Bathroom sink	6	B	0.16	1/5/17	D	0.16	7/28/17							
PbLH	Laurel Hall	Room 213BA	Bathroom sink	7	A	0.16	1/5/17										
PbLH	Laurel Hall	Room 213BA	Bathroom sink	7	B	0.16	1/5/17										
PbLH	Laurel Hall	Adj to Rm 211	Water Fountain	8	A	0.16	7/27/17										
PbLH	Laurel Hall	Adj to Rm 211	Water Fountain	8	B	0.16	7/27/17										
PbLH	Laurel Hall	Room 218BA	Bathroom sink	9	A	0.16	1/5/17										
PbLH	Laurel Hall	Room 218BA	Bathroom sink	9	B	0.16	1/5/17										
PbLH	Laurel Hall	Room 202BA	Bathroom sink	10	A	0.16	1/5/17										
PbLH	Laurel Hall	Room 202BA	Bathroom sink	10	B	0.16	1/5/17										
PbLH	Laurel Hall	Room 208BA	Bathroom sink	11	A	0.16	1/5/17										
PbLH	Laurel Hall	Room 208BA	Bathroom sink	11	B	0.16	1/5/17										
PbLH	Laurel Hall	Room 310BA	Bathroom sink	12	A	0.16	1/5/17										
PbLH	Laurel Hall	Room 310BA	Bathroom sink	12	B	0.16	1/5/17										
PbLH	Laurel Hall	Room 309BA	Bathroom sink	13	A	0.16	1/5/17										
PbLH	Laurel Hall	Room 309BA	Bathroom sink	13	B	0.16	1/5/17										
PbLH	Laurel Hall	Adj to Rm 307	Water Fountain	14	A	0.16	7/27/17										
PbLH	Laurel Hall	Adj to Rm 307	Water Fountain	14	B	0.16	7/27/17										
PbLH	Laurel Hall	Adj to Rm 305	Water Fountain	15	A	0.16	7/27/17										
PbLH	Laurel Hall	Adj to Rm 305	Water Fountain	15	B	0.16	7/27/17										
PbLH	Laurel Hall	Room 307BA	Bathroom sink	16	A	0.16	1/5/17										
PbLH	Laurel Hall	Room 307BA	Bathroom sink	16	B	0.16	1/5/17										
PbLH	Laurel Hall	Room 303BA	Bathroom sink	17	A	0.16	1/5/17	C	1.1	7/28/17							
PbLH	Laurel Hall	Room 303BA	Bathroom sink	17	B	0.16	1/5/17	D	0.16	7/28/17							
PbLH	Laurel Hall	Room 117BA	Water Fountain	18	A	0.16	1/5/17										
PbLH	Laurel Hall	Room 117BA	Water Fountain	18	B	0.16	1/5/17										
PbLH	Laurel Hall	ADJ to Rm 103BA	Water Fountain	19	A	0.16	1/5/17										
PbLH	Laurel Hall	ADJ to Rm 103BA	Water Fountain	19	B	0.16	1/5/17										
PbLIN	Linden Hall	Room 1126	Sink	2	A	0.79	11/1/16										
PbLIN	Linden Hall	Room 1126	Sink	2	B	0.95	11/1/16										
PbLIN	Linden Hall	Room H131	Sink	3	A	12.2	11/1/16										
PbLIN	Linden Hall	Room H131	Sink	3	B	1	11/1/16										
PbLIN	Linden Hall	Room 222	Sink	4	A	2.9	11/1/16										
PbLIN	Linden Hall	Room 222	Sink	4	B	2.5	11/1/16										
PbMAG	Magnolia Hall	Room 006MA	backflow preventer	1	A	117	12/30/16										Although water tested at backflow preventer (where water first enters the building) shows a high concentation of lead, faucets throughout the buildings fall below the 15ppb threshold.
PbMAG	Magnolia Hall	Room 006MA	backflow preventer	1	B	43.9	12/30/16										Although water tested at backflow preventer (where water first enters the building) shows a high concentation of lead, faucets throughout the buildings fall below the 15ppb threshold.
PbMAG	Magnolia Hall	Room 100BA	sink	2	A	2.2	12/30/16	C	0.16	3/16/17							
PbMAG	Magnolia Hall	Room 100BA	sink	2	B	1.1	12/30/16	D	0.16	3/16/17							
PbMAG	Magnolia Hall	Room 101BA	sink	3	A	28.2	12/30/16	C	0.16	3/16/17							
PbMAG	Magnolia Hall	Room 101BA	sink	3	B	1.8	12/30/16	D	0.16	3/16/17							
PbMAG	Magnolia Hall	Room 102BA	sink	4	A	9.1	12/30/16	C	0.16	3/16/17							
PbMAG	Magnolia Hall	Room 102BA	sink	4	B	1.4	12/30/16	D	0.16	3/16/17							
PbMAG	Magnolia Hall	Room 103BA	sink	5	A	1.7	12/30/16	C	0.16	3/16/17							

Sample ID	Building	Room/Location	Sample Location	Sample No.	Draw	Result (ug/L)	Date	Draw	Result (ug/L)	Date	Draw	Result (ug/L)	Date	Draw	Result (ug/L)	Date	Notes
PbMAG	Magnolia Hall	Room 103BA	sink	5	B	5.6	12/30/16	D	0.16	3/16/17							
PbMAG	Magnolia Hall	Room 104BA	sink	6	A	13.7	12/30/16	C	0.16	3/16/17							
PbMAG	Magnolia Hall	Room 104BA	sink	6	B	1.9	12/30/16	D	0.16	3/16/17							
PbMAG	Magnolia Hall	Room 105BA	sink	7	A	10.1	12/30/16	C	0.16	3/16/17							
PbMAG	Magnolia Hall	Room 105BA	sink	7	B	2.5	12/30/16	D	0.16	3/16/17							
PbMAG	Magnolia Hall	Room 106BA	sink	8	A	96.4	12/30/16	C	0.16	3/16/17	E	3.3	7/28/17				
PbMAG	Magnolia Hall	Room 106BA	sink	8	B	21.4	12/30/16	D	0.16	3/16/17	F	1.8	7/28/17				
PbMAG	Magnolia Hall	Room 107BA	sink	9	B	3.7	12/30/16	C	0.16	3/16/17							
PbMAG	Magnolia Hall	Room 107BA	sink	9	A	3.2	12/30/16	D	0.16	3/16/17							
PbMAG	Magnolia Hall	Room 108BA	sink	10	A	16.9	12/30/16	C	0.16	3/16/17							
PbMAG	Magnolia Hall	Room 108BA	sink	10	B	17.8	12/30/16	D	0.16	3/16/17							
PbMAG	Magnolia Hall	Room 200BA	sink	11	A	1.9	12/30/16	C	0.16	3/16/17							
PbMAG	Magnolia Hall	Room 200BA	sink	11	B	2.5	12/30/16	D	0.16	3/16/17							
PbMAG	Magnolia Hall	Room 201BA	sink	12	A	2	12/30/16	C	0.16	3/16/17							
PbMAG	Magnolia Hall	Room 201BA	sink	12	B	1.1	12/30/16	D	0.16	3/16/17							
PbMAG	Magnolia Hall	Room 202BA	sink	13	A	6.3	12/30/16	C	0.4	3/16/17							
PbMAG	Magnolia Hall	Room 202BA	sink	13	B	3.1	12/30/16	D	0.16	3/16/17							
PbMAG	Magnolia Hall	Room 203BA	sink	14	A	3.8	12/30/16	C	0.16	3/16/17							
PbMAG	Magnolia Hall	Room 203BA	sink	14	B	1.5	12/30/16	D	0.16	3/16/17							
PbMAG	Magnolia Hall	Room 204BA	sink	15	A	3.3	12/30/16	C	1.4	3/16/17							
PbMAG	Magnolia Hall	Room 204BA	sink	15	B	1.3	12/30/16	D	0.16	3/16/17							
PbMAG	Magnolia Hall	Room 205BA	sink	16	A	2.2	12/30/16	C	0.42	3/16/17							
PbMAG	Magnolia Hall	Room 205BA	sink	16	B	5.5	12/30/16	D	0.16	3/16/17							
PbMAG	Magnolia Hall	Room 206BA	sink	17	A	7	12/30/16	C	0.16	3/16/17							
PbMAG	Magnolia Hall	Room 206BA	sink	17	B	12.2	12/30/16	D	0.16	3/16/17							
PbMAG	Magnolia Hall	Room 207BA	sink	18	A	2.8	12/30/16	C	0.16	3/16/17							
PbMAG	Magnolia Hall	Room 207BA	sink	18	B	5.6	12/30/16	D	0.16	3/16/17							
PbMAG	Magnolia Hall	Room 300BA	sink	19	A	1.7	12/30/16	C	0.16	3/16/17							
PbMAG	Magnolia Hall	Room 300BA	sink	19	B	2.3	12/30/16	D	0.16	3/16/17							
PbMAG	Magnolia Hall	Room 301BA	sink	20	A	13.4	12/30/16	C	0.16	3/16/17							
PbMAG	Magnolia Hall	Room 301BA	sink	20	B	1.3	12/30/16	D	0.16	3/16/17							
PbMAG	Magnolia Hall	Room 302BA	sink	21	A	3	12/30/16	C	0.16	3/16/17							
PbMAG	Magnolia Hall	Room 302BA	sink	21	B	1.3	12/30/16	D	0.16	3/16/17							
PbMAG	Magnolia Hall	Room 303BA	sink	22	A	17.3	12/30/16	C	0.16	3/16/17							
PbMAG	Magnolia Hall	Room 303BA	sink	22	B	2.2	12/30/16	D	0.16	3/16/17							
PbMAG	Magnolia Hall	Room 304BA	sink	23	A	329	12/30/16	C	1.5	3/16/17	E	18.9	7/28/17	G	2.9	8/16/17	
PbMAG	Magnolia Hall	Room 304BA	sink	23	B	10.3	12/30/16	D	0.16	3/16/17	F	0.37	7/28/17	H	0.69	8/16/17	
PbMAG	Magnolia Hall	Room 305BA	sink	24	A	2.4	12/30/16	C	0.16	3/16/17							
PbMAG	Magnolia Hall	Room 305BA	sink	24	B	2.5	12/30/16	D	0.16	3/16/17							
PbMAG	Magnolia Hall	Room 306BA	sink	25	A	11.3	12/30/16	C	0.26	3/16/17							
PbMAG	Magnolia Hall	Room 306BA	sink	25	B	2	12/30/16	D	0.16	3/16/17							
PbMAG	Magnolia Hall	Room 307BA	sink	26	A	1.3	12/30/16	C	0.16	3/16/17							
PbMAG	Magnolia Hall	Room 307BA	sink	26	B	3.3	12/30/16	D	0.16	3/16/17							
PbMAG	Magnolia Hall	Apartment	sink	27	A	51.3	12/30/16	C	0.16	4/27/17							
PbMAG	Magnolia Hall	Apartment	sink	27	B	3.9	12/30/16	D	0.16	4/27/17							
PbMEM	Memorial Hall	Room 193	Sink	2	A	0.29	11/1/16										
PbMEM	Memorial Hall	Room 193	Sink	2	B	0.16	11/1/16										
PbMEM	Memorial Hall	Room H106	Water Fountain	3	A	0.16	11/1/16										
PbMEM	Memorial Hall	Room H106	Water Fountain	3	B	0.16	11/1/16										
PbMEM	Memorial Hall	Room L102	Water Fountain	4	A	0.16	11/1/16										
PbMEM	Memorial Hall	Room L102	Water Fountain	4	B	0.16	11/1/16										
PbMEM	Memorial Hall	Room 126	Sink	5	A	0.21	11/1/16										
PbMEM	Memorial Hall	Room 126	Sink	5	B	0.16	11/1/16										

Sample ID	Building	Room/Location	Sample Location	Sample No.	Draw	Result (ug/L)	Date	Draw	Result (ug/L)	Date	Draw	Result (ug/L)	Date	Draw	Result (ug/L)	Date	Notes
PbMIM	Mimosa Hall	Room 001MR	Backflow preventer	1	A	266	1/3/17										Although water tested at backflow preventer (where water first enters the building) shows a high concentation of lead, faucets throughout the buildings fall below the 15ppb threshold.
PbMIM	Mimosa Hall	Room 001MR	Backflow preventer	1	B	0.51	1/4/17										
PbMIM	Mimosa Hall	Room 117KN	Sink	2	A	3.7	1/5/17	C	0.16	3/13/17							
PbMIM	Mimosa Hall	Room 117KN	Sink	2	B	2.5	1/6/17	D	0.16	3/13/17							
PbMIM	Mimosa Hall	Room 119BA	Sink	4	A	0.2	1/6/17	C	0.16	3/13/17							
PbMIM	Mimosa Hall	Room 119BA	Sink	4	B	0.16	1/6/17	D	0.16	3/13/17							
PbMIM	Mimosa Hall	Room 121KN	Sink	5	A	2.4	1/6/17	C	0.16	3/13/17							
PbMIM	Mimosa Hall	Room 121KN	Sink	5	B	1.8	1/6/17	D	0.16	3/13/17							
PbMIM	Mimosa Hall	Room 122	Sink	6	A	5.7	1/6/17	C	0.16	3/13/17							
PbMIM	Mimosa Hall	Room 122	Sink	6	B	2	1/6/17	D	0.16	3/13/17							
PbMIM	Mimosa Hall	Room 123	Sink	7	A	5.8	1/6/17	C	0.16	3/13/17							
PbMIM	Mimosa Hall	Room 123	Sink	7	B	2.9	1/6/17	D	0.16	3/13/17							
PbMIM	Mimosa Hall	Room 125BA	Sink	8	A	52.5	1/6/17	C	0.16	3/13/17	E	1.8	7/28/17				
PbMIM	Mimosa Hall	Room 125BA	Sink	8	B	17	1/6/17	D	0.16	3/13/17	F	0.16	7/28/17				
PbMIM	Mimosa Hall	Room 128BA	Sink	9	B	0.55	1/6/17	C	0.16	3/13/17							
PbMIM	Mimosa Hall	Room 128BA	Sink	9	A	4.8	1/6/17	D	0.16	3/13/17							
PbMIM	Mimosa Hall	Room 101KN	Sink	10	A	13.6	1/6/17										
PbMIM	Mimosa Hall	Room 101KN	Sink	10	B	4.2	1/6/17										
PbMIM	Mimosa Hall	Room 109BA	Sink	12	A	11.9	1/6/17	C	0.16	3/13/17							
PbMIM	Mimosa Hall	Room 109BA	Sink	12	B	1.7	1/6/17	D	0.16	3/13/17							
PbMIM	Mimosa Hall	Room 107BA	Sink	13	A	4.3	1/6/17	C	0.16	3/13/17							
PbMIM	Mimosa Hall	Room 107BA	Sink	13	B	1.1	1/6/17	D	0.16	3/13/17							
PbMIM	Mimosa Hall	Room 104BA	Sink	14	A	4.5	1/6/17	C	0.16	3/13/17							
PbMIM	Mimosa Hall	Room 104BA	Sink	14	B	11.2	1/6/17	D	0.16	3/13/17							
PbMIM	Mimosa Hall	Room 101BA	Sink	15	A	3	1/6/17	C	0.16	3/13/17							
PbMIM	Mimosa Hall	Room 101BA	Sink	15	B	23	1/6/17	D	0.16	3/13/17							
PbMIM	Mimosa Hall	Room 110KN	Sink	16	A	65.2	1/6/17	C	4.8	7/27/17							
PbMIM	Mimosa Hall	Room 110KN	Sink	16	B	15.6	1/6/17	D	0.29	7/27/17							
PbMIM	Mimosa Hall	Room 112BA	Sink	17	A	1.9	1/6/17	C	0.16	3/13/17							
PbMIM	Mimosa Hall	Room 112BA	Sink	17	B	2	1/6/17	D	0.16	3/13/17							
PbMIM	Mimosa Hall	Room 114BA	Sink	18	A	6.4	1/6/17	C	0.16	3/13/17							
PbMIM	Mimosa Hall	Room 114BA	Sink	18	B	8.1	1/6/17	D	0.16	3/13/17							
PbMIM	Mimosa Hall	Room 227KN	Sink	19	A	22.1	1/6/17	C	3.4	7/27/17							
PbMIM	Mimosa Hall	Room 227KN	Sink	19	B	3.4	1/6/17	D	0.22	7/27/17							
PbMIM	Mimosa Hall	Room 228BA	Sink	20	A	3.3	1/6/17	C	0.16	3/13/17							
PbMIM	Mimosa Hall	Room 228BA	Sink	20	B	0.63	1/6/17	D	0.16	3/13/17							
PbMIM	Mimosa Hall	Room 233BA	Sink	21	A	5.4	1/6/17	C	0.16	3/13/17							
PbMIM	Mimosa Hall	Room 233BA	Sink	21	B	4	1/6/17	D	0.16	3/13/17							
PbMIM	Mimosa Hall	Room 236BA	Sink	22	A	19.6	1/6/17	C	0.16	3/13/17							
PbMIM	Mimosa Hall	Room 236BA	Sink	22	B	18.5	1/6/17	D	0.16	3/13/17							
PbMIM	Mimosa Hall	Room 238BA	Sink	23	A	4.7	1/6/17	C	0.16	3/13/17							
PbMIM	Mimosa Hall	Room 238BA	Sink	23	B	3.2	1/6/17	D	0.16	3/13/17							
PbMIM	Mimosa Hall	Room 240BA	Sink	24	A	5.2	1/6/17	C	0.16	3/13/17							
PbMIM	Mimosa Hall	Room 240BA	Sink	24	B	8.8	1/6/17	D	0.16	3/13/17							
PbMIM	Mimosa Hall	Room 242BA	Sink	25	A	247	1/6/17	C	0.16	3/13/17	E	3.9	7/28/17				
PbMIM	Mimosa Hall	Room 242BA	Sink	25	B	23.4	1/6/17	D	0.16	3/13/17	F	0.36	7/28/17				
PbMIM	Mimosa Hall	Room 245BA	Sink	26	A	3.5	1/6/17	C	0.16	3/13/17							
PbMIM	Mimosa Hall	Room 245BA	Sink	26	B	1.2	1/6/17	D	0.16	3/13/17							
PbMIM	Mimosa Hall	Room 226BA	Sink	27	A	6.6	1/6/17	C	0.16	3/13/17							
PbMIM	Mimosa Hall	Room 226BA	Sink	27	B	1.1	1/6/17	D	0.16	3/13/17							
PbMIM	Mimosa Hall	Room 221BA	Sink	28	A	1.7	1/6/17	C	0.16	3/13/17							
PbMIM	Mimosa Hall	Room 221BA	Sink	28	B	3.5	1/6/17	D	0.16	3/13/17							
PbMIM	Mimosa Hall	Room 211BA	Sink	29	A	4.2	1/6/17	C	0.16	3/13/17							
PbMIM	Mimosa Hall	Room 211BA	Sink	29	B	1.2	1/6/17	D	0.16	3/13/17							
PbMIM	Mimosa Hall	Room 200BA	Sink	30	A	2.4	1/6/17	C	0.16	3/13/17							

Sample ID	Building	Room/Location	Sample Location	Sample No.	Draw	Result (ug/L)	Date	Draw	Result (ug/L)	Date	Draw	Result (ug/L)	Date	Draw	Result (ug/L)	Date	Notes
PbMIM	Mimosa Hall	Room 200BA	Sink	30	B	2	1/6/17	D	0.16	3/13/17							
PbMIM	Mimosa Hall	Room 203BA	Sink	31	A	1.9	1/6/17	C	0.16	3/13/17							
PbMIM	Mimosa Hall	Room 203BA	Sink	31	B	27.8	1/6/17	D	0.16	3/13/17							
PbMIM	Mimosa Hall	Room 201BA	Sink	32	A	6.2	1/6/17	C	0.16	3/13/17							
PbMIM	Mimosa Hall	Room 201BA	Sink	32	B	21.1	1/6/17	D	0.16	3/13/17							
PbMIM	Mimosa Hall	Room 213BA	Sink	33	A	7	1/6/17	C	0.16	3/13/17							
PbMIM	Mimosa Hall	Room 213BA	Sink	33	B	14.6	1/6/17	D	0.16	3/13/17							
PbMIM	Mimosa Hall	Room 216BA	Sink	34	A	2.7	1/6/17	C	0.16	3/13/17							
PbMIM	Mimosa Hall	Room 216BA	Sink	34	B	4.8	1/6/17	D	0.16	3/13/17							
PbMIM	Mimosa Hall	Room 219BA	Sink	35	B	8.1	1/6/17	C	0.16	3/13/17							
PbMIM	Mimosa Hall	Room 219BA	Sink	35	A	2.6	1/6/17	D	0.16	3/13/17							
PbMIM	Mimosa Hall	Room 327BA	Sink	36	A	11.3	1/6/17	C	0.16	3/13/17							
PbMIM	Mimosa Hall	Room 327BA	Sink	36	B	2	1/6/17	D	0.16	3/13/17							
PbMIM	Mimosa Hall	Room 331BA	Sink	37	A	1.9	1/6/17	C	0.16	3/13/17							
PbMIM	Mimosa Hall	Room 331BA	Sink	37	B	1.3	1/6/17	D	0.16	3/13/17							
PbMIM	Mimosa Hall	Room 334BA	Sink	38	A	2820	1/6/17	C	0.16	3/13/17	E	2.1	7/28/17				
PbMIM	Mimosa Hall	Room 334BA	Sink	38	B	6.6	1/6/17	D	0.16	3/13/17	F	0.16	7/28/17				
PbMIM	Mimosa Hall	Room 337BA	Sink	39	A	9.6	1/6/17	C	0.16	3/13/17							
PbMIM	Mimosa Hall	Room 337BA	Sink	39	B	13.6	1/6/17	D	0.16	3/13/17							
PbMIM	Mimosa Hall	Room 340BA	Sink	40	A	2.8	1/6/17	C	0.16	3/13/17							
PbMIM	Mimosa Hall	Room 340BA	Sink	40	B	4.1	1/6/17	D	0.16	3/13/17							
PbMIM	Mimosa Hall	Room 342BA	Sink	41	A	1.5	1/6/17	C	0.16	3/13/17							
PbMIM	Mimosa Hall	Room 342BA	Sink	41	B	1.7	1/6/17	D	0.16	3/13/17							
PbMIM	Mimosa Hall	Room 344BA	Sink	42	A	2.1	1/6/17	C	0.16	3/13/17							
PbMIM	Mimosa Hall	Room 344BA	Sink	42	B	2.6	1/6/17	D	0.16	3/13/17							
PbMIM	Mimosa Hall	Room 348BA	Sink	43	A	15.8	1/6/17	C	0.16	3/13/17							
PbMIM	Mimosa Hall	Room 348BA	Sink	43	B	1.1	1/6/17	D	0.16	3/13/17							
PbMIM	Mimosa Hall	Room 326BA	Sink	44	A	4	1/6/17	C	0.16	3/13/17							
PbMIM	Mimosa Hall	Room 326BA	Sink	44	B	2	1/6/17	D	0.16	3/13/17							
PbMIM	Mimosa Hall	Room 323BA	Sink	45	A	3.9	1/6/17	C	0.16	3/13/17							
PbMIM	Mimosa Hall	Room 323BA	Sink	45	B	4.5	1/6/17	D	0.16	3/13/17							
PbMIM	Mimosa Hall	Room 310BA	Sink	47	A	5.6	1/6/17	C	0.16	3/13/17							
PbMIM	Mimosa Hall	Room 310BA	Sink	47	B	2.9	1/6/17	D	0.16	3/13/17							
PbMIM	Mimosa Hall	Room 306BA	Sink	48	A	3.2	1/6/17	C	0.16	3/13/17							
PbMIM	Mimosa Hall	Room 306BA	Sink	48	B	1.9	1/6/17	D	0.16	3/13/17							
PbMIM	Mimosa Hall	Room 303BA	Sink	49	A	47.5	1/6/17	C	0.16	3/13/17	E	6.6	7/28/17				
PbMIM	Mimosa Hall	Room 303BA	Sink	49	B	41.8	1/6/17	D	0.16	3/13/17	F	0.17	7/28/17				
PbMIM	Mimosa Hall	Room 301BA	Sink	50	A	4.5	1/6/17	C	0.16	3/13/17							
PbMIM	Mimosa Hall	Room 301BA	Sink	50	B	39.3	1/6/17	D	0.16	3/13/17							
PbMIM	Mimosa Hall	Room 314BA	Sink	51	A	2.1	1/6/17	C	0.16	3/13/17							
PbMIM	Mimosa Hall	Room 314BA	Sink	51	B	7.7	1/6/17	D	0.16	3/13/17							
PbMIM	Mimosa Hall	Room 317BA	Sink	52	A	26.8	1/6/17	C	0.16	3/13/17	E	3	7/28/17				
PbMIM	Mimosa Hall	Room 317BA	Sink	52	B	2.6	1/6/17	D	0.16	3/13/17	F	0.16	7/28/17				
PbMIM	Mimosa Hall	Room 319BA	Sink	53	A	2.5	1/6/17	C	0.16	3/13/17							
PbMIM	Mimosa Hall	Room 319BA	Sink	53	B	5	1/6/17	D	0.16	3/13/17							
PbMIM	Mimosa Hall	Room 427BA	Sink	54	A	4.5	1/6/17	C	0.16	3/13/17							
PbMIM	Mimosa Hall	Room 427BA	Sink	54	B	0.71	1/6/17	D	0.16	3/13/17							
PbMIM	Mimosa Hall	Room 431BA	Sink	55	A	2.5	1/6/17	C	0.16	3/13/17							
PbMIM	Mimosa Hall	Room 431BA	Sink	55	B	0.77	1/6/17	D	0.16	3/13/17							
PbMIM	Mimosa Hall	Room 434BA	Sink	56	A	2.4	1/6/17	C	0.16	3/13/17							
PbMIM	Mimosa Hall	Room 434BA	Sink	56	B	0.66	1/6/17	D	0.16	3/13/17							
PbMIM	Mimosa Hall	Room 437BA	Sink	57	A	3.7	1/6/17	C	0.16	3/13/17							
PbMIM	Mimosa Hall	Room 437BA	Sink	57	B	2.6	1/6/17	D	0.16	3/13/17							
PbMIM	Mimosa Hall	Room 440BA	Sink	58	A	2.3	1/6/17	C	0.16	3/13/17							
PbMIM	Mimosa Hall	Room 440BA	Sink	58	B	6.5	1/6/17	D	0.16	3/13/17							
PbMIM	Mimosa Hall	Room 442BA	Sink	59	A	5.8	1/6/17	C	0.16	3/13/17							
PbMIM	Mimosa Hall	Room 442BA	Sink	59	B	28.9	1/6/17	D	0.16	3/13/17							

Sample ID	Building	Room/Location	Sample Location	Sample No.	Draw	Result (ug/L)	Date	Draw	Result (ug/L)	Date	Draw	Result (ug/L)	Date	Draw	Result (ug/L)	Date	Notes
PbMIM	Mimosa Hall	Room 445BA	Sink	60	A	4.1	1/6/17	C	0.16	3/13/17							
PbMIM	Mimosa Hall	Room 445BA	Sink	60	B	4.1	1/6/17	D	0.16	3/13/17							
PbMIM	Mimosa Hall	Room 447BA	Sink	61	B	3.1	1/6/17	C	0.16	3/13/17	E	1.8	7/28/17				
PbMIM	Mimosa Hall	Room 447BA	Sink	61	A	124	1/6/17	D	0.16	3/13/17	F	0.3	7/28/17				
PbMIM	Mimosa Hall	Room 426BA	Sink	62	A	7	1/6/17	C	0.16	3/13/17							
PbMIM	Mimosa Hall	Room 426BA	Sink	62	B	2.6	1/6/17	D	0.16	3/13/17							
PbMIM	Mimosa Hall	Room 422BA	Sink	63	A	3.6	1/6/17	C	0.16	3/13/17							
PbMIM	Mimosa Hall	Room 422BA	Sink	63	B	5.2	1/6/17	D	0.16	3/13/17							
PbMIM	Mimosa Hall	Room 410BA	Sink	65	A	4.3	1/6/17	C	0.16	3/13/17							
PbMIM	Mimosa Hall	Room 410BA	Sink	65	B	2.1	1/6/17	D	0.16	3/13/17							
PbMIM	Mimosa Hall	Room 405BA	Sink	66	A	10.3	1/6/17	C	0.16	3/13/17							
PbMIM	Mimosa Hall	Room 405BA	Sink	66	B	4.6	1/6/17	D	0.16	3/13/17							
PbMIM	Mimosa Hall	Room 403BA	Sink	67	A	23.5	1/6/17	C	0.16	3/13/17							
PbMIM	Mimosa Hall	Room 403BA	Sink	67	B	13.6	1/6/17	D	0.16	3/13/17							
PbMIM	Mimosa Hall	Room 401BA	Sink	68	A	1.8	1/6/17	C	0.16	3/13/17							
PbMIM	Mimosa Hall	Room 401BA	Sink	68	B	25.5	1/6/17	D	0.16	3/13/17							
PbMIM	Mimosa Hall	Room 413BA	Sink	69	A	3.2	1/6/17	C	0.16	3/13/17							
PbMIM	Mimosa Hall	Room 413BA	Sink	69	B	6.4	1/6/17	D	0.16	3/13/17							
PbMIM	Mimosa Hall	Room 415BA	Sink	70	A	8.8	1/6/17	C	0.16	3/13/17							
PbMIM	Mimosa Hall	Room 415BA	Sink	70	B	9.4	1/6/17	D	0.16	3/13/17							
PbMIM	Mimosa Hall	Room 418BA	Sink	71	A	3.2	1/6/17	C	0.16	3/13/17							
PbMIM	Mimosa Hall	Room 418BA	Sink	71	B	2.1	1/6/17	D	0.16	3/13/17							
PbMUL	Mullica Hall	Room 121BA	Sink	2	A	17	1/5/17	C	0.16	3/13/17							
PbMUL	Mullica Hall	Room 121BA	Sink	2	B	17.1	1/5/17	D	0.16	3/13/17							
PbMUL	Mullica Hall	Room 124BA	Sink	3	A	15.5	1/5/17	C	0.16	3/13/17							
PbMUL	Mullica Hall	Room 124BA	Sink	3	B	3.8	1/5/17	D	0.16	3/13/17							
PbMUL	Mullica Hall	Room 127BA	Sink	4	A	8.8	1/5/17	C	0.16	3/13/17							
PbMUL	Mullica Hall	Room 127BA	Sink	4	B	2.7	1/5/17	D	0.16	3/13/17							
PbMUL	Mullica Hall	Room 131BA	Sink	5	A	14.5	1/5/17	C	0.16	3/13/17							
PbMUL	Mullica Hall	Room 131BA	Sink	5	B	115	1/5/17	D	0.16	3/13/17							
PbMUL	Mullica Hall	Room 134BA	Sink	6	A	14.6	1/5/17	C	0.16	3/13/17							
PbMUL	Mullica Hall	Room 134BA	Sink	6	B	4.1	1/5/17	D	0.16	3/13/17							
PbMUL	Mullica Hall	Room 202BA	Sink	7	A	5.1	1/5/17	C	0.16	3/13/17							
PbMUL	Mullica Hall	Room 202BA	Sink	7	B	3.1	1/5/17	D	0.16	3/13/17							
PbMUL	Mullica Hall	Room 206BA	Sink	8	A	8.4	1/5/17	C	0.16	3/13/17							
PbMUL	Mullica Hall	Room 206BA	Sink	8	B	11.6	1/5/17	D	0.16	3/13/17							
PbMUL	Mullica Hall	Room 209BA	Sink	9	B	1.8	1/5/17	C	0.16	3/13/17							
PbMUL	Mullica Hall	Room 209BA	Sink	9	A	3.9	1/5/17	D	0.16	3/13/17							
PbMUL	Mullica Hall	Room 214BA	Sink	10	A	8.4	1/5/17	C	0.16	3/13/17							
PbMUL	Mullica Hall	Room 214BA	Sink	10	B	3.2	1/5/17	D	0.16	3/13/17							
PbMUL	Mullica Hall	Room 217BA	Sink	11	A	927	1/5/17	C	0.16	3/13/17	E	9.1	7/28/17				
PbMUL	Mullica Hall	Room 217BA	Sink	11	B	32	1/5/17	D	0.16	3/13/17	F	1.1	7/28/17				
PbMUL	Mullica Hall	Room 221BA	Sink	12	A	6	1/5/17	C	0.16	3/13/17							
PbMUL	Mullica Hall	Room 221BA	Sink	12	B	14.7	1/5/17	D	0.16	3/13/17							
PbMUL	Mullica Hall	Room 224BA	Sink	13	A	2.9	1/5/17	C	0.16	3/13/17							
PbMUL	Mullica Hall	Room 224BA	Sink	13	B	5.7	1/5/17	D	0.16	3/13/17							
PbMUL	Mullica Hall	Room 227BA	Sink	14	A	88.7	1/5/17	C	0.16	3/13/17							
PbMUL	Mullica Hall	Room 227BA	Sink	14	B	8.5	1/5/17	D	0.16	3/13/17							
PbMUL	Mullica Hall	Room 231BA	Sink	15	A	64.5	1/5/17	C	0.16	3/13/17							
PbMUL	Mullica Hall	Room 231BA	Sink	15	B	3.6	1/5/17	D	0.16	3/13/17							
PbMUL	Mullica Hall	Room 234BA	Sink	16	A	7.4	1/5/17	C	0.16	3/13/17							
PbMUL	Mullica Hall	Room 234BA	Sink	16	B	2.6	1/5/17	D	0.16	3/13/17							
PbMUL	Mullica Hall	Room 302BA	Sink	17	A	11.9	1/5/17	C	0.16	3/13/17							
PbMUL	Mullica Hall	Room 302BA	Sink	17	B	4.1	1/5/17	D	0.16	3/13/17							
PbMUL	Mullica Hall	Room 306BA	Sink	18	A	22.8	1/5/17	C	0.16	3/13/17							
PbMUL	Mullica Hall	Room 306BA	Sink	18	B	8.1	1/5/17	D	0.16	3/13/17							

Sample ID	Building	Room/Location	Sample Location	Sample No.	Draw	Result (ug/L)	Date	Draw	Result (ug/L)	Date	Draw	Result (ug/L)	Date	Draw	Result (ug/L)	Date	Notes
PbMUL	Mullica Hall	Room 309BA	Sink	19	A	9.7	1/5/17	C	0.16	3/13/17							
PbMUL	Mullica Hall	Room 309BA	Sink	19	B	2.6	1/5/17	D	0.16	3/13/17							
PbMUL	Mullica Hall	Room 314BA	Sink	20	A	53.9	1/5/17	C	0.16	3/13/17							
PbMUL	Mullica Hall	Room 314BA	Sink	20	B	2.8	1/5/17	D	0.16	3/13/17							
PbMUL	Mullica Hall	Room 317BA	Sink	21	A	77.6	1/5/17	C	0.16	3/13/17	E	2.2	7/28/17				
PbMUL	Mullica Hall	Room 317BA	Sink	21	B	3.4	1/5/17	D	0.16	3/13/17	F	0.85	7/28/17				
PbMUL	Mullica Hall	Room 321BA	Sink	22	A	6.3	1/5/17	C	0.16	3/13/17							
PbMUL	Mullica Hall	Room 321BA	Sink	22	B	22	1/5/17	D	0.16	3/13/17							
PbMUL	Mullica Hall	Room 324BA	Sink	23	A	12.3	1/5/17	C	0.16	3/13/17							
PbMUL	Mullica Hall	Room 324BA	Sink	23	B	2.7	1/5/17	D	0.16	3/13/17							
PbMUL	Mullica Hall	Room 327BA	Sink	24	A	1180	1/5/17	C	0.16	3/13/17							
PbMUL	Mullica Hall	Room 327BA	Sink	24	B	1480	1/5/17	D	0.16	3/13/17							
PbMUL	Mullica Hall	Room 331BA	Sink	25	A	11.1	1/5/17	C	0.16	3/13/17							
PbMUL	Mullica Hall	Room 331BA	Sink	25	B	2.7	1/5/17	D	0.16	3/13/17							
PbMUL	Mullica Hall	Room 334BA	Sink	26	A	16	1/5/17	C	0.16	3/13/17							
PbMUL	Mullica Hall	Room 334BA	Sink	26	B	2.7	1/5/17	D	0.16	3/13/17							
PbMUL	Mullica Hall	Room 100KN	Sink	27	A	1450	1/5/17	C	0.16	3/13/17							
PbMUL	Mullica Hall	Room 100KN	Sink	27	B	59.7	1/5/17	D	0.16	3/13/17							
PbMUL	Mullica Hall	Room 102BA	Sink	28	A	12.5	1/5/17	C	0.16	3/13/17							
PbMUL	Mullica Hall	Room 102BA	Sink	28	B	2.4	1/5/17	D	0.16	3/13/17							
PbMUL	Mullica Hall	Room 104BA	Sink	29	A	357	1/5/17	C	6.6	7/27/17	E	4.5	7/28/17				
PbMUL	Mullica Hall	Room 104BA	Sink	29	B	21.1	1/5/17	D	1.7	7/27/17	F	1.9	7/28/17				
PbMUL	Mullica Hall	Room 106KN	Sink	30	A	27.6	1/5/17	C	0.16	3/13/17							
PbMUL	Mullica Hall	Room 106KN	Sink	30	B	17.1	1/5/17	D	0.16	3/13/17							
PbMUL	Mullica Hall	Room 109BA	Sink	31	A	5.1	1/5/17	C	0.16	3/13/17							
PbMUL	Mullica Hall	Room 109BA	Sink	31	B	2.4	1/5/17	D	0.16	3/13/17							
PbMUL	Mullica Hall	Room 114BA	Sink	32	A	6	1/5/17	C	0.16	3/13/17							
PbMUL	Mullica Hall	Room 114BA	Sink	32	B	2.3	1/5/17	D	0.16	3/13/17							
PbMUL	Mullica Hall	Room 119KN	Sink	33	A	584	1/5/17	C	0.16	3/13/17	E	2.6	7/28/17				
PbMUL	Mullica Hall	Room 119KN	Sink	33	B	2.2	1/5/17	D	0.16	3/13/17	F	0.24	7/28/17				
PbMUL	Mullica Hall	Room 103KN	Sink	34	A	2	1/5/17										
PbMUL	Mullica Hall	Room 103KN	Sink	34	B	3.6	1/5/17										
PbOAK	Oak Hall	Room 001	Backflow preventer	1	A	61.2	1/4/17										Although water tested at backflow preventer (where water first enters the building) shows a high concentation of lead, faucets throughout the buildings fall below the 15ppb threshold.
PbOAK	Oak Hall	Room 001	Backflow preventer	1	B	13	1/4/17										
PbOAK	Oak Hall	Room 103BA	Sink	2	A	1.4	1/4/17										
PbOAK	Oak Hall	Room 103BA	Sink	2	B	0.76	1/4/17										
PbOAK	Oak Hall	Room 104BA	Sink	3	A	3.6	1/4/17										
PbOAK	Oak Hall	Room 104BA	Sink	3	B	1.2	1/4/17										
PbOAK	Oak Hall	Room 113BA	Sink	4	A	3.1	1/4/17										
PbOAK	Oak Hall	Room 113BA	Sink	4	B	11.2	1/4/17										
PbOAK	Oak Hall	Room 117BA	Sink	5	A	7.1	1/4/17										
PbOAK	Oak Hall	Room 117BA	Sink	5	B	10	1/4/17										
PbOAK	Oak Hall	Room 118BA	Sink	6	A	3.1	1/4/17	C	0.18	2/28/17	E	4.6	7/28/17				
PbOAK	Oak Hall	Room 118BA	Sink	6	B	78.2	1/4/17	D	0.16	2/28/17	F	0.4	7/28/17				
PbOAK	Oak Hall	Room 119LA	Water Fountain	7	A	0.16	1/4/17										
PbOAK	Oak Hall	Room 119LA	Water Fountain	7	B	0.16	1/4/17										
PbOAK	Oak Hall	Room 119LA	Water Fountain	7	C	0.16	1/4/17										
PbOAK	Oak Hall	Room 119LA	Water Fountain	7	D	0.16	1/4/17										
PbOAK	Oak Hall	Room 219BA	Sink	8	A	4.6	1/4/17										
PbOAK	Oak Hall	Room 219BA	Sink	8	B	1.5	1/4/17										
PbOAK	Oak Hall	Room 213BA	Sink	9	B	10.2	1/4/17	C	7	7/28/17							
PbOAK	Oak Hall	Room 213BA	Sink	9	A	1.2	1/4/17	D	0.63	7/28/17							
PbOAK	Oak Hall	Room 211	Water Fountain	10	A	73.2	1/4/17	C	0.16	7/27/17							
PbOAK	Oak Hall	Room 211	Water Fountain	10	B	6.5	1/4/17	D	0.16	7/27/17							

Sample ID	Building	Room/Location	Sample Location	Sample No.	Draw	Result (ug/L)	Date	Draw	Result (ug/L)	Date	Draw	Result (ug/L)	Date	Draw	Result (ug/L)	Date	Notes
PbOAK	Oak Hall	Room 309	Water Fountain	11	A	30.6	1/4/17	C	0.16	7/27/17							
PbOAK	Oak Hall	Room 309	Water Fountain	11	B	4.5	1/4/17	D	0.16	7/27/17							
PbOAK	Oak Hall	Room 309BH	Sink	12	A	7.9	1/4/17										
PbOAK	Oak Hall	Room 309BH	Sink	12	B	3.9	1/4/17										
PbOAK	Oak Hall	Room 310BA	Sink	13	A	1.8	1/4/17										
PbOAK	Oak Hall	Room 310BA	Sink	13	B	1.8	1/4/17										
PbOAK	Oak Hall	Room 308BA	Sink	14	A	1.5	1/4/17	C	0.16	2/28/17							
PbOAK	Oak Hall	Room 308BA	Sink	14	B	38.6	1/4/17	D	0.16	2/28/17							
PbOAK	Oak Hall	Room 210	Water Fountain	15	A	0.16	1/4/17										
PbOAK	Oak Hall	Room 210	Water Fountain	15	B	0.16	1/4/17										
PbOAK	Oak Hall	Room 210	Water Fountain	15	C	0.16	1/4/17										
PbOAK	Oak Hall	Room 210	Water Fountain	15	D	0.16	1/4/17										
PbOAK	Oak Hall	Room 202BA	Sink	16	A	2.2	1/4/17										
PbOAK	Oak Hall	Room 202BA	Sink	16	B	1.7	1/4/17										
PbOAK	Oak Hall	Room 303BA	Sink	17	A	3.2	1/4/17										
PbOAK	Oak Hall	Room 303BA	Sink	17	B	3.4	1/4/17										
PbOAK	Oak Hall	Room 304BA	Sink	18	A	43.4	1/4/17	C	0.16	2/28/17	E	3.1	7/28/17				
PbOAK	Oak Hall	Room 304BA	Sink	18	B	43.2	1/4/17	D	0.16	2/28/17	F	0.19	7/28/17				
PbOAK	Oak Hall	Room 305	Water Fountain	19	A	6.3	1/4/17	C	0.16	7/27/17							
PbOAK	Oak Hall	Room 305	Water Fountain	19	B	17.1	1/4/17	D	0.16	7/27/17							
PbOAK	Oak Hall	Room 108BA	Sink	20	A	2	1/4/17										
PbOAK	Oak Hall	Room 108BA	Sink	20	B	2	1/4/17										
PbOAK	Oak Hall	Room 108BA	Water Fountain	21	A	0.16	1/4/17										
PbOAK	Oak Hall	Room 108BA	Water Fountain	21	B	0.16	1/4/17										
PbOAK	Oak Hall	Room 102	Water Fountain	22	A	0.16	1/4/17	A		2/23/17							
PbOAK	Oak Hall	Room 102	Water Fountain	22	B	0.16	1/4/17	B		2/23/17							
PbREC	Recreation Center	Room 003A	Sink	2	A	0.56	11/25/16										
PbREC	Recreation Center	Room 003A	Sink	2	B	0.16	11/25/16										
PbREC	Recreation Center	Room H001	Water Fountain	3	A	0.16	11/25/16										
PbREC	Recreation Center	Room H001	Water Fountain	3	B	0.16	11/25/16										
PbREC	Recreation Center	Room L102	Water Fountain	4	A	0.16	11/25/16										
PbREC	Recreation Center	Room L102	Water Fountain	4	B	0.16	11/25/16										
PbREC	Recreation Center	Room 123	Sink	5	A	1.7	11/25/16										
PbREC	Recreation Center	Room 123	Sink	5	B	0.55	11/25/16										
PbREC	Recreation Center	Room 135	Water Fountain	6	A	0.16	11/25/16										
PbREC	Recreation Center	Room 135	Water Fountain	6	B	0.16	11/25/16										
PbREC	Recreation Center	Room 109	Water Fountain	7	A	0.16	11/25/16										
PbREC	Recreation Center	Room 109	Water Fountain	7	B	0.3	11/25/16										
PbREC	Recreation Center	Room 107A	Sink	9	B	0.61	11/25/16										
PbREC	Recreation Center	Room 107A	Sink	9	A	8.4	11/25/16										
PbREC	Recreation Center	Room 102	Sink	10	A	2.5	11/25/16										
PbREC	Recreation Center	Room 102	Sink	10	B	0.27	11/25/16										
PbREC	Recreation Center	Room 102	Sink	11	A	0.21	11/25/16										
PbREC	Recreation Center	Room 102	Sink	11	B	0.2	11/25/16										
PbREC	Recreation Center	Room 102	Ice Machine	12	A	5.3	11/25/16										
PbREC	Recreation Center	Room 102	Ice Machine	12	B	0.32	11/25/16										
PbREC	Recreation Center	Room 132	Water Fountain	13	A	0.16	11/25/16										
PbREC	Recreation Center	Room 132	Water Fountain	13	B	0.16	11/25/16										
PbREC	Recreation Center	Room 128	Water Fountain	14	A	0.16	11/25/16										
PbREC	Recreation Center	Room 128	Water Fountain	14	B	0.16	11/25/16										
PbREC	Recreation Center	Room 201	Water Fountain	15	A	0.16	11/25/16										
PbREC	Recreation Center	Room 201	Water Fountain	15	B	0.16	11/25/16										
PbREC	Recreation Center	Room H200	Water Fountain	16	A	0.16	11/25/16										
PbREC	Recreation Center	Room H200	Water Fountain	16	B	0.16	11/25/16										
PbROB	Robinson Hall	Room L102	Sink	2	A	0.39	11/8/16										

Sample ID	Building	Room/Location	Sample Location	Sample No.	Draw	Result (ug/L)	Date	Draw	Result (ug/L)	Date	Draw	Result (ug/L)	Date	Draw	Result (ug/L)	Date	Notes
PbROB	Robinson Hall	Room L102	Sink	2	B	1.1	11/8/16										
PbROB	Robinson Hall	Room L102	Coffee Pot	3	A	0.35	11/8/16										
PbROB	Robinson Hall	Room L102	Coffee Pot	3	B	0.19	11/8/16										
PbROB	Robinson Hall	Room H101	Water Fountain	4	A	0.45	11/8/16										
PbROB	Robinson Hall	Room H101	Water Fountain	4	B	0.51	11/8/16										
PbROB	Robinson Hall	Room 100A	Sink	5	A	5.8	11/8/16										
PbROB	Robinson Hall	Room 100A	Sink	5	B	2.2	11/8/16										
PbROB	Robinson Hall	Room 215B	Water Fountain	6	A	0.12	11/8/16										
PbROB	Robinson Hall	Room 215B	Water Fountain	6	B	0.09	11/8/16										
PbROB	Robinson Hall	Room 315B	Water Fountain	7	A	0.11	11/8/16										
PbROB	Robinson Hall	Room 315B	Water Fountain	7	B	0.09	11/8/16										
PbROT	ROTC House	Kitchen	Sink	2	A	12.9	11/8/17	C	0.19	4/27/17							
PbROT	ROTC House	Kitchen	Sink	2	B	6	11/8/17	D	0.16	4/27/17							
PbROW	Rowan Hall	Room 109	Sink	2	A	0.09	11/10/16										
PbROW	Rowan Hall	Room 109	Sink	2	B	0.09	11/10/16										
PbROW	Rowan Hall	Room 109	Water Dispenser	3	A	0.11	11/10/16										
PbROW	Rowan Hall	Room 109	Water Dispenser	3	B	0.12	11/10/16										
PbROW	Rowan Hall	Room H225	Water Fountain	4	A	0.77	11/10/16										
PbROW	Rowan Hall	Room H225	Water Fountain	4	B	0.09	11/10/16										
PbROW	Rowan Hall	Room 210	Sink	5	A	0.41	11/10/16										
PbROW	Rowan Hall	Room 210	Sink	5	B	0.41	11/10/16										
PbROW	Rowan Hall	Room H320	Water Fountain	6	A	1.5	11/10/16										
PbROW	Rowan Hall	Room H320	Water Fountain	6	B	0.37	11/10/16										
PbROW	Rowan Hall	Room 310	Sink	7	A	0.78	11/10/16										
PbROW	Rowan Hall	Room 310	Sink	7	B	0.22	11/10/16										
PbROW	Rowan Hall	Room H131	Water Fountain	8	A	0.09	11/10/16										
PbROW	Rowan Hall	Room H131	Water Fountain	8	B	0.09	11/10/16										
PbSAV	Savitz Hall	Room 147	Water Fountain	2	A	0.16	11/3/16										
PbSAV	Savitz Hall	Room 147	Water Fountain	2	B	0.16	11/3/16										
PbSAV	Savitz Hall	Room 215	Water Fountain	3	A	0.16	11/3/16										
PbSAV	Savitz Hall	Room 215	Water Fountain	3	B	0.16	11/3/16										
PbSAV	Savitz Hall	Room 237	Sink	4	A	0.26	11/3/16										
PbSAV	Savitz Hall	Room 237	Sink	4	B	0.33	11/3/16										
PbSAV	Savitz Hall	Room 253	Water Fountain	5	A	0.16	11/3/16										
PbSAV	Savitz Hall	Room 253	Water Fountain	5	B	0.16	11/3/16										
PbSAV	Savitz Hall	Room 322	Sink	6	A	0.16	11/3/16										
PbSAV	Savitz Hall	Room 322	Sink	6	B	0.16	11/3/16										
PbSAV	Savitz Hall	Room 357	Water Fountain	7	A	0.16	11/3/16										
PbSAV	Savitz Hall	Room 357	Water Fountain	7	B	0.16	11/3/16										
PbSC	Student Center	Room G20	Backflow preventer	1	A	427	12/23/16	C	382	2/23/17							Although water tested at backflow preventer (where water first enters the building) shows a high concentation of lead, faucets throughout the buildings fall below the 15ppb threshold.
PbSC	Student Center	Room G20	Backflow preventer	1	B	57.6	12/23/16	D	4.1	2/23/17							
PbSC	Student Center	Room H001 by G18	Water Fountain	2	A	0.16	12/23/16										
PbSC	Student Center	Room H001 by G18	Water Fountain	2	B	0.16	12/23/16										
PbSC	Student Center	Room H002 by 16C	Sink	3	A	2.3	12/23/16	C	15.3	7/27/17	E	4.7	8/16/17				
PbSC	Student Center	Room H002 by 16C	Sink	3	B	34.1	12/23/16	D	0.93	7/27/17	F	0.22	8/16/17				
PbSC	Student Center	Room H002	Sink	4	A	6.2	12/23/16										
PbSC	Student Center	Room H002	Sink	4	B	2.6	12/23/16										
PbSC	Student Center	Room 016A	Water Dispenser	5	A	13.4	12/23/16										
PbSC	Student Center	Room 016A	Water Dispenser	5	B	3.2	12/23/16										
PbSC	Student Center	Room 016F	Sink	6	A	1.3	12/23/16	C	7.8	7/27/17							
PbSC	Student Center	Room 016F	Sink	6	B	91.7	12/23/16	D	1	7/27/17							

Sample ID	Building	Room/Location	Sample Location	Sample No.	Draw	Result (ug/L)	Date	Draw	Result (ug/L)	Date	Draw	Result (ug/L)	Date	Draw	Result (ug/L)	Date	Notes
PbSC	Student Center	Room 001	Sink	7	A	3.7	12/23/16										
PbSC	Student Center	Room 001	Sink	7	B	20.5	12/23/16										Sink taken offline until a filter is installed.
PbSC	Student Center	Room 001	Coffe pot	8	A	0.16	12/23/16										
PbSC	Student Center	Room 001	Coffe pot	8	B	0.16	12/23/16										
PbSC	Student Center	Room 009E	Ice Machine	9	A	69.4	12/23/16	C	15.1	2/23/17	E	29.8	3/10/17	G	1	7/27/17	
PbSC	Student Center	Room 009E	Ice Machine	9	B	8	12/23/16	D	2.8	2/23/17	F	0.23	3/10/17	H	0.33	7/27/17	
PbSC	Student Center	Room 009C	Sink	10	A	17.5	12/23/16	C	0.16	7/27/17							
PbSC	Student Center	Room 009C	Sink	10	B	220	12/23/16	D	0.16	7/27/17							
PbSC	Student Center	Room 009	Water Dispenser	11	A	0.16	7/27/17										
PbSC	Student Center	Room 009	Water Dispenser	11	B	0.53	7/27/17										
PbSC	Student Center	Room 009	Water Dispenser	12	A	0.29	12/23/16										
PbSC	Student Center	Room 009	Water Dispenser	12	B	0.17	12/23/16										
PbSC	Student Center	Room 009A	Water Dispenser	13	A	0.25	12/23/16										
PbSC	Student Center	Room 009A	Water Dispenser	13	B	0.16	12/23/16										
PbSC	Student Center	Room 009A	Water Dispenser	14	A	0.16	12/23/16										
PbSC	Student Center	Room 009A	Water Dispenser	14	B	0.16	12/23/16										
PbSC	Student Center	Room 021	Coffe pot	15	A	0.16	12/23/16										
PbSC	Student Center	Room 021	Coffe pot	15	B	0.16	12/23/16										
PbSC	Student Center	Room H001 by 24	Water Fountain	17	A	28.8	12/23/16	C	0.16	7/27/17							
PbSC	Student Center	Room H001 by 24	Water Fountain	17	B	11.7	12/23/16	D	0.16	7/27/17							
PbSC	Student Center	Room W100	Starbucks Coffee Pot	18	A	0.16	12/23/16										
PbSC	Student Center	Room W100	Starbucks Coffee Pot	18	B	0.16	12/23/16										
PbSC	Student Center	Room W100	Starbucks Sink	19	A	33	12/23/16										Hand-washing sink only.
PbSC	Student Center	Room W100	Starbucks Sink	19	B	10.1	12/23/16										
PbSC	Student Center	Room W100	Starbucks Expresso	20	A	2.7	12/23/16										
PbSC	Student Center	Room W100	Starbucks Expresso	20	B	2.1	12/23/16										
PbSC	Student Center	Room H100 by 121	Water Fountain	21	A	0.16	12/23/16										
PbSC	Student Center	Room H100 by 121	Water Fountain	21	B	0.16	12/23/16										
PbSC	Student Center	Room H100 by 103	Water Fountain	22	A	6	12/23/16										
PbSC	Student Center	Room H100 by 103	Water Fountain	22	B	1.7	12/23/16										
PbSC	Student Center	Room H100 by 129B	Water Fountain	23	A	1.1	12/23/16										
PbSC	Student Center	Room H100 by129B	Water Fountain	23	B	0.53	12/23/16										
PbSC	Student Center	Room 146	Ice Machine	24	A	0.16	12/23/16										
PbSC	Student Center	Room 146	Ice Machine	24	B	0.16	12/23/16										
PbSC	Student Center	Adj. to above 146	Ice Machine	25	A	0.16	12/23/16										
PbSC	Student Center	Adj. to above 146	Ice Machine	25	B	0.16	12/23/16										
PbSC	Student Center	Room 146	Drink Machine	26	A	7.2	12/23/16										
PbSC	Student Center	Room 146	Drink Machine	26	B	0.47	12/23/16										
PbSC	Student Center	Room 146	Sink	27	A	118	12/23/16	C	4	2/23/17	E	2.2	7/28/17				
PbSC	Student Center	Room 146	Sink	27	B	3.6	12/23/16	D	0.58	2/23/17	F	3.2	7/28/17				
PbSC	Student Center	Room 146	Sink	28	A	18.2	12/23/16	C	2.5	2/7/17							
PbSC	Student Center	Room 146	Sink	28	B	1.7	12/23/16	D	0.21	2/7/17							
PbSC	Student Center	Room 146	Sink	29	A	32.9	12/23/16	C	1.8	2/7/17	E	0.16	7/27/17				
PbSC	Student Center	Room 146	Sink	29	B	6	12/23/16	D	0.16	2/7/17	F	0.16	7/27/17				
PbSC	Student Center	Room 146	Sink	30	A	10.6	12/23/16										
PbSC	Student Center	Room 146	Sink	30	B	11.6	12/23/16										
PbSC	Student Center	Room 146	Sink	31	A	2.2	12/23/16										
PbSC	Student Center	Room 146	Sink	31	B	0.89	12/23/16										
PbSC	Student Center	Room 146	Sink	32	A	36.9	12/23/16	C	1.1	3/10/17							
PbSC	Student Center	Room 146	Sink	32	B	3.8	12/23/16	D	0.16	3/10/17							
PbSC	Student Center	Room 146	Sink	33	A	12.3	12/23/16	C	208	3/10/17	E	0.71	7/27/17				
PbSC	Student Center	Room 146	Sink	33	B	9.4	12/23/16	D	2.3	3/10/17	F	0.23	7/27/17				
PbSC	Student Center	Room 146	Steam Kettle	34	A	6.8	12/23/16										
PbSC	Student Center	Room 146	Steam Kettle	34	B	0.37	12/23/16										
PbSC	Student Center	Room 146	Steam Kettle	35	A	7.4	12/23/16										
PbSC	Student Center	Room 146	Steam Kettle	35	B	0.74	12/23/16										
PbSC	Student Center	Room 146	Tilt Skillet	36	A	5.1	12/23/16										

Sample ID	Building	Room/Location	Sample Location	Sample No.	Draw	Result (ug/L)	Date	Draw	Result (ug/L)	Date	Draw	Result (ug/L)	Date	Draw	Result (ug/L)	Date	Notes
PbSC	Student Center	Room 146	Tilt Skillet	36	B	0.63	12/23/16										
PbSC	Student Center	Former Office/Sprout Station	Sink	37	A	3	12/23/16										
PbSC	Student Center	Former Office/Sprout Station	Sink	37	B	0.63	12/23/16										
PbSC	Student Center	Dish/Prep Area	Sink	38	A	2	12/23/16										
PbSC	Student Center	Dish/Prep Area	Sink	38	B	3.5	12/23/16										
PbSC	Student Center	Room 146	Water Fountain	39	A	0.16	12/23/16										
PbSC	Student Center	Room 146	Water Fountain	39	B	1.2	12/23/16										
PbSC	Student Center	Dining Room	Sink	40	A	0.53	12/23/16										
PbSC	Student Center	Dining Room	Sink	40	B	1.6	12/23/16										
PbSC	Student Center	Dining Room	Sink	42	A	1.8	12/23/16										
PbSC	Student Center	Dining Room	Sink	42	B	0.16	12/23/16										
PbSC	Student Center	Dining Room	Sink	43	A	0.68	12/23/16										
PbSC	Student Center	Dining Room	Sink	43	B	14.8	12/23/16										
PbSC	Student Center	H200 by 219	Water Fountain	44	A	0.16	12/23/16										
PbSC	Student Center	H200 by 219	Water Fountain	44	B	0.16	12/23/16										
PbSC	Student Center	H200 by 227	Water Fountain	46	A	389	12/23/16	C	12	2/7/17	E	8.5	7/28/17				
PbSC	Student Center	H200 by 227	Water Fountain	46	B	2.1	12/23/16	D	0.79	2/7/17	F	1.7	7/28/17				
PbSC	Student Center	Room 231	Sink	47	A	0.17	7/27/17										
PbSC	Student Center	Room 231	Sink	47	B	0.16	7/27/17										
PbSC	Student Center	Room 231	Water Dispenser	48	A	0.16	7/27/17										
PbSC	Student Center	Room 231	Water Dispenser	48	B	0.16	7/27/17										
PbSC	Student Center	Room 146	Sink	50	A	9.5	12/23/16										
PbSC	Student Center	Room 146	Sink	50	B	2.2	12/23/16										
PbSC	Student Center	Room 146	Sink	51	A	10.2	12/23/16										
PbSC	Student Center	Room 146	Sink	51	B	3.9	12/23/16										
PbSC	Student Center	Room 140	Bottle Fill	52	A	0.16	12/23/16										
PbSC	Student Center	Room 140	Bottle Fill	52	B	0.16	12/23/16										
PbSC	Student Center	Jersey Mike's	Prep Sink	53	A	4.8	3/10/17				E	3.6	7/27/17				
PbSC	Student Center	Jersey Mike's	Prep Sink	53	B	0.16	3/10/17				F	0.32	7/27/17				
PbSC	Student Center	Jersey Mike's	Prep Sink 2	54	A	0.26	7/27/17										
PbSC	Student Center	Jersey Mike's	Prep Sink 2	54	B	0.18	7/27/17										
PbSCI	Science Hall	Room H101 by 148	Water Fountain	2	A	0.1	11/10/16										
PbSCI	Science Hall	Room H101 by 148	Water Fountain	2	B	0.09	11/10/16										
PbSCI	Science Hall	Room 135	Sink	3	A	0.58	11/10/16										
PbSCI	Science Hall	Room 135	Sink	3	B	0.3	11/10/16										
PbSCI	Science Hall	Room 135	Water Dispenser	4	A	4	11/10/16										
PbSCI	Science Hall	Room 135	Water Dispenser	4	B	1.4	11/10/16										
PbSCI	Science Hall	Room 128	Water Dispenser	5	A	0.09	11/10/16										
PbSCI	Science Hall	Room 128	Water Dispenser	5	B	0.09	11/10/16										
PbSCI	Science Hall	Room 115	Water Fountain	6	A	0.28	11/10/16										
PbSCI	Science Hall	Room 115	Water Fountain	6	B	0.09	11/10/16										
PbSCI	Science Hall	Room 101L	Sink	7	A	0.48	11/10/16										
PbSCI	Science Hall	Room 101L	Sink	7	B	0.18	11/10/16										
PbSCI	Science Hall	Room 101L	Water Dispenser	8	A	3	11/10/16										
PbSCI	Science Hall	Room 101L	Water Dispenser	8	B	0.09	11/10/16										
PbSCI	Science Hall	Room 201M	Sink	9	B	0.34	11/10/16										
PbSCI	Science Hall	Room 201M	Sink	9	A	0.36	11/10/16										
PbSCI	Science Hall	Room 211	Water Fountain	10	A	0.15	11/10/16										
PbSCI	Science Hall	Room 211	Water Fountain	10	B	0.09	11/10/16										
PbSCI	Science Hall	Room 252	Water Fountain	11	A	0.12	11/10/16										
PbSCI	Science Hall	Room 252	Water Fountain	11	B	0.09	11/10/16										
PbSCI	Science Hall	Room 256G	Sink	12	A	0.39	11/10/16										
PbSCI	Science Hall	Room 256G	Sink	12	B	0.15	11/10/16										
PbSCI	Science Hall	Room 347	Sink	13	A	2	11/10/16										
PbSCI	Science Hall	Room 347	Sink	13	B	0.13	11/10/16										
PbSCI	Science Hall	Room 336	Water Fountain	14	A	0.2	11/10/16										

Sample ID	Building	Room/Location	Sample Location	Sample No.	Draw	Result (ug/L)	Date	Draw	Result (ug/L)	Date	Draw	Result (ug/L)	Date	Draw	Result (ug/L)	Date	Notes
PbSCI	Science Hall	Room 336	Water Fountain	14	B	0.09	11/10/16										
PbSCI	Science Hall	Room 329	Water Fountain	15	A	0.11	11/10/16										
PbSCI	Science Hall	Room 329	Water Fountain	15	B	0.093	11/10/16										
PbSCI	Science Hall	Room 311	Water Fountain	16	A	0.17	11/10/16										
PbSCI	Science Hall	Room 311	Water Fountain	16	B	0.09	11/10/16										
PbSCI	Science Hall	Room 301	Sink	17	A	0.28	11/10/16										
PbSCI	Science Hall	Room 301	Sink	17	B	0.38	11/10/16										
PbTWN	Townhouse Building 100	Apt 101	Kitchen Sink	1	A	0.16	3/18/17										
PbTWN	Townhouse Building 100	Apt 101	Kitchen Sink	1	B	0.16	3/18/17										
PbTWN	Townhouse Building 100	Apt 101	Bathroom Sink 2nd floor	2	A	0.16	3/16/17										
PbTWN	Townhouse Building 100	Apt 101	Bathroom Sink 2nd floor	2	B	0.16	3/16/17										
PbTWN	Townhouse Building 100	Apt 101	Bathroom Sink 3rd floor	3	A	0.16	3/16/17										
PbTWN	Townhouse Building 100	Apt 101	Bathroom Sink 3rd floor	3	B	0.16	3/16/17										
PbTWN	Townhouse Building 100	Apt 102	Kitchen Sink	1	A	0.16	3/18/17										
PbTWN	Townhouse Building 100	Apt 102	Kitchen Sink	1	B	0.16	3/18/17										
PbTWN	Townhouse Building 100	Apt 102	Bathroom Sink 2nd floor	2	A	0.16	3/16/17										
PbTWN	Townhouse Building 100	Apt 102	Bathroom Sink 2nd floor	2	B	0.16	3/16/17										
PbTWN	Townhouse Building 100	Apt 102	Bathroom Sink 3rd floor	3	A	0.16	3/16/17										
PbTWN	Townhouse Building 100	Apt 102	Bathroom Sink 3rd floor	3	B	0.16	3/16/17										
PbTWN	Townhouse Building 100	Apt 103	Kitchen Sink	2	A	1.3	1/4/17										
PbTWN	Townhouse Building 100	Apt 103	Kitchen Sink	2	B	6.8	1/4/17										
PbTWN	Townhouse Building 100	Apt 103	Kitchen Sink	1	A	0.16	3/18/17										
PbTWN	Townhouse Building 100	Apt 103	Kitchen Sink	1	B	0.16	3/18/17										
PbTWN	Townhouse Building 100	Apt 103	Bathroom Sink 2nd floor	2	A	0.16	3/16/17										
PbTWN	Townhouse Building 100	Apt 103	Bathroom Sink 2nd floor	2	B	0.16	3/16/17										
PbTWN	Townhouse Building 100	Apt 103	Bathroom Sink 3rd floor	3	A	0.16	3/16/17	C	4.2	8/1/17							
PbTWN	Townhouse Building 100	Apt 103	Bathroom Sink 3rd floor	3	B	0.16	3/16/17	D	0.79	8/1/17							
PbTWN	Townhouse Building 100	Apt 104	Kitchen Sink	1	A	0.16	3/18/17										
PbTWN	Townhouse Building 100	Apt 104	Kitchen Sink	1	B	0.16	3/18/17										
PbTWN	Townhouse Building 100	Apt 104	Bathroom Sink 2nd floor	2	A	0.16	3/16/17	C	0.95	8/1/17							
PbTWN	Townhouse Building 100	Apt 104	Bathroom Sink 2nd floor	2	B	0.16	3/16/17	D	0.16	8/1/17							
PbTWN	Townhouse Building 100	Apt 104	Bathroom Sink 3rd floor	3	A	0.16	3/16/17										
PbTWN	Townhouse Building 100	Apt 104	Bathroom Sink 3rd floor	3	B	0.16	3/16/17										
PbTWN	Townhouse Building 100	Apt 105	Kitchen Sink	1	A	0.16	3/18/17										
PbTWN	Townhouse Building 100	Apt 105	Kitchen Sink	1	B	0.16	3/18/17										
PbTWN	Townhouse Building 100	Apt 105	Bathroom Sink 2nd floor	2	A	0.16	3/16/17										
PbTWN	Townhouse Building 100	Apt 105	Bathroom Sink 2nd floor	2	B	0.16	3/16/17										
PbTWN	Townhouse Building 100	Apt 105	Bathroom Sink 3rd floor	3	A	0.16	3/16/17										
PbTWN	Townhouse Building 100	Apt 105	Bathroom Sink 3rd floor	3	B	0.16	3/16/17										
PbTWN	Townhouse Building 100	Apt 106	Kitchen Sink	1	A	0.16	3/18/17										
PbTWN	Townhouse Building 100	Apt 106	Kitchen Sink	1	B	0.16	3/18/17										
PbTWN	Townhouse Building 100	Apt 106	Bathroom Sink 2nd floor	2	A	0.16	3/16/17										
PbTWN	Townhouse Building 100	Apt 106	Bathroom Sink 2nd floor	2	B	0.16	3/16/17										
PbTWN	Townhouse Building 100	Apt 106	Bathroom Sink 3rd floor	3	A	0.16	3/16/17										
PbTWN	Townhouse Building 100	Apt 106	Bathroom Sink 3rd floor	3	B	0.16	3/16/17										
PbTWN	Townhouse Building 100	Apt 107	Kitchen Sink	1	A	0.16	3/18/17										
PbTWN	Townhouse Building 100	Apt 107	Kitchen Sink	1	B	0.16	3/18/17										
PbTWN	Townhouse Building 100	Apt 107	Bathroom Sink 2nd floor	2	A	0.16	3/16/17										
PbTWN	Townhouse Building 100	Apt 107	Bathroom Sink 2nd floor	2	B	0.16	3/16/17										
PbTWN	Townhouse Building 100	Apt 107	Bathroom Sink 3rd floor	3	A	0.16	3/16/17										
PbTWN	Townhouse Building 100	Apt 107	Bathroom Sink 3rd floor	3	B	0.16	3/16/17										
PbTWN	Townhouse Building 100	Apt 108	Kitchen Sink	1	A	0.16	3/18/17	C	1.1	8/1/17							
PbTWN	Townhouse Building 100	Apt 108	Kitchen Sink	1	B	0.16	3/18/17	D	1	8/1/17							
PbTWN	Townhouse Building 100	Apt 108	Bathroom Sink 2nd floor	2	A	0.16	3/16/17										
PbTWN	Townhouse Building 100	Apt 108	Bathroom Sink 2nd floor	2	B	0.16	3/16/17										
PbTWN	Townhouse Building 100	Apt 108	Bathroom Sink 3rd floor	3	A	0.16	3/16/17										

Sample ID	Building	Room/Location	Sample Location	Sample No.	Draw	Result (ug/L)	Date	Draw	Result (ug/L)	Date	Draw	Result (ug/L)	Date	Draw	Result (ug/L)	Date	Notes
PbTWN	Townhouse Building 100	Apt 108	Bathroom Sink 3rd floor	3	B	0.16	3/16/17										
PbTWN	Townhouse Building 200	Apt 201KN	Sink	2	A	2.2	1/4/17										
PbTWN	Townhouse Building 200	Apt 201KN	Sink	2	B	5	1/4/17										
PbTWN	Townhouse Building 200	Apt 201	Kitchen Sink	1	A	0.16	3/18/17	C	1.7	8/1/17							
PbTWN	Townhouse Building 200	Apt 201	Kitchen Sink	1	B	0.16	3/18/17	D	0.2	8/1/17							
PbTWN	Townhouse Building 200	Apt 202	Bathroom Sink 2nd floor	2	A	0.16	3/16/17										
PbTWN	Townhouse Building 200	Apt 202	Bathroom Sink 2nd floor	2	B	0.16	3/16/17										
PbTWN	Townhouse Building 200	Apt 202	Bathroom Sink 3rd floor	3	A	0.16	3/16/17										
PbTWN	Townhouse Building 200	Apt 202	Bathroom Sink 3rd floor	3	B	0.16	3/16/17										
PbTWN	Townhouse Building 200	Apt 202	Kitchen Sink	1	A	0.16	3/18/17										
PbTWN	Townhouse Building 200	Apt 202	Kitchen Sink	1	B	0.16	3/18/17										
PbTWN	Townhouse Building 200	Apt 202	Bathroom Sink 2nd floor	2	A	0.16	3/16/17										
PbTWN	Townhouse Building 200	Apt 202	Bathroom Sink 2nd floor	2	B	0.16	3/16/17										
PbTWN	Townhouse Building 200	Apt 202	Bathroom Sink 3rd floor	3	A	0.16	3/16/17										
PbTWN	Townhouse Building 200	Apt 202	Bathroom Sink 3rd floor	3	B	0.16	3/16/17										
PbTWN	Townhouse Building 200	Apt 203	Kitchen Sink	1	A	0.16	3/18/17										
PbTWN	Townhouse Building 200	Apt 203	Kitchen Sink	1	B	0.16	3/18/17										
PbTWN	Townhouse Building 200	Apt 203	Bathroom Sink 2nd floor	2	A	0.16	3/16/17										
PbTWN	Townhouse Building 200	Apt 203	Bathroom Sink 2nd floor	2	B	0.16	3/16/17										
PbTWN	Townhouse Building 200	Apt 203	Bathroom Sink 3rd floor	3	A	0.16	3/16/17										
PbTWN	Townhouse Building 200	Apt 203	Bathroom Sink 3rd floor	3	B	0.16	3/16/17										
PbTWN	Townhouse Building 200	Apt 204	Kitchen Sink	1	A	0.16	3/18/17										
PbTWN	Townhouse Building 200	Apt 204	Kitchen Sink	1	B	0.16	3/18/17										
PbTWN	Townhouse Building 200	Apt 204	Bathroom Sink 2nd floor	2	A	0.16	3/16/17	C	2.3	8/1/17							
PbTWN	Townhouse Building 200	Apt 204	Bathroom Sink 2nd floor	2	B	0.16	3/16/17	D	0.22	8/1/17							
PbTWN	Townhouse Building 200	Apt 204	Bathroom Sink 3rd floor	3	A	0.16	3/16/17										
PbTWN	Townhouse Building 200	Apt 204	Bathroom Sink 3rd floor	3	B	0.16	3/16/17										
PbTWN	Townhouse Building 300	Apt 301KN	Sink	2	A	1.2	1/4/17										
PbTWN	Townhouse Building 300	Apt 301KN	Sink	2	B	91.8	1/4/17										The two samples directly below this one are the second [A and B] samples for the kitchen sink in Townhouse 301. Third [C and D] samples also were taken for this sink.
PbTWN	Townhouse Building 300	Apt 301	Kitchen Sink	1	A	0.16	3/18/17	C	1.3	8/1/17							
PbTWN	Townhouse Building 300	Apt 301	Kitchen Sink	1	B	0.16	3/18/17	D	0.16	8/1/17							
PbTWN	Townhouse Building 300	Apt 301	Bathroom Sink 2nd floor	2	A	0.16	3/16/17										
PbTWN	Townhouse Building 300	Apt 301	Bathroom Sink 2nd floor	2	B	0.16	3/16/17										
PbTWN	Townhouse Building 300	Apt 301	Bathroom Sink 3rd floor	3	A	0.16	3/16/17										
PbTWN	Townhouse Building 300	Apt 301	Bathroom Sink 3rd floor	3	B	0.16	3/16/17										
PbTWN	Townhouse Building 300	Apt 302	Kitchen Sink	1	A	0.16	3/18/17										
PbTWN	Townhouse Building 300	Apt 302	Kitchen Sink	1	B	0.16	3/18/17										
PbTWN	Townhouse Building 300	Apt 302	Bathroom Sink 2nd floor	2	A	0.16	3/16/17										
PbTWN	Townhouse Building 300	Apt 302	Bathroom Sink 2nd floor	2	B	0.16	3/16/17										
PbTWN	Townhouse Building 300	Apt 302	Bathroom Sink 3rd floor	3	A	0.16	3/16/17										
PbTWN	Townhouse Building 300	Apt 302	Bathroom Sink 3rd floor	3	B	0.16	3/16/17										
PbTWN	Townhouse Building 300	Apt 303	Kitchen Sink	1	A	0.16	3/18/17										
PbTWN	Townhouse Building 300	Apt 303	Kitchen Sink	1	B	0.16	3/18/17										
PbTWN	Townhouse Building 300	Apt 303	Bathroom Sink 2nd floor	2	A	0.16	3/16/17										
PbTWN	Townhouse Building 300	Apt 303	Bathroom Sink 2nd floor	2	B	0.16	3/16/17										
PbTWN	Townhouse Building 300	Apt 303	Bathroom Sink 3rd floor	3	A	0.16	3/16/17										
PbTWN	Townhouse Building 300	Apt 303	Bathroom Sink 3rd floor	3	B	0.16	3/16/17										
PbTWN	Townhouse Building 300	Apt 304	Kitchen Sink	1	A	0.16	3/18/17										
PbTWN	Townhouse Building 300	Apt 304	Kitchen Sink	1	B	0.16	3/18/17										
PbTWN	Townhouse Building 300	Apt 304	Bathroom Sink 2nd floor	2	A	0.16	3/16/17	C	3.3	8/1/17							
PbTWN	Townhouse Building 300	Apt 304	Bathroom Sink 2nd floor	2	B	0.16	3/16/17	D	0.7	8/1/17							
PbTWN	Townhouse Building 300	Apt 304	Bathroom Sink 3rd floor	3	A	0.16	3/16/17										
PbTWN	Townhouse Building 300	Apt 304	Bathroom Sink 3rd floor	3	B	0.16	3/16/17										

Sample ID	Building	Room/Location	Sample Location	Sample No.	Draw	Result (ug/L)	Date	Draw	Result (ug/L)	Date	Draw	Result (ug/L)	Date	Draw	Result (ug/L)	Date	Notes
PbTWN	Townhouse Building 300	Apt 305	Kitchen Sink	1	A	0.16	3/18/17										
PbTWN	Townhouse Building 300	Apt 305	Kitchen Sink	1	B	0.16	3/18/17										
PbTWN	Townhouse Building 300	Apt 305	Bathroom Sink 2nd floor	2	A	0.16	3/16/17										
PbTWN	Townhouse Building 300	Apt 305	Bathroom Sink 2nd floor	2	B	0.16	3/16/17										
PbTWN	Townhouse Building 300	Apt 305	Bathroom Sink 3rd floor	3	A	0.16	3/16/17										
PbTWN	Townhouse Building 300	Apt 305	Bathroom Sink 3rd floor	3	B	0.16	3/16/17										
PbTWN	Townhouse Building 300	Apt 306	Kitchen Sink	1	A	0.16	3/18/17										
PbTWN	Townhouse Building 300	Apt 306	Kitchen Sink	1	B	0.16	3/18/17										
PbTWN	Townhouse Building 300	Apt 306	Bathroom Sink 2nd floor	2	A	0.16	3/16/17										
PbTWN	Townhouse Building 300	Apt 306	Bathroom Sink 2nd floor	2	B	0.16	3/16/17										
PbTWN	Townhouse Building 300	Apt 306	Bathroom Sink 3rd floor	3	A	0.16	3/16/17										
PbTWN	Townhouse Building 300	Apt 306	Bathroom Sink 3rd floor	3	B	0.16	3/16/17										
PbTWN	Townhouse Building 300	Apt 307	Kitchen Sink	1	A	0.16	3/18/17										
PbTWN	Townhouse Building 300	Apt 307	Kitchen Sink	1	B	0.16	3/18/17										
PbTWN	Townhouse Building 300	Apt 307	Bathroom Sink 2nd floor	2	A	0.17	3/16/17										
PbTWN	Townhouse Building 300	Apt 307	Bathroom Sink 2nd floor	2	B	0.16	3/16/17										
PbTWN	Townhouse Building 300	Apt 307	Bathroom Sink 3rd floor	3	A	0.16	3/16/17	C	1.1	8/1/17							
PbTWN	Townhouse Building 300	Apt 307	Bathroom Sink 3rd floor	3	B	0.16	3/16/17	D	0.2	8/1/17							
PbTWN	Townhouse Building 300	Apt 308	Kitchen Sink	1	A	0.16	3/18/17										
PbTWN	Townhouse Building 300	Apt 308	Kitchen Sink	1	B	0.16	3/18/17										
PbTWN	Townhouse Building 300	Apt 308	Bathroom Sink 2nd floor	2	A	0.16	3/16/17										
PbTWN	Townhouse Building 300	Apt 308	Bathroom Sink 2nd floor	2	B	0.16	3/16/17										
PbTWN	Townhouse Building 300	Apt 308	Bathroom Sink 3rd floor	3	A	0.16	3/16/17										
PbTWN	Townhouse Building 300	Apt 308	Bathroom Sink 3rd floor	3	B	0.16	3/16/17										
PbTWN	Townhouse Building 400	Apt 401	Kitchen Sink	1	A	0.16	3/18/17										
PbTWN	Townhouse Building 400	Apt 401	Kitchen Sink	1	B	0.16	3/18/17										
PbTWN	Townhouse Building 400	Apt 401	Bathroom Sink 2nd floor	2	A	0.16	3/16/17										
PbTWN	Townhouse Building 400	Apt 401	Bathroom Sink 2nd floor	2	B	0.16	3/16/17										
PbTWN	Townhouse Building 400	Apt 401	Bathroom Sink 3rd floor	3	A	0.16	3/16/17										
PbTWN	Townhouse Building 400	Apt 401	Bathroom Sink 3rd floor	3	B	0.16	3/16/17										
PbTWN	Townhouse Building 400	Apt 402KN	Sink	2	A	1.9	1/4/17										
PbTWN	Townhouse Building 400	Apt 402KN	Sink	2	B	102	1/4/17										The two samples directly below this one are the second [A and B] samples for the kitchen sink in Townhouse 402.
PbTWN	Townhouse Building 400	Apt 402	Kitchen Sink	1	A	0.16	3/18/17										
PbTWN	Townhouse Building 400	Apt 402	Kitchen Sink	1	B	0.16	3/18/17										
PbTWN	Townhouse Building 400	Apt 402	Bathroom Sink 2nd floor	2	A	0.16	3/16/17	C	2.6	8/1/17							
PbTWN	Townhouse Building 400	Apt 402	Bathroom Sink 2nd floor	2	B	0.16	3/16/17	D	0.26	8/1/17							
PbTWN	Townhouse Building 400	Apt 402	Bathroom Sink 3rd floor	3	A	0.16	3/16/17										
PbTWN	Townhouse Building 400	Apt 402	Bathroom Sink 3rd floor	3	B	0.16	3/16/17										
PbTWN	Townhouse Building 400	Apt 403	Kitchen Sink	1	A	0.16	3/18/17										
PbTWN	Townhouse Building 400	Apt 403	Kitchen Sink	1	B	0.16	3/18/17										
PbTWN	Townhouse Building 400	Apt 403	Bathroom Sink 2nd floor	2	A	0.16	3/16/17										
PbTWN	Townhouse Building 400	Apt 403	Bathroom Sink 2nd floor	2	B	0.16	3/16/17										
PbTWN	Townhouse Building 400	Apt 403	Bathroom Sink 3rd floor	3	A	0.16	3/16/17										
PbTWN	Townhouse Building 400	Apt 403	Bathroom Sink 3rd floor	3	B	0.16	3/16/17										
PbTWN	Townhouse Building 400	Apt 404	Kitchen Sink	1	A	0.16	3/18/17										
PbTWN	Townhouse Building 400	Apt 404	Kitchen Sink	1	B	0.16	3/18/17										
PbTWN	Townhouse Building 400	Apt 404	Bathroom Sink 2nd floor	2	A	0.16	3/16/17										
PbTWN	Townhouse Building 400	Apt 404	Bathroom Sink 2nd floor	2	B	0.16	3/16/17										
PbTWN	Townhouse Building 400	Apt 404	Bathroom Sink 3rd floor	3	A	0.16	3/16/17										
PbTWN	Townhouse Building 400	Apt 404	Bathroom Sink 3rd floor	3	B	0.16	3/16/17										
PbTWN	Townhouse Building 400	Apt 405	Kitchen Sink	1	A	0.16	3/18/17	C	2.9	8/1/17							
PbTWN	Townhouse Building 400	Apt 405	Kitchen Sink	1	B	0.16	3/18/17	D	0.16	8/1/17							
PbTWN	Townhouse Building 400	Apt 405	Bathroom Sink 2nd floor	2	A	0.16	3/16/17										
PbTWN	Townhouse Building 400	Apt 405	Bathroom Sink 2nd floor	2	B	0.16	3/16/17										
PbTWN	Townhouse Building 400	Apt 405	Bathroom Sink 3rd floor	3	A	0.16	3/16/17										

Sample ID	Building	Room/Location	Sample Location	Sample No.	Draw	Result (ug/L)	Date	Draw	Result (ug/L)	Date	Draw	Result (ug/L)	Date	Draw	Result (ug/L)	Date	Notes
PbTWN	Townhouse Building 400	Apt 405	Bathroom Sink 3rd floor	3	B	0.16	3/16/17										
PbTWN	Townhouse Building 500	Apt 501	Kitchen Sink	1	A	2.2	7/27/17										
PbTWN	Townhouse Building 500	Apt 501	Kitchen Sink	1	B	0.16	7/27/17										
PbTWN	Townhouse Building 500	Apt 501	Bathroom Sink 2nd floor	2	A	0.16	3/16/17	C	2.7	8/1/17							
PbTWN	Townhouse Building 500	Apt 501	Bathroom Sink 2nd floor	2	B	0.16	3/16/17	D	0.51	8/1/17							
PbTWN	Townhouse Building 500	Apt 501	Bathroom Sink 3rd floor	3	A	0.16	3/16/17										
PbTWN	Townhouse Building 500	Apt 501	Bathroom Sink 3rd floor	3	B	0.16	3/16/17										
PbTWN	Townhouse Building 500	Apt 502KN	Sink	2	A	0.68	1/4/17										
PbTWN	Townhouse Building 500	Apt 502KN	Sink	2	B	205	1/4/17										The two samples directly below this one are the second [A and B] samples for the kitchen sink in Townhouse 502.
PbTWN	Townhouse Building 500	Apt 502	Kitchen Sink	1	A	1.5	7/27/17										
PbTWN	Townhouse Building 500	Apt 502	Kitchen Sink	1	B	0.2	7/27/17										
PbTWN	Townhouse Building 500	Apt 502	Bathroom Sink 2nd floor	2	A	0.16	3/16/17										
PbTWN	Townhouse Building 500	Apt 502	Bathroom Sink 2nd floor	2	B	0.16	3/16/17										
PbTWN	Townhouse Building 500	Apt 502	Bathroom Sink 3rd floor	3	A	0.16	3/16/17										
PbTWN	Townhouse Building 500	Apt 502	Bathroom Sink 3rd floor	3	B	0.16	3/16/17										
PbTWN	Townhouse Building 500	Apt 503	Kitchen Sink	1	A	4.1	7/27/17										
PbTWN	Townhouse Building 500	Apt 503	Kitchen Sink	1	B	0.16	7/27/17										
PbTWN	Townhouse Building 500	Apt 503	Bathroom Sink 2nd floor	2	A	0.16	3/16/17										
PbTWN	Townhouse Building 500	Apt 503	Bathroom Sink 2nd floor	2	B	0.16	3/16/17										
PbTWN	Townhouse Building 500	Apt 503	Bathroom Sink 3rd floor	3	A	0.16	3/16/17										
PbTWN	Townhouse Building 500	Apt 503	Bathroom Sink 3rd floor	3	B	0.16	3/16/17										
PbTWN	Townhouse Building 500	Apt 504	Kitchen Sink	1	A	1.8	7/27/17										
PbTWN	Townhouse Building 500	Apt 504	Kitchen Sink	1	B	0.16	7/27/17										
PbTWN	Townhouse Building 500	Apt 504	Bathroom Sink 2nd floor	2	A	0.16	3/16/17										
PbTWN	Townhouse Building 500	Apt 504	Bathroom Sink 2nd floor	2	B	0.16	3/16/17										
PbTWN	Townhouse Building 500	Apt 504	Bathroom Sink 3rd floor	3	A	0.16	3/16/17										
PbTWN	Townhouse Building 500	Apt 504	Bathroom Sink 3rd floor	3	B	0.16	3/16/17										
PbTWN	Townhouse Building 500	Apt 505	Kitchen Sink	1	A	2.2	7/27/17										
PbTWN	Townhouse Building 500	Apt 505	Kitchen Sink	1	B	0.16	7/27/17										
PbTWN	Townhouse Building 500	Apt 505	Bathroom Sink 2nd floor	2	A	0.16	3/16/17										
PbTWN	Townhouse Building 500	Apt 505	Bathroom Sink 2nd floor	2	B	0.16	3/16/17										
PbTWN	Townhouse Building 500	Apt 505	Bathroom Sink 3rd floor	3	A	0.16	3/16/17										
PbTWN	Townhouse Building 500	Apt 505	Bathroom Sink 3rd floor	3	B	0.16	3/16/17										
PbTWN	Townhouse Building 500	Apt 506	Kitchen Sink	1	A	2.4	7/27/17										
PbTWN	Townhouse Building 500	Apt 506	Kitchen Sink	1	B	0.16	7/27/17										
PbTWN	Townhouse Building 500	Apt 506	Bathroom Sink 2nd floor	2	A	0.16	3/16/17										
PbTWN	Townhouse Building 500	Apt 506	Bathroom Sink 2nd floor	2	B	0.16	3/16/17										
PbTWN	Townhouse Building 500	Apt 506	Bathroom Sink 3rd floor	3	A	0.16	3/16/17	C	4.9	8/1/17							
PbTWN	Townhouse Building 500	Apt 506	Bathroom Sink 3rd floor	3	B	0.16	3/16/17	D	0.26	8/1/17							
PbTWN	Townhouse Building 600	Apt 601	Kitchen Sink	1	A	1.3	7/27/17										
PbTWN	Townhouse Building 600	Apt 601	Kitchen Sink	1	B	0.19	7/27/17										
PbTWN	Townhouse Building 600	Apt 601	Bathroom Sink 2nd floor	2	A	0.16	3/16/17										
PbTWN	Townhouse Building 600	Apt 601	Bathroom Sink 2nd floor	2	B	0.16	3/16/17										
PbTWN	Townhouse Building 600	Apt 601	Bathroom Sink 3rd floor	3	A	0.16	3/16/17										
PbTWN	Townhouse Building 600	Apt 601	Bathroom Sink 3rd floor	3	B	0.16	3/16/17										
PbTWN	Townhouse Building 600	Apt 602	Kitchen Sink	1	A	1.7	7/27/17										
PbTWN	Townhouse Building 600	Apt 602	Kitchen Sink	1	B	0.3	7/27/17										
PbTWN	Townhouse Building 600	Apt 602	Bathroom Sink 2nd floor	2	A	0.16	3/16/17										
PbTWN	Townhouse Building 600	Apt 602	Bathroom Sink 2nd floor	2	B	0.16	3/16/17										
PbTWN	Townhouse Building 600	Apt 602	Bathroom Sink 3rd floor	3	A	0.16	3/16/17										
PbTWN	Townhouse Building 600	Apt 602	Bathroom Sink 3rd floor	3	B	0.16	3/16/17										
PbTWN	Townhouse Building 600	Apt 603KN	Sink	2	A	0.74	1/4/17										
PbTWN	Townhouse Building 600	Apt 603KN	Sink	2	B	3	1/4/17										
PbTWN	Townhouse Building 600	Apt 603	Kitchen Sink	1	A	1	7/27/17										

Sample ID	Building	Room/Location	Sample Location	Sample No.	Draw	Result (ug/L)	Date	Draw	Result (ug/L)	Date	Draw	Result (ug/L)	Date	Draw	Result (ug/L)	Date	Notes
PbTWN	Townhouse Building 600	Apt 603	Kitchen Sink	1	B	0.18	7/27/17										
PbTWN	Townhouse Building 600	Apt 603	Bathroom Sink 2nd floor	2	A	0.16	3/16/17	C	0.97	8/1/17							
PbTWN	Townhouse Building 600	Apt 603	Bathroom Sink 2nd floor	2	B	0.16	3/16/17	D	0.16	8/1/17							
PbTWN	Townhouse Building 600	Apt 603	Bathroom Sink 3rd floor	3	A	0.16	3/16/17										
PbTWN	Townhouse Building 600	Apt 603	Bathroom Sink 3rd floor	3	B	0.16	3/16/17										
PbTWN	Townhouse Building 600	Apt 604	Kitchen Sink	1	A	0.68	7/27/17										
PbTWN	Townhouse Building 600	Apt 604	Kitchen Sink	1	B	0.65	7/27/17										
PbTWN	Townhouse Building 600	Apt 604	Bathroom Sink 2nd floor	2	A	0.16	3/16/17										
PbTWN	Townhouse Building 600	Apt 604	Bathroom Sink 2nd floor	2	B	0.16	3/16/17										
PbTWN	Townhouse Building 600	Apt 604	Bathroom Sink 3rd floor	3	A	0.16	3/16/17										
PbTWN	Townhouse Building 600	Apt 604	Bathroom Sink 3rd floor	3	B	0.16	3/16/17										
PbTWN	Townhouse Building 600	Apt 605	Kitchen Sink	1	A	2.4	7/27/17										
PbTWN	Townhouse Building 600	Apt 605	Kitchen Sink	1	B	0.21	7/27/17										
PbTWN	Townhouse Building 600	Apt 605	Bathroom Sink 2nd floor	2	A	0.16	3/16/17										
PbTWN	Townhouse Building 600	Apt 605	Bathroom Sink 2nd floor	2	B	0.16	3/16/17										
PbTWN	Townhouse Building 600	Apt 605	Bathroom Sink 3rd floor	3	A	0.16	3/16/17										
PbTWN	Townhouse Building 600	Apt 605	Bathroom Sink 3rd floor	3	B	0.16	3/16/17										
PbTWN	Townhouse Building 600	Apt 606	Kitchen Sink	1	A	1.4	7/27/17										
PbTWN	Townhouse Building 600	Apt 606	Kitchen Sink	1	B	0.26	7/27/17										
PbTWN	Townhouse Building 600	Apt 606	Bathroom Sink 2nd floor	2	A	0.16	3/16/17										
PbTWN	Townhouse Building 600	Apt 606	Bathroom Sink 2nd floor	2	B	0.16	3/16/17										
PbTWN	Townhouse Building 600	Apt 606	Bathroom Sink 3rd floor	3	A	0.16	3/16/17										
PbTWN	Townhouse Building 600	Apt 606	Bathroom Sink 3rd floor	3	B	0.16	3/16/17										
PbTWN	Townhouse Building 600	Apt 607	Kitchen Sink	1	A	2.3	7/27/17										
PbTWN	Townhouse Building 600	Apt 607	Kitchen Sink	1	B	0.2	7/27/17										
PbTWN	Townhouse Building 600	Apt 607	Bathroom Sink 2nd floor	2	A	0.16	3/16/17										
PbTWN	Townhouse Building 600	Apt 607	Bathroom Sink 2nd floor	2	B	0.16	3/16/17										
PbTWN	Townhouse Building 600	Apt 607	Bathroom Sink 3rd floor	3	A	0.16	3/16/17	C	5.1	8/1/17							
PbTWN	Townhouse Building 600	Apt 607	Bathroom Sink 3rd floor	3	B	0.16	3/16/17	D	0.17	8/1/17							
PbTWN	Townhouse Building 700	Apt 701	Kitchen Sink	1	A	4.4	7/27/17										
PbTWN	Townhouse Building 700	Apt 701	Kitchen Sink	1	B	0.47	7/27/17										
PbTWN	Townhouse Building 700	Apt 701	Bathroom Sink 2nd floor	2	A	0.16	3/16/17										
PbTWN	Townhouse Building 700	Apt 701	Bathroom Sink 2nd floor	2	B	0.16	3/16/17										
PbTWN	Townhouse Building 700	Apt 701	Bathroom Sink 3rd floor	3	A	0.16	3/16/17	C	3.7	8/1/17							
PbTWN	Townhouse Building 700	Apt 701	Bathroom Sink 3rd floor	3	B	0.16	3/16/17	D	0.21	8/1/17							
PbTWN	Townhouse Building 700	Apt 702	Kitchen Sink	1	A	2.7	7/27/17										
PbTWN	Townhouse Building 700	Apt 702	Kitchen Sink	1	B	0.27	7/27/17										
PbTWN	Townhouse Building 700	Apt 702	Bathroom Sink 2nd floor	2	A	0.16	3/16/17										
PbTWN	Townhouse Building 700	Apt 702	Bathroom Sink 2nd floor	2	B	0.16	3/16/17										
PbTWN	Townhouse Building 700	Apt 702	Bathroom Sink 3rd floor	3	A	0.16	3/16/17										
PbTWN	Townhouse Building 700	Apt 702	Bathroom Sink 3rd floor	3	B	0.16	3/16/17										
PbTWN	Townhouse Building 700	Apt 703KN	Sink	2	A	1.1	1/4/17										
PbTWN	Townhouse Building 700	Apt 703KN	Sink	2	B	6.9	1/4/17										
PbTWN	Townhouse Building 700	Apt 703	Kitchen Sink	1	A	2.4	7/27/17										
PbTWN	Townhouse Building 700	Apt 703	Kitchen Sink	1	B	0.16	7/27/17										
PbTWN	Townhouse Building 700	Apt 703	Bathroom Sink 2nd floor	2	A	0.16	3/16/17										
PbTWN	Townhouse Building 700	Apt 703	Bathroom Sink 2nd floor	2	B	0.16	3/16/17										
PbTWN	Townhouse Building 700	Apt 703	Bathroom Sink 3rd floor	3	A	0.16	3/16/17										
PbTWN	Townhouse Building 700	Apt 703	Bathroom Sink 3rd floor	3	B	0.16	3/16/17										
PbTWN	Townhouse Building 700	Apt 704	Kitchen Sink	1	A	2	7/27/17										
PbTWN	Townhouse Building 700	Apt 704	Kitchen Sink	1	B	0.31	7/27/17										
PbTWN	Townhouse Building 700	Apt 704	Bathroom Sink 2nd floor	2	A	0.16	3/16/17	C	2.3	8/1/17							
PbTWN	Townhouse Building 700	Apt 704	Bathroom Sink 2nd floor	2	B	0.16	3/16/17	D	0.17	8/1/17							
PbTWN	Townhouse Building 700	Apt 704	Bathroom Sink 3rd floor	3	A	0.16	3/16/17										
PbTWN	Townhouse Building 700	Apt 704	Bathroom Sink 3rd floor	3	B	0.16	3/16/17										
PbTWN	Townhouse Building 700	Apt 705	Kitchen Sink	1	A	1.7	7/27/17										

Sample ID	Building	Room/Location	Sample Location	Sample No.	Draw	Result (ug/L)	Date	Draw	Result (ug/L)	Date	Draw	Result (ug/L)	Date	Draw	Result (ug/L)	Date	Notes
PbTWN	Townhouse Building 700	Apt 705	Kitchen Sink	1	B	0.48	7/27/17										
PbTWN	Townhouse Building 700	Apt 705	Bathroom Sink 2nd floor	2	A	0.16	3/16/17										
PbTWN	Townhouse Building 700	Apt 705	Bathroom Sink 2nd floor	2	B	0.16	3/16/17										
PbTWN	Townhouse Building 700	Apt 705	Bathroom Sink 3rd floor	3	A	0.16	3/16/17										
PbTWN	Townhouse Building 700	Apt 705	Bathroom Sink 3rd floor	3	B	0.16	3/16/17										
PbTWN	Townhouse Building 700	Apt 706	Kitchen Sink	1	A	2	7/27/17										
PbTWN	Townhouse Building 700	Apt 706	Kitchen Sink	1	B	0.16	7/27/17										
PbTWN	Townhouse Building 700	Apt 706	Bathroom Sink 2nd floor	2	A	0.16	3/16/17										
PbTWN	Townhouse Building 700	Apt 706	Bathroom Sink 2nd floor	2	B	0.16	3/16/17										
PbTWN	Townhouse Building 700	Apt 706	Bathroom Sink 3rd floor	3	A	0.16	3/16/17										
PbTWN	Townhouse Building 700	Apt 706	Bathroom Sink 3rd floor	3	B	0.16	3/16/17										
PbTWN	Townhouse Building 700	Apt 707	Kitchen Sink	1	A	0.81	7/27/17										
PbTWN	Townhouse Building 700	Apt 707	Kitchen Sink	1	B	0.16	7/27/17										
PbTWN	Townhouse Building 700	Apt 707	Bathroom Sink 2nd floor	2	A	0.16	3/16/17										
PbTWN	Townhouse Building 700	Apt 707	Bathroom Sink 2nd floor	2	B	0.16	3/16/17										
PbTWN	Townhouse Building 700	Apt 707	Bathroom Sink 3rd floor	3	A	0.16	3/16/17										
PbTWN	Townhouse Building 700	Apt 707	Bathroom Sink 3rd floor	3	B	0.16	3/16/17										
PbTWN	Townhouse Building 700	Apt 708	Kitchen Sink	1	A	1.8	7/27/17										
PbTWN	Townhouse Building 700	Apt 708	Kitchen Sink	1	B	0.45	7/27/17										
PbTWN	Townhouse Building 700	Apt 708	Bathroom Sink 2nd floor	2	A	0.16	3/16/17										
PbTWN	Townhouse Building 700	Apt 708	Bathroom Sink 2nd floor	2	B	0.16	3/16/17										
PbTWN	Townhouse Building 700	Apt 708	Bathroom Sink 3rd floor	3	A	0.16	3/16/17										
PbTWN	Townhouse Building 700	Apt 708	Bathroom Sink 3rd floor	3	B	0.16	3/16/17										
PbTWN	Townhouse Building 800	Apt 801	Kitchen Sink	1	A	1.6	7/27/17										
PbTWN	Townhouse Building 800	Apt 801	Kitchen Sink	1	B	0.16	7/27/17										
PbTWN	Townhouse Building 800	Apt 801	Bathroom Sink 2nd floor	2	A	0.16	3/16/17										
PbTWN	Townhouse Building 800	Apt 801	Bathroom Sink 2nd floor	2	B	0.16	3/16/17										
PbTWN	Townhouse Building 800	Apt 801	Bathroom Sink 3rd floor	3	A	0.16	3/16/17										
PbTWN	Townhouse Building 800	Apt 801	Bathroom Sink 3rd floor	3	B	0.16	3/16/17										
PbTWN	Townhouse Building 800	Apt 802	Kitchen Sink	1	A	2	7/27/17										
PbTWN	Townhouse Building 800	Apt 802	Kitchen Sink	1	B	0.16	7/27/17										
PbTWN	Townhouse Building 800	Apt 802	Bathroom Sink 2nd floor	2	A	0.16	3/16/17										
PbTWN	Townhouse Building 800	Apt 802	Bathroom Sink 2nd floor	2	B	0.16	3/16/17										
PbTWN	Townhouse Building 800	Apt 802	Bathroom Sink 3rd floor	3	A	0.16	3/16/17										
PbTWN	Townhouse Building 800	Apt 802	Bathroom Sink 3rd floor	3	B	0.16	3/16/17										
PbTWN	Townhouse Building 800	Apt 803	Kitchen Sink	1	A	4.6	7/27/17										
PbTWN	Townhouse Building 800	Apt 803	Kitchen Sink	1	B	0.16	7/27/17										
PbTWN	Townhouse Building 800	Apt 803	Bathroom Sink 2nd floor	2	A	0.16	3/16/17	C	2	8/1/17							
PbTWN	Townhouse Building 800	Apt 803	Bathroom Sink 2nd floor	2	B	0.16	3/16/17	D	0.16	8/1/17							
PbTWN	Townhouse Building 800	Apt 803	Bathroom Sink 3rd floor	3	A	0.16	3/16/17										
PbTWN	Townhouse Building 800	Apt 803	Bathroom Sink 3rd floor	3	B	0.16	3/16/17										
PbTWN	Townhouse Building 800	Apt 804	Kitchen Sink	1	A	3.7	7/27/17										
PbTWN	Townhouse Building 800	Apt 804	Kitchen Sink	1	B	0.16	7/27/17										
PbTWN	Townhouse Building 800	Apt 804	Bathroom Sink 2nd floor	2	A	0.16	3/16/17										
PbTWN	Townhouse Building 800	Apt 804	Bathroom Sink 2nd floor	2	B	0.16	3/16/17										
PbTWN	Townhouse Building 800	Apt 804	Bathroom Sink 3rd floor	3	A	0.16	3/16/17	C	1.4	8/1/17							
PbTWN	Townhouse Building 800	Apt 804	Bathroom Sink 3rd floor	3	B	0.16	3/16/17	D	0.19	8/1/17							
PbTWN	Townhouse Building 800	Apt 805KN	Sink	2	A	0.86	1/4/17										
PbTWN	Townhouse Building 800	Apt 805KN	Sink	2	B	0.25	1/4/17										
PbTWN	Townhouse Building 800	Apt 805	Kitchen Sink	1	A	0.78	7/27/17										
PbTWN	Townhouse Building 800	Apt 805	Kitchen Sink	1	B	0.16	7/27/17										
PbTWN	Townhouse Building 800	Apt 805	Bathroom Sink 2nd floor	2	A	0.16	3/16/17										
PbTWN	Townhouse Building 800	Apt 805	Bathroom Sink 2nd floor	2	B	0.16	3/16/17										
PbTWN	Townhouse Building 800	Apt 805	Bathroom Sink 3rd floor	3	A	0.16	3/16/17										
PbTWN	Townhouse Building 800	Apt 805	Bathroom Sink 3rd floor	3	B	0.16	3/16/17										

Sample ID	Building	Room/Location	Sample Location	Sample No.	Draw	Result (ug/L)	Date	Draw	Result (ug/L)	Date	Draw	Result (ug/L)	Date	Draw	Result (ug/L)	Date	Notes
PbTWN	Townhouse Building 900	Apt 901	Kitchen Sink	1	A	0.96	7/27/17										
PbTWN	Townhouse Building 900	Apt 901	Kitchen Sink	1	B	0.16	7/27/17										
PbTWN	Townhouse Building 900	Apt 901	Bathroom Sink 2nd floor	2	A	0.16	3/16/17										
PbTWN	Townhouse Building 900	Apt 901	Bathroom Sink 2nd floor	2	B	0.16	3/16/17										
PbTWN	Townhouse Building 900	Apt 901	Bathroom Sink 3rd floor	3	A	0.16	3/16/17										
PbTWN	Townhouse Building 900	Apt 901	Bathroom Sink 3rd floor	3	B	0.16	3/16/17										
PbTWN	Townhouse Building 900	Apt 902	Kitchen Sink	1	A	2.6	7/27/17										
PbTWN	Townhouse Building 900	Apt 902	Kitchen Sink	1	B	0.16	7/27/17										
PbTWN	Townhouse Building 900	Apt 902	Bathroom Sink 2nd floor	2	A	0.16	3/16/17										
PbTWN	Townhouse Building 900	Apt 902	Bathroom Sink 2nd floor	2	B	0.16	3/16/17										
PbTWN	Townhouse Building 900	Apt 902	Bathroom Sink 3rd floor	3	A	0.16	3/16/17										
PbTWN	Townhouse Building 900	Apt 902	Bathroom Sink 3rd floor	3	B	0.16	3/16/17										
PbTWN	Townhouse Building 900	Apt 903KN	Sink	2	A	3.3	1/4/17										
PbTWN	Townhouse Building 900	Apt 903KN	Sink	2	B	7.7	1/4/17										
PbTWN	Townhouse Building 900	Apt 903	Kitchen Sink	1	A	3.3	7/27/17										
PbTWN	Townhouse Building 900	Apt 903	Kitchen Sink	1	B	0.16	7/27/17										
PbTWN	Townhouse Building 900	Apt 903	Bathroom Sink 2nd floor	2	A	0.16	3/16/17	C	3.3	8/1/17							
PbTWN	Townhouse Building 900	Apt 903	Bathroom Sink 2nd floor	2	B	0.16	3/16/17	D	0.77	8/1/17							
PbTWN	Townhouse Building 900	Apt 903	Bathroom Sink 3rd floor	3	A	0.16	3/16/17										
PbTWN	Townhouse Building 900	Apt 903	Bathroom Sink 3rd floor	3	B	0.16	3/16/17										
PbTWN	Townhouse Building 900	Apt 904	Kitchen Sink	1	A	1.9	7/27/17										
PbTWN	Townhouse Building 900	Apt 904	Kitchen Sink	1	B	0.16	7/27/17										
PbTWN	Townhouse Building 900	Apt 904	Bathroom Sink 2nd floor	2	A	0.16	3/16/17										
PbTWN	Townhouse Building 900	Apt 904	Bathroom Sink 2nd floor	2	B	0.16	3/16/17										
PbTWN	Townhouse Building 900	Apt 904	Bathroom Sink 3rd floor	3	A	0.16	3/16/17										
PbTWN	Townhouse Building 900	Apt 904	Bathroom Sink 3rd floor	3	B	0.16	3/16/17										
PbTWN	Townhouse Building 900	Apt 905	Kitchen Sink	1	A	5.6	7/27/17										
PbTWN	Townhouse Building 900	Apt 905	Kitchen Sink	1	B	0.25	7/27/17										
PbTWN	Townhouse Building 900	Apt 905	Bathroom Sink 2nd floor	2	A	0.16	3/16/17										
PbTWN	Townhouse Building 900	Apt 905	Bathroom Sink 2nd floor	2	B	0.16	3/16/17										
PbTWN	Townhouse Building 900	Apt 905	Bathroom Sink 3rd floor	3	A	0.16	3/16/17	C	3.2	8/1/17							
PbTWN	Townhouse Building 900	Apt 905	Bathroom Sink 3rd floor	3	B	0.16	3/16/17	D	0.19	8/1/17							
PbTWN	Townhouse Building 1000	Apt 1001	Kitchen Sink	1	A	2.9	7/27/17										
PbTWN	Townhouse Building 1000	Apt 1001	Kitchen Sink	1	B	0.16	7/27/17										
PbTWN	Townhouse Building 1000	Apt 1001	Bathroom Sink 2nd floor	2	A	0.16	3/16/17										
PbTWN	Townhouse Building 1000	Apt 1001	Bathroom Sink 2nd floor	2	B	0.16	3/16/17										
PbTWN	Townhouse Building 1000	Apt 1001	Bathroom Sink 3rd floor	3	A	0.16	3/16/17										
PbTWN	Townhouse Building 1000	Apt 1001	Bathroom Sink 3rd floor	3	B	0.16	3/16/17										
PbTWN	Townhouse Building 1000	Apt 1002	Kitchen Sink	1	A	3.1	7/27/17										
PbTWN	Townhouse Building 1000	Apt 1002	Kitchen Sink	1	B	0.68	7/27/17										
PbTWN	Townhouse Building 1000	Apt 1002	Bathroom Sink 2nd floor	2	A	0.16	3/16/17										
PbTWN	Townhouse Building 1000	Apt 1002	Bathroom Sink 2nd floor	2	B	0.16	3/16/17										
PbTWN	Townhouse Building 1000	Apt 1002	Bathroom Sink 3rd floor	3	A	0.16	3/16/17	C	1.9	8/1/17							
PbTWN	Townhouse Building 1000	Apt 1002	Bathroom Sink 3rd floor	3	B	0.16	3/16/17	D	0.17	8/1/17							
PbTWN	Townhouse Building 1000	Apt 1003	Kitchen Sink	1	A	3.7	7/27/17										
PbTWN	Townhouse Building 1000	Apt 1003	Kitchen Sink	1	B	0.57	7/27/17										
PbTWN	Townhouse Building 1000	Apt 1003	Bathroom Sink 2nd floor	2	A	0.16	3/16/17										
PbTWN	Townhouse Building 1000	Apt 1003	Bathroom Sink 2nd floor	2	B	0.16	3/16/17										
PbTWN	Townhouse Building 1000	Apt 1003	Bathroom Sink 3rd floor	3	A	0.16	3/16/17										
PbTWN	Townhouse Building 1000	Apt 1003	Bathroom Sink 3rd floor	3	B	0.16	3/16/17										
PbTWN	Townhouse Building 1000	Apt 1004	Kitchen Sink	1	A	4.3	7/27/17										
PbTWN	Townhouse Building 1000	Apt 1004	Kitchen Sink	1	B	0.16	7/27/17										
PbTWN	Townhouse Building 1000	Apt 1004	Bathroom Sink 2nd floor	2	A	0.16	3/16/17										
PbTWN	Townhouse Building 1000	Apt 1004	Bathroom Sink 2nd floor	2	B	0.16	3/16/17										
PbTWN	Townhouse Building 1000	Apt 1004	Bathroom Sink 3rd floor	3	A	0.16	3/16/17										
PbTWN	Townhouse Building 1000	Apt 1004	Bathroom Sink 3rd floor	3	B	0.16	3/16/17										

Sample ID	Building	Room/Location	Sample Location	Sample No.	Draw	Result (ug/L)	Date	Draw	Result (ug/L)	Date	Draw	Result (ug/L)	Date	Draw	Result (ug/L)	Date	Notes
PbTWN	Townhouse Building 1000	Apt 1005	Kitchen Sink	1	A	2.2	7/27/17										
PbTWN	Townhouse Building 1000	Apt 1005	Kitchen Sink	1	B	0.23	7/27/17										
PbTWN	Townhouse Building 1000	Apt 1005	Bathroom Sink 2nd floor	2	A	0.16	3/16/17										
PbTWN	Townhouse Building 1000	Apt 1005	Bathroom Sink 2nd floor	2	B	0.16	3/16/17										
PbTWN	Townhouse Building 1000	Apt 1005	Bathroom Sink 3rd floor	3	A	0.16	3/16/17										
PbTWN	Townhouse Building 1000	Apt 1005	Bathroom Sink 3rd floor	3	B	0.16	3/16/17										
PbTWN	Townhouse Building 1000	Apt 1006KN	Sink	2	A	2.2	1/4/17										
PbTWN	Townhouse Building 1000	Apt 1006KN	Sink	2	B	24.5	1/4/17										The two samples directly below this one are the second [A and B] samples for the kitchen sink in Townhouse 1006.
PbTWN	Townhouse Building 1000	Apt 1006	Kitchen Sink	1	A	2.8	7/27/17										
PbTWN	Townhouse Building 1000	Apt 1006	Kitchen Sink	1	B	0.43	7/27/17										
PbTWN	Townhouse Building 1000	Apt 1006	Bathroom Sink 2nd floor	2	A	0.16	3/16/17										
PbTWN	Townhouse Building 1000	Apt 1006	Bathroom Sink 2nd floor	2	B	0.16	3/16/17										
PbTWN	Townhouse Building 1000	Apt 1006	Bathroom Sink 3rd floor	3	A	0.16	3/16/17										
PbTWN	Townhouse Building 1000	Apt 1006	Bathroom Sink 3rd floor	3	B	0.16	3/16/17										
PbTWN	Townhouse Building 1000	Apt 1007	Kitchen Sink	1	A	3.5	7/27/17										
PbTWN	Townhouse Building 1000	Apt 1007	Kitchen Sink	1	B	0.25	7/27/17										
PbTWN	Townhouse Building 1000	Apt 1007	Bathroom Sink 2nd floor	2	A	0.16	3/16/17										
PbTWN	Townhouse Building 1000	Apt 1007	Bathroom Sink 2nd floor	2	B	0.16	3/16/17										
PbTWN	Townhouse Building 1000	Apt 1007	Bathroom Sink 3rd floor	3	A	0.16	3/16/17										
PbTWN	Townhouse Building 1000	Apt 1007	Bathroom Sink 3rd floor	3	B	0.16	3/16/17										
PbTWN	Townhouse Building 1000	Apt 1008	Kitchen Sink	1	A	2.5	7/27/17										
PbTWN	Townhouse Building 1000	Apt 1008	Kitchen Sink	1	B	0.17	7/27/17										
PbTWN	Townhouse Building 1000	Apt 1008	Bathroom Sink 2nd floor	2	A	0.16	3/16/17	C	1.7	8/1/17							
PbTWN	Townhouse Building 1000	Apt 1008	Bathroom Sink 2nd floor	2	B	0.16	3/16/17	D	0.16	8/1/17							
PbTWN	Townhouse Building 1000	Apt 1008	Bathroom Sink 3rd floor	3	A	0.16	3/16/17										
PbTWN	Townhouse Building 1000	Apt 1008	Bathroom Sink 3rd floor	3	B	0.16	3/16/17										
PbTWN	Townhouse Building 1100	Apt 1101	Kitchen Sink	1	A	2.2	7/27/17										
PbTWN	Townhouse Building 1100	Apt 1101	Kitchen Sink	1	B	0.47	7/27/17										
PbTWN	Townhouse Building 1100	Apt 1101	Bathroom Sink 2nd floor	2	A	0.16	3/16/17										
PbTWN	Townhouse Building 1100	Apt 1101	Bathroom Sink 2nd floor	2	B	0.16	3/16/17										
PbTWN	Townhouse Building 1100	Apt 1101	Bathroom Sink 3rd floor	3	A	0.16	3/16/17										
PbTWN	Townhouse Building 1100	Apt 1101	Bathroom Sink 3rd floor	3	B	0.16	3/16/17										
PbTWN	Townhouse Building 1100	Apt 1102KN	Sink	2	A	0.56	1/4/17										
PbTWN	Townhouse Building 1100	Apt 1102KN	Sink	2	B	0.4	1/4/17										
PbTWN	Townhouse Building 1100	Apt 1102	Kitchen Sink	1	A	3.4	7/27/17										
PbTWN	Townhouse Building 1100	Apt 1102	Kitchen Sink	1	B	0.22	7/27/17										
PbTWN	Townhouse Building 1100	Apt 1102	Bathroom Sink 2nd floor	2	A	0.16	3/16/17										
PbTWN	Townhouse Building 1100	Apt 1102	Bathroom Sink 2nd floor	2	B	0.16	3/16/17										
PbTWN	Townhouse Building 1100	Apt 1102	Bathroom Sink 3rd floor	3	A	0.16	3/16/17										
PbTWN	Townhouse Building 1100	Apt 1102	Bathroom Sink 3rd floor	3	B	0.16	3/16/17										
PbTWN	Townhouse Building 1100	Apt 1103	Kitchen Sink	1	A	2.8	7/27/17										
PbTWN	Townhouse Building 1100	Apt 1103	Kitchen Sink	1	B	0.16	7/27/17										
PbTWN	Townhouse Building 1100	Apt 1103	Bathroom Sink 2nd floor	2	A	0.16	3/16/17	C	1.1	8/1/17							
PbTWN	Townhouse Building 1100	Apt 1103	Bathroom Sink 2nd floor	2	B	0.16	3/16/17	D	0.16	8/1/17							
PbTWN	Townhouse Building 1100	Apt 1103	Bathroom Sink 3rd floor	3	A	0.16	3/16/17										
PbTWN	Townhouse Building 1100	Apt 1103	Bathroom Sink 3rd floor	3	B	0.16	3/16/17										
PbTWN	Townhouse Building 1100	Apt 1104	Kitchen Sink	1	A	2.3	7/27/17										
PbTWN	Townhouse Building 1100	Apt 1104	Kitchen Sink	1	B	0.24	7/27/17										
PbTWN	Townhouse Building 1100	Apt 1104	Bathroom Sink 2nd floor	2	A	0.16	3/16/17										
PbTWN	Townhouse Building 1100	Apt 1104	Bathroom Sink 2nd floor	2	B	0.16	3/16/17										
PbTWN	Townhouse Building 1100	Apt 1104	Bathroom Sink 3rd floor	3	A	0.16	3/16/17										
PbTWN	Townhouse Building 1100	Apt 1104	Bathroom Sink 3rd floor	3	B	0.16	3/16/17										
PbTWN	Townhouse Building 1100	Apt 1105	Kitchen Sink	1	A	3.3	7/27/17										
PbTWN	Townhouse Building 1100	Apt 1105	Kitchen Sink	1	B	0.21	7/27/17										
PbTWN	Townhouse Building 1100	Apt 1105	Bathroom Sink 2nd floor	2	A	0.16	3/16/17										

Sample ID	Building	Room/Location	Sample Location	Sample No.	Draw	Result (ug/L)	Date	Draw	Result (ug/L)	Date	Draw	Result (ug/L)	Date	Draw	Result (ug/L)	Date	Notes
PbTWN	Townhouse Building 1100	Apt 1105	Bathroom Sink 2nd floor	2	B	0.16	3/16/17										
PbTWN	Townhouse Building 1100	Apt 1105	Bathroom Sink 3rd floor	3	A	0.16	3/16/17										
PbTWN	Townhouse Building 1100	Apt 1105	Bathroom Sink 3rd floor	3	B	0.16	3/16/17										
PbTWN	Townhouse Building 1100	Apt 1106	Kitchen Sink	1	A	2.9	7/27/17	C	2.7	8/1/17							
PbTWN	Townhouse Building 1100	Apt 1106	Kitchen Sink	1	B	0.2	7/27/17	D	0.54	8/1/17							
PbTWN	Townhouse Building 1100	Apt 1106	Bathroom Sink 2nd floor	2	A	0.16	3/16/17										
PbTWN	Townhouse Building 1100	Apt 1106	Bathroom Sink 2nd floor	2	B	0.16	3/16/17										
PbTWN	Townhouse Building 1100	Apt 1106	Bathroom Sink 3rd floor	3	A	0.16	3/16/17										
PbTWN	Townhouse Building 1100	Apt 1106	Bathroom Sink 3rd floor	3	B	0.16	3/16/17										
PbTWN	Townhouse Building 1200	Apt 1201KN	Sink	2	A	0.88	1/4/17										
PbTWN	Townhouse Building 1200	Apt 1201KN	Sink	2	B	75.1	1/4/17										The two samples directly below this one are the second [A and B] samples for the kitchen sink in Townhouse 1201.
PbTWN	Townhouse Building 1200	Apt 1201	Kitchen Sink	1	A	2.4	7/27/17										
PbTWN	Townhouse Building 1200	Apt 1201	Kitchen Sink	1	B	0.16	7/27/17										
PbTWN	Townhouse Building 1200	Apt 1201	Bathroom Sink 2nd floor	2	A	0.16	3/16/17										
PbTWN	Townhouse Building 1200	Apt 1201	Bathroom Sink 2nd floor	2	B	0.16	3/16/17										
PbTWN	Townhouse Building 1200	Apt 1201	Bathroom Sink 3rd floor	3	A	0.16	3/16/17										
PbTWN	Townhouse Building 1200	Apt 1201	Bathroom Sink 3rd floor	3	B	0.16	3/16/17										
PbTWN	Townhouse Building 1200	Apt 1202	Kitchen Sink	1	A	2.6	7/27/17										
PbTWN	Townhouse Building 1200	Apt 1202	Kitchen Sink	1	B	0.16	7/27/17										
PbTWN	Townhouse Building 1200	Apt 1202	Bathroom Sink 2nd floor	2	A	0.16	3/16/17										
PbTWN	Townhouse Building 1200	Apt 1202	Bathroom Sink 2nd floor	2	B	0.16	3/16/17										
PbTWN	Townhouse Building 1200	Apt 1202	Bathroom Sink 3rd floor	3	A	0.16	3/16/17										
PbTWN	Townhouse Building 1200	Apt 1202	Bathroom Sink 3rd floor	3	B	0.16	3/16/17										
PbTWN	Townhouse Building 1200	Apt 1203	Kitchen Sink	1	A	0.55	7/27/17										
PbTWN	Townhouse Building 1200	Apt 1203	Kitchen Sink	1	B	0.33	7/27/17										
PbTWN	Townhouse Building 1200	Apt 1203	Bathroom Sink 2nd floor	2	A	0.16	3/16/17										
PbTWN	Townhouse Building 1200	Apt 1203	Kitchen Sink	1	B	0.33	7/27/17										
PbTWN	Townhouse Building 1200	Apt 1203	Bathroom Sink 2nd floor	2	A	0.16	3/16/17										
PbTWN	Townhouse Building 1200	Apt 1203	Bathroom Sink 2nd floor	2	B	0.16	3/16/17										
PbTWN	Townhouse Building 1200	Apt 1203	Bathroom Sink 3rd floor	3	A	0.16	3/16/17										
PbTWN	Townhouse Building 1200	Apt 1203	Bathroom Sink 3rd floor	3	B	0.16	3/16/17										
PbTWN	Townhouse Building 1200	Apt 1204	Kitchen Sink	1	A	2.6	7/27/17										
PbTWN	Townhouse Building 1200	Apt 1204	Kitchen Sink	1	B	0.31	7/27/17										
PbTWN	Townhouse Building 1200	Apt 1204	Bathroom Sink 2nd floor	2	A	0.16	3/16/17	C	0.57	8/1/17							
PbTWN	Townhouse Building 1200	Apt 1204	Bathroom Sink 2nd floor	2	B	0.16	3/16/17	D	0.16	8/1/17							
PbTWN	Townhouse Building 1200	Apt 1204	Bathroom Sink 3rd floor	3	A	0.16	3/16/17										
PbTWN	Townhouse Building 1200	Apt 1204	Bathroom Sink 3rd floor	3	B	0.16	3/16/17										
PbTWN	Townhouse Building 1200	Apt 1205	Kitchen Sink	1	A	1.6	7/27/17										
PbTWN	Townhouse Building 1200	Apt 1205	Kitchen Sink	1	B	0.16	7/27/17										
PbTWN	Townhouse Building 1200	Apt 1205	Bathroom Sink 2nd floor	2	A	0.16	3/16/17										
PbTWN	Townhouse Building 1200	Apt 1205	Bathroom Sink 2nd floor	2	B	0.16	3/16/17										
PbTWN	Townhouse Building 1200	Apt 1205	Bathroom Sink 3rd floor	3	A	0.16	3/16/17										
PbTWN	Townhouse Building 1200	Apt 1205	Bathroom Sink 3rd floor	3	B	0.16	3/16/17										
PbTWN	Townhouse Building 1200	Apt 1206	Kitchen Sink	1	A	1.1	7/27/17										
PbTWN	Townhouse Building 1200	Apt 1206	Kitchen Sink	1	B	0.16	7/27/17										
PbTWN	Townhouse Building 1200	Apt 1206	Bathroom Sink 2nd floor	2	A	0.16	3/16/17										
PbTWN	Townhouse Building 1200	Apt 1206	Bathroom Sink 2nd floor	2	B	0.16	3/16/17										
PbTWN	Townhouse Building 1200	Apt 1206	Bathroom Sink 3rd floor	3	A	0.16	3/16/17										
PbTWN	Townhouse Building 1200	Apt 1206	Bathroom Sink 3rd floor	3	B	0.16	3/16/17										
PbTWN	Townhouse Building 1200	Apt 1207	Kitchen Sink	1	A	3.5	7/27/17										
PbTWN	Townhouse Building 1200	Apt 1207	Kitchen Sink	1	B	0.31	7/27/17										
PbTWN	Townhouse Building 1200	Apt 1207	Bathroom Sink 2nd floor	2	A	0.16	3/16/17										
PbTWN	Townhouse Building 1200	Apt 1207	Bathroom Sink 2nd floor	2	B	0.16	3/16/17										
PbTWN	Townhouse Building 1200	Apt 1207	Bathroom Sink 3rd floor	3	A	0.16	3/16/17	C	2.1	8/1/17							
PbTWN	Townhouse Building 1200	Apt 1207	Bathroom Sink 3rd floor	3	B	0.16	3/16/17	D	0.16	8/1/17							
PbTWN	Townhouse Building 1200	Apt 1208	Kitchen Sink	1	A	2.4	7/27/17										
PbTWN	Townhouse Building 1200	Apt 1208	Kitchen Sink	1	B	0.16	7/27/17										

Sample ID	Building	Room/Location	Sample Location	Sample No.	Draw	Result (ug/L)	Date	Draw	Result (ug/L)	Date	Draw	Result (ug/L)	Date	Draw	Result (ug/L)	Date	Notes
PbTWN	Townhouse Building 1200	Apt 1208	Bathroom Sink 2nd floor	2	A	0.16	3/16/17										
PbTWN	Townhouse Building 1200	Apt 1208	Bathroom Sink 2nd floor	2	B	0.16	3/16/17										
PbTWN	Townhouse Building 1200	Apt 1208	Bathroom Sink 3rd floor	3	A	0.16	3/16/17										
PbTWN	Townhouse Building 1200	Apt 1208	Bathroom Sink 3rd floor	3	B	0.16	3/16/17										
PbTWN	Townhouse Building 1300	Apt 1301KN	Sink	2	A	0.4	1/4/17										
PbTWN	Townhouse Building 1300	Apt 1301KN	Sink	2	B	11.5	1/4/17										
PbTWN	Townhouse Building 1300	Apt 1301	Kitchen Sink	1	A	1.9	7/27/17										
PbTWN	Townhouse Building 1300	Apt 1301	Kitchen Sink	1	B	0.16	7/27/17										
PbTWN	Townhouse Building 1300	Apt 1301	Bathroom Sink 2nd floor	2	A	0.16	3/16/17										
PbTWN	Townhouse Building 1300	Apt 1301	Bathroom Sink 2nd floor	2	B	0.16	3/16/17										
PbTWN	Townhouse Building 1300	Apt 1301	Bathroom Sink 3rd floor	3	A	0.16	3/16/17										
PbTWN	Townhouse Building 1300	Apt 1301	Bathroom Sink 3rd floor	3	B	0.16	3/16/17										
PbTWN	Townhouse Building 1300	Apt 1302	Kitchen Sink	1	A	0.76	7/27/17										
PbTWN	Townhouse Building 1300	Apt 1302	Kitchen Sink	1	B	0.16	7/27/17										
PbTWN	Townhouse Building 1300	Apt 1302	Bathroom Sink 2nd floor	2	A	0.16	3/16/17										
PbTWN	Townhouse Building 1300	Apt 1302	Bathroom Sink 2nd floor	2	B	0.16	3/16/17										
PbTWN	Townhouse Building 1300	Apt 1302	Bathroom Sink 3rd floor	3	A	0.16	3/16/17	C	2.9	8/1/17							
PbTWN	Townhouse Building 1300	Apt 1302	Bathroom Sink 3rd floor	3	B	0.16	3/16/17	D	0.21	8/1/17							
PbTWN	Townhouse Building 1300	Apt 1303	Kitchen Sink	1	A	3.4	7/27/17										
PbTWN	Townhouse Building 1300	Apt 1303	Kitchen Sink	1	B	0.2	7/27/17										
PbTWN	Townhouse Building 1300	Apt 1303	Bathroom Sink 2nd floor	2	A	0.16	3/16/17										
PbTWN	Townhouse Building 1300	Apt 1303	Bathroom Sink 2nd floor	2	B	0.16	3/16/17										
PbTWN	Townhouse Building 1300	Apt 1303	Bathroom Sink 3rd floor	3	A	0.16	3/16/17										
PbTWN	Townhouse Building 1300	Apt 1303	Bathroom Sink 3rd floor	3	B	0.16	3/16/17										
PbTWN	Townhouse Building 1300	Apt 1304	Kitchen Sink	1	A	2.7	7/27/17										
PbTWN	Townhouse Building 1300	Apt 1304	Kitchen Sink	1	B	0.16	7/27/17										
PbTWN	Townhouse Building 1300	Apt 1304	Bathroom Sink 2nd floor	2	A	0.16	3/16/17	C	2.1	8/1/17							
PbTWN	Townhouse Building 1300	Apt 1304	Bathroom Sink 2nd floor	2	B	0.16	3/16/17	D	0.18	8/1/17							
PbTWN	Townhouse Building 1300	Apt 1304	Bathroom Sink 3rd floor	3	A	0.16	3/16/17										
PbTWN	Townhouse Building 1300	Apt 1304	Bathroom Sink 3rd floor	3	B	0.16	3/16/17										
PbTWN	Townhouse Building 1300	Apt 1305	Kitchen Sink	1	A	4.2	7/27/17										
PbTWN	Townhouse Building 1300	Apt 1305	Kitchen Sink	1	B	3.9	7/27/17										
PbTWN	Townhouse Building 1300	Apt 1305	Bathroom Sink 2nd floor	2	A	0.16	3/16/17										
PbTWN	Townhouse Building 1300	Apt 1305	Bathroom Sink 2nd floor	2	B	0.16	3/16/17										
PbTWN	Townhouse Building 1300	Apt 1305	Bathroom Sink 3rd floor	3	A	0.16	3/16/17										
PbTWN	Townhouse Building 1300	Apt 1305	Bathroom Sink 3rd floor	3	B	0.16	3/16/17										
PbTWN	Townhouse Building 1300	Apt 1306	Kitchen Sink	1	A	4.7	7/27/17										
PbTWN	Townhouse Building 1300	Apt 1306	Kitchen Sink	1	B	0.16	7/27/17										
PbTWN	Townhouse Building 1300	Apt 1306	Bathroom Sink 2nd floor	2	A	0.16	3/16/17										
PbTWN	Townhouse Building 1300	Apt 1306	Bathroom Sink 2nd floor	2	B	0.16	3/16/17										
PbTWN	Townhouse Building 1300	Apt 1306	Bathroom Sink 3rd floor	3	A	0.16	3/16/17										
PbTWN	Townhouse Building 1300	Apt 1306	Bathroom Sink 3rd floor	3	B	0.16	3/16/17										
PbTWN	Townhouse Building 1300	Apt 1307	Kitchen Sink	1	A	1.9	7/27/17										
PbTWN	Townhouse Building 1300	Apt 1307	Kitchen Sink	1	B	0.42	7/27/17										
PbTWN	Townhouse Building 1300	Apt 1307	Bathroom Sink 2nd floor	2	A	0.16	3/16/17										
PbTWN	Townhouse Building 1300	Apt 1307	Bathroom Sink 2nd floor	2	B	0.16	3/16/17										
PbTWN	Townhouse Building 1300	Apt 1307	Bathroom Sink 3rd floor	3	A	0.16	3/16/17										
PbTWN	Townhouse Building 1300	Apt 1307	Bathroom Sink 3rd floor	3	B	0.16	3/16/17										
PbTWN	Townhouse Building 1400	Apt 1401	Kitchen Sink	1	A	4.3	7/27/17										
PbTWN	Townhouse Building 1400	Apt 1401	Kitchen Sink	1	B	0.16	7/27/17										
PbTWN	Townhouse Building 1400	Apt 1401	Bathroom Sink 2nd floor	2	A	0.16	3/16/17										
PbTWN	Townhouse Building 1400	Apt 1401	Bathroom Sink 2nd floor	2	B	0.16	3/16/17										
PbTWN	Townhouse Building 1400	Apt 1401	Bathroom Sink 3rd floor	3	A	0.16	3/16/17										
PbTWN	Townhouse Building 1400	Apt 1401	Bathroom Sink 3rd floor	3	B	0.16	3/16/17										
PbTWN	Townhouse Building 1400	Apt 1402KN	Sink	2	A	1.1	1/4/17										

Sample ID	Building	Room/Location	Sample Location	Sample No.	Draw	Result (ug/L)	Date	Draw	Result (ug/L)	Date	Draw	Result (ug/L)	Date	Draw	Result (ug/L)	Date	Notes
PbTWN	Townhouse Building 1400	Apt 1402KN	Sink	2	B	0.74	1/4/17										
PbTWN	Townhouse Building 1400	Apt 1402	Kitchen Sink	1	A	2.5	7/27/17										
PbTWN	Townhouse Building 1400	Apt 1402	Kitchen Sink	1	B	0.16	7/27/17										
PbTWN	Townhouse Building 1400	Apt 1402	Bathroom Sink 2nd floor	2	A	0.16	3/16/17	C	1.2	8/1/17							
PbTWN	Townhouse Building 1400	Apt 1402	Bathroom Sink 2nd floor	2	B	0.16	3/16/17	D	3.6	8/1/17							
PbTWN	Townhouse Building 1400	Apt 1402	Bathroom Sink 3rd floor	3	A	0.16	3/16/17										
PbTWN	Townhouse Building 1400	Apt 1402	Bathroom Sink 3rd floor	3	B	0.16	3/16/17										
PbTWN	Townhouse Building 1400	Apt 1403	Kitchen Sink	1	A	2	7/27/17										
PbTWN	Townhouse Building 1400	Apt 1403	Kitchen Sink	1	B	0.16	7/27/17										
PbTWN	Townhouse Building 1400	Apt 1403	Bathroom Sink 2nd floor	2	A	0.16	3/16/17										
PbTWN	Townhouse Building 1400	Apt 1403	Bathroom Sink 2nd floor	2	B	0.16	3/16/17										
PbTWN	Townhouse Building 1400	Apt 1403	Bathroom Sink 3rd floor	3	A	0.16	3/16/17										
PbTWN	Townhouse Building 1400	Apt 1403	Bathroom Sink 3rd floor	3	B	0.16	3/16/17										
PbTWN	Townhouse Building 1400	Apt 1404	Kitchen Sink	1	A	1.4	7/27/17										
PbTWN	Townhouse Building 1400	Apt 1404	Kitchen Sink	1	B	0.16	7/27/17										
PbTWN	Townhouse Building 1400	Apt 1404	Bathroom Sink 2nd floor	2	A	0.16	3/16/17										
PbTWN	Townhouse Building 1400	Apt 1404	Bathroom Sink 2nd floor	2	B	0.16	3/16/17										
PbTWN	Townhouse Building 1400	Apt 1404	Bathroom Sink 3rd floor	3	A	0.16	3/16/17										
PbTWN	Townhouse Building 1400	Apt 1404	Bathroom Sink 3rd floor	3	B	0.16	3/16/17										
PbTWN	Townhouse Building 1400	Apt 1405	Kitchen Sink	1	A	2.2	7/27/17										
PbTWN	Townhouse Building 1400	Apt 1405	Kitchen Sink	1	B	0.16	7/27/17										
PbTWN	Townhouse Building 1400	Apt 1405	Bathroom Sink 2nd floor	2	A	0.16	3/16/17										
PbTWN	Townhouse Building 1400	Apt 1405	Bathroom Sink 2nd floor	2	B	0.16	3/16/17										
PbTWN	Townhouse Building 1400	Apt 1405	Bathroom Sink 3rd floor	3	A	0.16	3/16/17	C	1.7	8/1/17							
PbTWN	Townhouse Building 1400	Apt 1405	Bathroom Sink 3rd floor	3	B	0.16	3/16/17	D	0.16	8/1/17							
PbTWN	Townhouse Building 1400	Apt 1406	Kitchen Sink	1	A	1.3	7/27/17										
PbTWN	Townhouse Building 1400	Apt 1406	Kitchen Sink	1	B	0.25	7/27/17										
PbTWN	Townhouse Building 1400	Apt 1406	Bathroom Sink 2nd floor	2	A	0.16	3/16/17										
PbTWN	Townhouse Building 1400	Apt 1406	Bathroom Sink 2nd floor	2	B	0.16	3/16/17										
PbTWN	Townhouse Building 1400	Apt 1406	Bathroom Sink 3rd floor	3	A	0.16	3/16/17										
PbTWN	Townhouse Building 1400	Apt 1406	Bathroom Sink 3rd floor	3	B	0.16	3/16/17										
PbTWN	Townhouse Building 1400	Apt 1407	Kitchen Sink	1	A	2.4	7/27/17										
PbTWN	Townhouse Building 1400	Apt 1407	Kitchen Sink	1	B	0.16	7/27/17										
PbTWN	Townhouse Building 1400	Apt 1407	Bathroom Sink 2nd floor	2	A	0.16	3/16/17										
PbTWN	Townhouse Building 1400	Apt 1407	Bathroom Sink 2nd floor	2	B	0.16	3/16/17										
PbTWN	Townhouse Building 1400	Apt 1407	Bathroom Sink 3rd floor	3	A	0.16	3/16/17										
PbTWN	Townhouse Building 1400	Apt 1407	Bathroom Sink 3rd floor	3	B	0.16	3/16/17										
PbTWN	Townhouse Building 1500	Apt 1501KN	Sink	2	A	0.63	1/4/17										
PbTWN	Townhouse Building 1500	Apt 1501KN	Sink	2	B	0.24	1/4/17										
PbTWN	Townhouse Building 1500	Apt 1501	Kitchen Sink	1	A			C	0.16	4/27/17							
PbTWN	Townhouse Building 1500	Apt 1501	Kitchen Sink	1	B			D	0.16	4/27/17							
PbTWN	Townhouse Building 1500	Apt 1501	Bathroom Sink 2nd floor	2	A	0.16	3/16/17	C	1.7	8/1/17							
PbTWN	Townhouse Building 1500	Apt 1501	Bathroom Sink 2nd floor	2	B	0.16	3/16/17	D	0.17	8/1/17							
PbTWN	Townhouse Building 1500	Apt 1501	Bathroom Sink 3rd floor	3	A	0.16	3/16/17										
PbTWN	Townhouse Building 1500	Apt 1501	Bathroom Sink 3rd floor	3	B	0.16	3/16/17										
PbTWN	Townhouse Building 1500	Apt 1502	Kitchen Sink	1	A			C	0.16	4/27/17							
PbTWN	Townhouse Building 1500	Apt 1502	Kitchen Sink	1	B			D	0.16	4/27/17							
PbTWN	Townhouse Building 1500	Apt 1502	Bathroom Sink 2nd floor	2	A	0.16	3/16/17										
PbTWN	Townhouse Building 1500	Apt 1502	Bathroom Sink 2nd floor	2	B	0.16	3/16/17										
PbTWN	Townhouse Building 1500	Apt 1502	Bathroom Sink 3rd floor	3	A	0.16	3/16/17										
PbTWN	Townhouse Building 1500	Apt 1502	Bathroom Sink 3rd floor	3	B	0.16	3/16/17										
PbTWN	Townhouse Building 1500	Apt 1503	Kitchen Sink	1	A			C	0.16	4/27/17							
PbTWN	Townhouse Building 1500	Apt 1503	Kitchen Sink	1	B			D	0.16	4/27/17							
PbTWN	Townhouse Building 1500	Apt 1503	Bathroom Sink 2nd floor	2	A	0.16	3/16/17										
PbTWN	Townhouse Building 1500	Apt 1503	Bathroom Sink 2nd floor	2	B	0.16	3/16/17										
PbTWN	Townhouse Building 1500	Apt 1503	Bathroom Sink 3rd floor	3	A	0.16	3/16/17										

Sample ID	Building	Room/Location	Sample Location	Sample No.	Draw	Result (ug/L)	Date	Draw	Result (ug/L)	Date	Draw	Result (ug/L)	Date	Draw	Result (ug/L)	Date	Notes
PbTWN	Townhouse Building 1500	Apt 1503	Bathroom Sink 3rd floor	3	B	0.16	3/16/17										
PbTWN	Townhouse Building 1500	Apt 1504	Kitchen Sink	1	A			C	0.16	4/27/17							
PbTWN	Townhouse Building 1500	Apt 1504	Kitchen Sink	1	B			D	0.16	4/27/17							
PbTWN	Townhouse Building 1500	Apt 1504	Bathroom Sink 2nd floor	2	A	0.16	3/16/17										
PbTWN	Townhouse Building 1500	Apt 1504	Bathroom Sink 2nd floor	2	B	0.16	3/16/17										
PbTWN	Townhouse Building 1500	Apt 1504	Bathroom Sink 3rd floor	3	A	0.16	3/16/17										
PbTWN	Townhouse Building 1500	Apt 1504	Bathroom Sink 3rd floor	3	B	0.16	3/16/17										
PbTWN	Townhouse Building 1500	Apt 1505	Kitchen Sink	1	A			C	0.16	4/27/17	E	4.5	8/1/17				
PbTWN	Townhouse Building 1500	Apt 1505	Kitchen Sink	1	B			D	0.16	4/27/17	F	0.16	8/1/17				
PbTWN	Townhouse Building 1500	Apt 1505	Bathroom Sink 2nd floor	2	A	0.16	3/16/17										
PbTWN	Townhouse Building 1500	Apt 1505	Bathroom Sink 2nd floor	2	B	0.16	3/16/17										
PbTWN	Townhouse Building 1500	Apt 1505	Bathroom Sink 3rd floor	3	A	0.16	3/16/17										
PbTWN	Townhouse Building 1500	Apt 1505	Bathroom Sink 3rd floor	3	B	0.16	3/16/17										
PbTWN	Townhouse Building 1500	Apt 1506	Kitchen Sink	1	A			C	0.16	4/27/17							
PbTWN	Townhouse Building 1500	Apt 1506	Kitchen Sink	1	B			D	0.16	4/27/17							
PbTWN	Townhouse Building 1500	Apt 1506	Bathroom Sink 2nd floor	2	A	0.16	3/16/17										
PbTWN	Townhouse Building 1500	Apt 1506	Bathroom Sink 2nd floor	2	B	0.16	3/16/17										
PbTWN	Townhouse Building 1500	Apt 1506	Bathroom Sink 3rd floor	3	A	0.16	3/16/17										
PbTWN	Townhouse Building 1500	Apt 1506	Bathroom Sink 3rd floor	3	B	0.16	3/16/17										
PbTWN	Townhouse Building 1600	Apt 1601	Kitchen Sink	1	A			C	0.16	4/27/17							
PbTWN	Townhouse Building 1600	Apt 1601	Kitchen Sink	1	B			D	0.16	4/27/17							
PbTWN	Townhouse Building 1600	Apt 1601	Bathroom Sink 2nd floor	2	A	0.16	3/16/17										
PbTWN	Townhouse Building 1600	Apt 1601	Bathroom Sink 2nd floor	2	B	0.16	3/16/17										
PbTWN	Townhouse Building 1600	Apt 1601	Bathroom Sink 3rd floor	3	A	0.16	3/16/17	C	2.8	8/1/17							
PbTWN	Townhouse Building 1600	Apt 1601	Bathroom Sink 3rd floor	3	B	0.16	3/16/17	D	0.2	8/1/17							
PbTWN	Townhouse Building 1600	Apt 1602	Kitchen Sink	1	A			C	0.16	4/27/17	E	3.3	8/1/17				
PbTWN	Townhouse Building 1600	Apt 1602	Kitchen Sink	1	B			D	0.16	4/27/17	F	0.34	8/1/17				
PbTWN	Townhouse Building 1600	Apt 1602	Bathroom Sink 2nd floor	2	A	0.16	3/16/17										
PbTWN	Townhouse Building 1600	Apt 1602	Bathroom Sink 2nd floor	2	B	0.16	3/16/17										
PbTWN	Townhouse Building 1600	Apt 1602	Bathroom Sink 3rd floor	3	A	0.16	3/16/17										
PbTWN	Townhouse Building 1600	Apt 1602	Bathroom Sink 3rd floor	3	B	0.16	3/16/17										
PbTWN	Townhouse Building 1600	Apt 1603KN	Sink	2	A	1	1/4/17										
PbTWN	Townhouse Building 1600	Apt 1603KN	Sink	2	B	46.7	1/4/17										The two samples directly below this one are the second [C and D] samples for the kitchen sink in Townhouse 1603.
PbTWN	Townhouse Building 1600	Apt 1603	Kitchen Sink	1	A			C	0.16	4/27/17							
PbTWN	Townhouse Building 1600	Apt 1603	Kitchen Sink	1	B			D	0.16	4/27/17							
PbTWN	Townhouse Building 1600	Apt 1603	Bathroom Sink 2nd floor	2	A	0.16	3/16/17										
PbTWN	Townhouse Building 1600	Apt 1603	Bathroom Sink 2nd floor	2	B	0.16	3/16/17										
PbTWN	Townhouse Building 1600	Apt 1603	Bathroom Sink 3rd floor	3	A	0.16	3/16/17										
PbTWN	Townhouse Building 1600	Apt 1603	Bathroom Sink 3rd floor	3	B	0.16	3/16/17										
PbTWN	Townhouse Building 1600	Apt 1604	Kitchen Sink	1	A			C	0.16	4/27/17							
PbTWN	Townhouse Building 1600	Apt 1604	Kitchen Sink	1	B			D	0.16	4/27/17							
PbTWN	Townhouse Building 1600	Apt 1604	Bathroom Sink 2nd floor	2	A	0.16	3/16/17										
PbTWN	Townhouse Building 1600	Apt 1604	Bathroom Sink 2nd floor	2	B	0.16	3/16/17										
PbTWN	Townhouse Building 1600	Apt 1604	Bathroom Sink 3rd floor	3	A	0.16	3/16/17										
PbTWN	Townhouse Building 1600	Apt 1604	Bathroom Sink 3rd floor	3	B	0.16	3/16/17										
PbTWN	Townhouse Building 1600	Apt 1605	Kitchen Sink	1	A			C	0.16	4/27/17							
PbTWN	Townhouse Building 1600	Apt 1605	Kitchen Sink	1	B			D	0.16	4/27/17							
PbTWN	Townhouse Building 1600	Apt 1605	Bathroom Sink 2nd floor	2	A	0.16	3/16/17										
PbTWN	Townhouse Building 1600	Apt 1605	Bathroom Sink 2nd floor	2	B	0.16	3/16/17										
PbTWN	Townhouse Building 1600	Apt 1605	Bathroom Sink 3rd floor	3	A	0.16	3/16/17										
PbTWN	Townhouse Building 1600	Apt 1605	Bathroom Sink 3rd floor	3	B	0.16	3/16/17										
PbTWN	Townhouse Building 1600	Apt 1606	Kitchen Sink	1	A			C	0.16	4/27/17							
PbTWN	Townhouse Building 1600	Apt 1606	Kitchen Sink	1	B			D	0.16	4/27/17							
PbTWN	Townhouse Building 1600	Apt 1606	Bathroom Sink 2nd floor	2	A	0.16	3/16/17	C	2.8	8/1/17							
PbTWN	Townhouse Building 1600	Apt 1606	Bathroom Sink 2nd floor	2	B	0.16	3/16/17	D	0.25	8/1/17							

Sample ID	Building	Room/Location	Sample Location	Sample No.	Draw	Result (ug/L)	Date	Draw	Result (ug/L)	Date	Draw	Result (ug/L)	Date	Draw	Result (ug/L)	Date	Notes
PbTWN	Townhouse Building 1600	Apt 1606	Bathroom Sink 3rd floor	3	A	0.16	3/16/17										
PbTWN	Townhouse Building 1600	Apt 1606	Bathroom Sink 3rd floor	3	B	0.16	3/16/17										
PbTWN	Townhouse Building 1600	Apt 1607	Kitchen Sink	1	A			C	0.16	4/27/17							
PbTWN	Townhouse Building 1600	Apt 1607	Kitchen Sink	1	B			D	0.16	4/27/17							
PbTWN	Townhouse Building 1600	Apt 1607	Bathroom Sink 2nd floor	2	A	0.16	3/16/17										
PbTWN	Townhouse Building 1600	Apt 1607	Bathroom Sink 2nd floor	2	B	0.16	3/16/17										
PbTWN	Townhouse Building 1600	Apt 1607	Bathroom Sink 3rd floor	3	A	0.16	3/16/17										
PbTWN	Townhouse Building 1600	Apt 1607	Bathroom Sink 3rd floor	3	B	0.16	3/16/17										
PbTWN	Townhouse Building 1700	Apt 1701	Kitchen Sink	1	A	1.9	7/27/17										
PbTWN	Townhouse Building 1700	Apt 1701	Kitchen Sink	1	B	0.16	7/27/17										
PbTWN	Townhouse Building 1700	Apt 1701	Bathroom Sink 2nd floor	2	A	0.16	3/16/17										
PbTWN	Townhouse Building 1700	Apt 1701	Bathroom Sink 2nd floor	2	B	0.16	3/16/17										
PbTWN	Townhouse Building 1700	Apt 1701	Bathroom Sink 3rd floor	3	A	0.16	3/16/17	C	1.2	8/1/17							
PbTWN	Townhouse Building 1700	Apt 1701	Bathroom Sink 3rd floor	3	B	0.16	3/16/17	D	0.16	8/1/17							
PbTWN	Townhouse Building 1700	Apt 1702	Kitchen Sink	1	A	2.7	7/27/17										
PbTWN	Townhouse Building 1700	Apt 1702	Kitchen Sink	1	B	0.16	7/27/17										
PbTWN	Townhouse Building 1700	Apt 1702	Bathroom Sink 2nd floor	2	A	0.16	3/16/17										
PbTWN	Townhouse Building 1700	Apt 1702	Bathroom Sink 2nd floor	2	B	0.16	3/16/17										
PbTWN	Townhouse Building 1700	Apt 1702	Bathroom Sink 3rd floor	3	A	0.16	3/16/17										
PbTWN	Townhouse Building 1700	Apt 1702	Bathroom Sink 3rd floor	3	B	0.16	3/16/17										
PbTWN	Townhouse Building 1700	Apt 1702KN	Sink	2	A	3.2	1/4/17										
PbTWN	Townhouse Building 1700	Apt 1702KN	Sink	2	B	1.2	1/4/17										
PbTWN	Townhouse Building 1700	Apt 1703	Kitchen Sink	1	A	2.7	7/27/17										
PbTWN	Townhouse Building 1700	Apt 1703	Kitchen Sink	1	B	0.19	7/27/17										
PbTWN	Townhouse Building 1700	Apt 1703	Bathroom Sink 2nd floor	2	A	0.16	3/16/17										
PbTWN	Townhouse Building 1700	Apt 1703	Bathroom Sink 2nd floor	2	B	0.16	3/16/17										
PbTWN	Townhouse Building 1700	Apt 1703	Bathroom Sink 3rd floor	3	A	0.16	3/16/17										
PbTWN	Townhouse Building 1700	Apt 1703	Bathroom Sink 3rd floor	3	B	0.16	3/16/17										
PbTWN	Townhouse Building 1700	Apt 1704	Kitchen Sink	1	A	2.2	7/27/17										
PbTWN	Townhouse Building 1700	Apt 1704	Kitchen Sink	1	B	2.2	7/27/17										
PbTWN	Townhouse Building 1700	Apt 1704	Bathroom Sink 2nd floor	2	A	0.16	3/16/17										
PbTWN	Townhouse Building 1700	Apt 1704	Bathroom Sink 2nd floor	2	B	0.16	3/16/17										
PbTWN	Townhouse Building 1700	Apt 1704	Bathroom Sink 3rd floor	3	A	0.16	3/16/17										
PbTWN	Townhouse Building 1700	Apt 1704	Bathroom Sink 3rd floor	3	B	0.16	3/16/17										
PbTWN	Townhouse Building 1700	Apt 1705	Kitchen Sink	1	A	1.2	7/27/17										
PbTWN	Townhouse Building 1700	Apt 1705	Kitchen Sink	1	B	0.16	7/27/17										
PbTWN	Townhouse Building 1700	Apt 1705	Bathroom Sink 2nd floor	2	A	0.16	3/16/17	C	2.3	8/1/17							
PbTWN	Townhouse Building 1700	Apt 1705	Bathroom Sink 2nd floor	2	B	0.16	3/16/17	D	0.26	8/1/17							
PbTWN	Townhouse Building 1700	Apt 1705	Bathroom Sink 3rd floor	3	A	0.16	3/16/17										
PbTWN	Townhouse Building 1700	Apt 1705	Bathroom Sink 3rd floor	3	B	0.16	3/16/17										
PbTWN	Townhouse Building 1700	Apt 1706	Kitchen Sink	1	A	3.1	7/27/17										
PbTWN	Townhouse Building 1700	Apt 1706	Kitchen Sink	1	B	0.16	7/27/17										
PbTWN	Townhouse Building 1700	Apt 1706	Bathroom Sink 2nd floor	2	A	0.16	3/16/17										
PbTWN	Townhouse Building 1700	Apt 1706	Bathroom Sink 2nd floor	2	B	0.16	3/16/17										
PbTWN	Townhouse Building 1700	Apt 1706	Bathroom Sink 3rd floor	3	A	0.16	3/16/17										
PbTWN	Townhouse Building 1700	Apt 1706	Bathroom Sink 3rd floor	3	B	0.16	3/16/17										
PbTWN	Townhouse Building 1700	Apt 1707	Kitchen Sink	1	A	4.3	7/27/17										
PbTWN	Townhouse Building 1700	Apt 1707	Kitchen Sink	1	B	0.2	7/27/17										
PbTWN	Townhouse Building 1700	Apt 1707	Bathroom Sink 2nd floor	2	A	0.16	3/16/17										
PbTWN	Townhouse Building 1700	Apt 1707	Bathroom Sink 2nd floor	2	B	0.16	3/16/17										
PbTWN	Townhouse Building 1700	Apt 1707	Bathroom Sink 3rd floor	3	A	0.16	3/16/17										
PbTWN	Townhouse Building 1700	Apt 1707	Bathroom Sink 3rd floor	3	B	0.16	3/16/17										
PbTRI	Triad	Mech 001	backflow preventer	1	A	227	12/28/16										Although water tested at backflow preventer (where water first enters the building) shows a high concentation of lead, faucets throughout the buildings fall below the 15ppb threshold.

Sample ID	Building	Room/Location	Sample Location	Sample No.	Draw	Result (ug/L)	Date	Draw	Result (ug/L)	Date	Draw	Result (ug/L)	Date	Draw	Result (ug/L)	Date	Notes
PbTRI	Triad	Mech 001	backflow preventer	1	B	4.8	12/28/16										
PbTRI	Triad	Room B19KN	sink	2	A	4.1	12/28/16	C	0.16	3/17/17	E	3	8/16/17				
PbTRI	Triad	Room B19KN	sink	2	B	3.9	12/28/16	D	0.16	3/17/17	F	0.16	8/16/17				
PbTRI	Triad	Room B18KN	sink	3	A	1.1	12/28/16	C	0.16	3/17/17							
PbTRI	Triad	Room B18KN	sink	3	B	1.5	12/28/16	D	0.16	3/17/17							
PbTRI	Triad	Room B17KN	sink	4	A	0.75	12/28/16	C	0.16	3/17/17							
PbTRI	Triad	Room B17KN	sink	4	B	2.6	12/28/16	D	0.16	3/17/17							
PbTRI	Triad	Room B16KN	sink	5	A	3.1	12/28/16	C	0.16	3/17/17							
PbTRI	Triad	Room B16KN	sink	5	B	79	12/28/16	D	0.16	3/17/17							
PbTRI	Triad	Room B15KN	sink	6	A	13.5	12/28/16	C	0.16	3/17/17							
PbTRI	Triad	Room B15KN	sink	6	B	74.3	12/28/16	D	0.16	3/17/17							
PbTRI	Triad	Room B14KN	sink	7	A	0.91	12/28/16	C	0.16	3/17/17	E	0.79	8/16/17				
PbTRI	Triad	Room B14KN	sink	7	B	31	12/28/16	D	0.16	3/17/17	F	0.16	8/16/17				
PbTRI	Triad	Room B13KN	sink	8	A	1.1	12/28/16	C	0.16	3/17/17							
PbTRI	Triad	Room B13KN	sink	8	B	5.5	12/28/16	D	0.16	3/17/17							
PbTRI	Triad	Room B12KN	sink	9	B	10	12/28/16	C	0.16	3/17/17							
PbTRI	Triad	Room B12KN	sink	9	A	4.3	12/28/16	D	0.16	3/17/17							
PbTRI	Triad	Room B11KN	sink	10	A	0.53	12/28/16	C	0.16	3/17/17							
PbTRI	Triad	Room B11KN	sink	10	B	8.5	12/28/16	D	0.16	3/17/17							
PbTRI	Triad	Room S1/ 102	sink	11	A	0.79	12/28/16	C	0.16	3/17/17							
PbTRI	Triad	Room S1/ 102	sink	11	B	29.1	12/28/16	D	0.16	3/17/17							
PbTRI	Triad	Room C19KN	sink	12	A	6.8	12/28/16	C	0.16	3/17/17	E	3.3	8/16/17				
PbTRI	Triad	Room C19KN	sink	12	B	4.5	12/28/16	D	0.16	3/17/17	F	0.16	8/16/17				
PbTRI	Triad	Room C18KN	sink	13	A	0.38	12/28/16	C	0.16	3/17/17							
PbTRI	Triad	Room C18KN	sink	13	B	0.4	12/28/16	D	0.16	3/17/17							
PbTRI	Triad	Room C17KN	sink	14	A	1.3	12/28/16	C	0.16	3/17/17							
PbTRI	Triad	Room C17KN	sink	14	B	1.5	12/28/16	D	0.16	3/17/17							
PbTRI	Triad	Room C16KN	sink	15	A	0.88	12/28/16	C	0.16	3/17/17							
PbTRI	Triad	Room C16KN	sink	15	B	23.6	12/28/16	D	0.16	3/17/17							
PbTRI	Triad	Room C15KN	sink	16	A	0.68	12/28/16	C	0.16	3/17/17							
PbTRI	Triad	Room C15KN	sink	16	B	32.8	12/28/16	D	0.16	3/17/17							
PbTRI	Triad	Room C14KN	sink	17	A	0.64	12/28/16	C	0.16	3/17/17	E	3.2	8/16/17				
PbTRI	Triad	Room C14KN	sink	17	B	27.7	12/28/16	D	0.16	3/17/17	F	0.16	8/16/17				
PbTRI	Triad	Room C13KN	sink	18	A	5.3	12/28/16	C	0.16	3/17/17							
PbTRI	Triad	Room C13KN	sink	18	B	2.3	12/28/16	D	0.16	3/17/17							
PbTRI	Triad	Room C12KN	sink	19	A	0.53	12/28/16	C	0.16	3/17/17							
PbTRI	Triad	Room C12KN	sink	19	B	0.41	12/28/16	D	0.16	3/17/17							
PbTRI	Triad	Room C11KN	sink	20	A	10.5	12/28/16	C	0.16	3/17/17							
PbTRI	Triad	Room C11KN	sink	20	B	0.38	12/28/16	D	0.16	3/17/17							
PbTRI	Triad	Room A19KN	sink	21	A	1.8	12/28/16	C	0.16	3/17/17	E	2.3	8/16/17				
PbTRI	Triad	Room A19KN	sink	21	B	4	12/28/16	D	0.16	3/17/17	F	0.16	8/16/17				
PbTRI	Triad	Room A18KN	sink	22	A	0.75	12/28/16	C	0.16	3/17/17							
PbTRI	Triad	Room A18KN	sink	22	B	9	12/28/16	D	0.16	3/17/17							
PbTRI	Triad	Room A17KN	sink	23	A	2.1	12/28/16	C	0.16	3/17/17							
PbTRI	Triad	Room A17KN	sink	23	B	23.4	12/28/16	D	0.16	3/17/17							
PbTRI	Triad	Room A16KN	sink	24	A	1.7	12/28/16	C	0.16	3/17/17							
PbTRI	Triad	Room A16KN	sink	24	B	7.6	12/28/16	D	0.16	3/17/17							
PbTRI	Triad	Room A15KN	sink	25	A	1.1	12/28/16	C	0.16	3/17/17							
PbTRI	Triad	Room A15KN	sink	25	B	2.5	12/28/16	D	0.16	3/17/17							
PbTRI	Triad	Room A14KN	sink	26	A	0.51	12/28/16	C	0.16	3/17/17	E	0.62	8/16/17				
PbTRI	Triad	Room A14KN	sink	26	B	16.2	12/28/16	D	0.16	3/17/17	F	0.16	8/16/17				
PbTRI	Triad	Room A13KN	sink	27	A	1	12/28/16	C	0.16	3/17/17							
PbTRI	Triad	Room A13KN	sink	27	B	13.1	12/28/16	D	0.16	3/17/17							
PbTRI	Triad	Room A12KN	sink	28	A	1.2	12/28/16	C	0.16	3/17/17							
PbTRI	Triad	Room A12KN	sink	28	B	1	12/28/16	D	0.16	3/17/17							
PbTRI	Triad	Room A11KN	sink	29	A	7.4	12/28/16	C	0.16	3/17/17							
PbTRI	Triad	Room A11KN	sink	29	B	12.2	12/28/16	D	0.16	3/17/17							

Sample ID	Building	Room/Location	Sample Location	Sample No.	Draw	Result (ug/L)	Date	Draw	Result (ug/L)	Date	Draw	Result (ug/L)	Date	Draw	Result (ug/L)	Date	Notes
PbTRI	Triad	Room A29KN	sink	30	A	24.7	12/28/16	C	0.16	3/17/17	E	1.3	8/16/17				
PbTRI	Triad	Room A29KN	sink	30	B	5.1	12/28/16	D	0.16	3/17/17	F	0.16	8/16/17				
PbTRI	Triad	Room A28KN	sink	31	A	81.8	12/28/16	C	0.21	3/17/17							
PbTRI	Triad	Room A28KN	sink	31	B	11.4	12/28/16	D	0.16	3/17/17							
PbTRI	Triad	Room A27KN	sink	32	A	3.1	12/28/16	C	0.16	3/17/17							
PbTRI	Triad	Room A27KN	sink	32	B	6.9	12/28/16	D	0.16	3/17/17							
PbTRI	Triad	Room A26KN	sink	33	A	38.9	12/28/16	C	0.53	3/17/17							
PbTRI	Triad	Room A26KN	sink	33	B	3.3	12/28/16	D	0.16	3/17/17							
PbTRI	Triad	Room A25KN	sink	34	A	32.1	12/28/16	C	0.16	3/17/17							
PbTRI	Triad	Room A25KN	sink	34	B	35.4	12/28/16	D	0.16	3/17/17							
PbTRI	Triad	Room A24KN	sink	35	B	90.2	12/28/16	C	0.16	3/17/17							
PbTRI	Triad	Room A24KN	sink	35	A	64.9	12/28/16	D	0.16	3/17/17							
PbTRI	Triad	Room A23KN	sink	36	A	11.1	12/28/16	C	0.25	3/17/17	E	2.6	8/16/17				
PbTRI	Triad	Room A23KN	sink	36	B	3.4	12/28/16	D	0.16	3/17/17	F	0.17	8/16/17				
PbTRI	Triad	Room A22KN	sink	37	A	2	12/28/16	C	0.16	3/17/17							
PbTRI	Triad	Room A22KN	sink	37	B	2.7	12/28/16	D	0.16	3/17/17							
PbTRI	Triad	Room A21KN	sink	38	A	1.6	12/28/16	C	0.16	3/17/17							
PbTRI	Triad	Room A21KN	sink	38	B	3.3	12/28/16	D	0.18	3/17/17							
PbTRI	Triad	Room B29KN	sink	39	A	60.1	12/28/16	C	0.16	3/17/17	E	1.3	8/16/17				
PbTRI	Triad	Room B29KN	sink	39	B	2.9	12/28/16	D	0.16	3/17/17	F	0.16	8/16/17				
PbTRI	Triad	Room B28KN	sink	40	A	14	12/28/16	C	0.16	3/17/17							
PbTRI	Triad	Room B28KN	sink	40	B	1.5	12/28/16	D	0.16	3/17/17							
PbTRI	Triad	Room B27KN	sink	41	A	7.3	12/28/16	C	0.16	3/17/17							
PbTRI	Triad	Room B27KN	sink	41	B	4.7	12/28/16	D	0.16	3/17/17							
PbTRI	Triad	Room B26KN	sink	42	A	87.4	12/28/16	C	0.16	3/17/17							
PbTRI	Triad	Room B26KN	sink	42	B	3.7	12/28/16	D	0.16	3/17/17							
PbTRI	Triad	Room B25KN	sink	43	A	131	12/28/16	C	0.19	3/17/17							
PbTRI	Triad	Room B25KN	sink	43	B	19	12/28/16	D	0.16	3/17/17							
PbTRI	Triad	Room B24KN	sink	44	A	497	12/28/16	C	0.16	3/17/17	E	3.1	8/16/17				
PbTRI	Triad	Room B24KN	sink	44	B	82.2	12/28/16	D	0.16	3/17/17	F	0.16	8/16/17				
PbTRI	Triad	Room B23KN	sink	45	A	158	12/28/16	C	0.16	3/17/17							
PbTRI	Triad	Room B23KN	sink	45	B	11.5	12/28/16	D	0.16	3/17/17							
PbTRI	Triad	Room B22KN	sink	46	A	2.7	12/28/16	C	0.16	3/17/17							
PbTRI	Triad	Room B22KN	sink	46	B	51.9	12/28/16	D	0.16	3/17/17							
PbTRI	Triad	Room B21KN	sink	47	A	42.7	12/28/16	C	0.16	3/17/17							
PbTRI	Triad	Room B21KN	sink	47	B	1.5	12/28/16	D	0.16	3/17/17							
PbTRI	Triad	Room G2	sink	48	A	29.2	12/28/16	C	0.16	3/17/17							
PbTRI	Triad	Room G2	sink	48	B	11.5	12/28/16	D	0.16	3/17/17							
PbTRI	Triad	Room C21KN	sink	49	A	563	12/28/16	C	0.16	3/17/17	E	2.8	8/16/17				
PbTRI	Triad	Room C21KN	sink	49	B	30.1	12/28/16	D	0.16	3/17/17	F	0.16	8/16/17				
PbTRI	Triad	Room C22KN	sink	50	A	4.7	12/28/16	C	0.16	3/17/17							
PbTRI	Triad	Room C22KN	sink	50	B	6.3	12/28/16	D	0.16	3/17/17							
PbTRI	Triad	Room C23KN	sink	51	A	22.8	12/28/16	C	0.16	3/17/17							
PbTRI	Triad	Room C23KN	sink	51	B	7.2	12/28/16	D	0.16	3/17/17							
PbTRI	Triad	Room C24KN	sink	52	A	189	12/28/16	C	0.16	3/17/17							
PbTRI	Triad	Room C24KN	sink	52	B	30.8	12/28/16	D	0.16	3/17/17							
PbTRI	Triad	Room C25KN	sink	53	A	8.8	12/28/16	C	0.16	3/17/17	E	10	8/16/17				
PbTRI	Triad	Room C25KN	sink	53	B	3.4	12/28/16	D	0.16	3/17/17	F	0.16	8/16/17				
PbTRI	Triad	Room C26KN	sink	54	A	225	12/28/16	C	0.16	3/17/17							
PbTRI	Triad	Room C26KN	sink	54	B	3.5	12/28/16	D	0.16	3/17/17							
PbTRI	Triad	Room C27KN	sink	55	A	18.3	12/28/16	C	0.16	3/17/17							
PbTRI	Triad	Room C27KN	sink	55	B	3.3	12/28/16	D	0.16	3/17/17							
PbTRI	Triad	Room C28KN	sink	56	A	35.1	12/28/16	C	0.16	3/17/17							
PbTRI	Triad	Room C28KN	sink	56	B	1	12/28/16	D	0.16	3/17/17							
PbTRI	Triad	Room C29KN	sink	57	A	43.7	12/28/16	C	0.16	3/17/17							
PbTRI	Triad	Room C29KN	sink	57	B	0.84	12/28/16	D	0.16	3/17/17							
PbTRI	Triad	Room A39	sink	58	A	6.7	12/28/16	C	0.16	3/17/17	E	4.5	8/16/17				

Sample ID	Building	Room/Location	Sample Location	Sample No.	Draw	Result (ug/L)	Date	Draw	Result (ug/L)	Date	Draw	Result (ug/L)	Date	Draw	Result (ug/L)	Date	Notes
PbTRI	Triad	Room A39	sink	58	B	1.7	12/28/16	D	0.16	3/17/17	F	0.22	8/16/17				
PbTRI	Triad	Room A38	sink	59	A	242	12/28/16	C	0.16	3/17/17							
PbTRI	Triad	Room A38	sink	59	B	28.5	12/28/16	D	0.16	3/17/17							
PbTRI	Triad	Room A37	sink	60	A	23.4	12/28/16	C	0.16	3/17/17							
PbTRI	Triad	Room A37	sink	60	B	1.5	12/28/16	D	0.16	3/17/17							
PbTRI	Triad	Room A36	sink	61	A	2.8	12/28/16	C	0.16	3/17/17							
PbTRI	Triad	Room A36	sink	61	B	51.6	12/28/16	D	0.16	3/17/17							
PbTRI	Triad	Room A35	sink	62	A	37.5	12/28/16	C	0.16	3/17/17	E	7.8	8/16/17				
PbTRI	Triad	Room A35	sink	62	B	13.3	12/28/16	D	0.16	3/17/17	F	0.16	8/16/17				
PbTRI	Triad	Room A34	sink	63	A	133	12/28/16	C	0.16	3/17/17							
PbTRI	Triad	Room A34	sink	63	B	73.7	12/28/16	D	0.16	3/17/17							
PbTRI	Triad	Room A33	sink	64	A	72.7	12/28/16	C	0.16	3/17/17							
PbTRI	Triad	Room A33	sink	64	B	3.2	12/28/16	D	0.16	3/17/17							
PbTRI	Triad	Room A32	sink	65	A	18.9	12/28/16	C	0.2	3/17/17							
PbTRI	Triad	Room A32	sink	65	B	1	12/28/16	D	0.16	3/17/17							
PbTRI	Triad	Room A31	sink	66	A	7.7	12/28/16	C	0.16	3/17/17							
PbTRI	Triad	Room A31	sink	66	B	1.2	12/28/16	D	0.16	3/17/17							
PbTRI	Triad	Room B39	sink	67	A	183	12/28/16	C	0.16	3/17/17							
PbTRI	Triad	Room B39	sink	67	B	221	12/28/16	D	0.16	3/17/17							
PbTRI	Triad	Room B38	sink	68	A	224	12/28/16	C	0.16	3/17/17							
PbTRI	Triad	Room B38	sink	68	B	8.4	12/28/16	D	0.16	3/17/17							
PbTRI	Triad	Room B37	sink	69	A	50.3	12/28/16	C	0.16	3/17/17							
PbTRI	Triad	Room B37	sink	69	B	152	12/28/16	D	0.16	3/17/17							
PbTRI	Triad	Room B36	sink	70	A	273	12/28/16	C	0.16	3/17/17							
PbTRI	Triad	Room B36	sink	70	B	1210	12/28/16	D	0.16	3/17/17							
PbTRI	Triad	Room B35	sink	71	A	97.6	12/28/16	C	0.16	3/17/17	E	2	8/16/17				
PbTRI	Triad	Room B35	sink	71	B	180	12/28/16	D	0.16	3/17/17	F	0.16	8/16/17				
PbTRI	Triad	Room B34	sink	72	A	61.1	12/28/16	C	0.16	3/17/17							
PbTRI	Triad	Room B34	sink	72	B	95	12/28/16	D	0.16	3/17/17							
PbTRI	Triad	Room B33	sink	73	A	119	12/28/16	C	0.16	3/17/17							
PbTRI	Triad	Room B33	sink	73	B	15.6	12/28/16	D	0.16	3/17/17							
PbTRI	Triad	Room B32	sink	74	A	26	12/28/16	C	0.16	3/17/17							
PbTRI	Triad	Room B32	sink	74	B	6.7	12/28/16	D	0.16	3/17/17							
PbTRI	Triad	Room B31	sink	75	A	72.2	12/28/16	C	0.16	3/17/17	E	1.5	8/16/17				
PbTRI	Triad	Room B31	sink	75	B	3.5	12/28/16	D	0.16	3/17/17	F	0.16	8/16/17				
PbTRI	Triad	Room C39	sink	76	A	2840	12/28/16	C	0.16	3/17/17	E	6.4	8/16/17				
PbTRI	Triad	Room C39	sink	76	B	23.3	12/28/16	D	0.16	3/17/17	F	0.17	8/16/17				
PbTRI	Triad	Room C38	sink	77	A	37.2	12/28/16	C	0.16	3/17/17							
PbTRI	Triad	Room C38	sink	77	B	3.7	12/28/16	D	0.16	3/17/17							
PbTRI	Triad	Room C37	sink	78	A	28.6	12/28/16	C	0.16	3/17/17							
PbTRI	Triad	Room C37	sink	78	B	9.8	12/28/16	D	0.16	3/17/17							
PbTRI	Triad	Room C36	sink	79	A	30.7	12/28/16	C	0.16	3/17/17							
PbTRI	Triad	Room C36	sink	79	B	38.6	12/28/16	D	0.16	3/17/17							
PbTRI	Triad	Room C35	sink	80	A	36.8	12/28/16	C	0.16	3/17/17	E	3.4	8/16/17				
PbTRI	Triad	Room C35	sink	80	B	140	12/28/16	D	0.16	3/17/17	F	0.16	8/16/17				
PbTRI	Triad	Room C34	sink	81	A	161	12/28/16	C	0.16	3/17/17							
PbTRI	Triad	Room C34	sink	81	B	116	12/28/16	D	0.16	3/17/17							
PbTRI	Triad	Room C33	sink	82	A	248	12/28/16	C	0.16	3/17/17							
PbTRI	Triad	Room C33	sink	82	B	5.3	12/28/16	D	0.16	3/17/17							
PbTRI	Triad	Room C32	sink	83	A	5.8	12/28/16	C	0.16	3/17/17							
PbTRI	Triad	Room C32	sink	83	B	19.9	12/28/16	D	0.16	3/17/17							
PbTRI	Triad	Room C31	sink	84	A	325	12/28/16	C	0.21	3/17/17							
PbTRI	Triad	Room C31	sink	84	B	22.3	12/28/16	D	0.16	3/17/17							
PbTRI	Triad	Room S3	sink	85	A	6.4	12/28/16	C	0.16	3/17/17							
PbTRI	Triad	Room S3	sink	85	B	328	12/28/16	D	0.16	3/17/17							
PbTRI	Triad	Room A41	sink	86	A	839	12/28/16	C	0.16	3/17/17							
PbTRI	Triad	Room A41	sink	86	B	14.3	12/28/16	D	0.16	3/17/17							

Sample ID	Building	Room/Location	Sample Location	Sample No.	Draw	Result (ug/L)	Date	Draw	Result (ug/L)	Date	Draw	Result (ug/L)	Date	Draw	Result (ug/L)	Date	Notes
PbTRI	Triad	Room A49	sink	87	A	120	12/28/16	C	0.16	3/17/17	E	6.1	8/16/17				
PbTRI	Triad	Room A49	sink	87	B	50.9	12/28/16	D	0.16	3/17/17	F	0.19	8/16/17				
PbTRI	Triad	Room A42	sink	88	A	7.7	12/28/16	C	0.16	3/17/17							
PbTRI	Triad	Room A42	sink	88	B	13.6	12/28/16	D	0.16	3/17/17							
PbTRI	Triad	Room A48	sink	89	A	63.7	12/28/16	C	0.16	3/17/17							
PbTRI	Triad	Room A48	sink	89	B	86.2	12/28/16	D	0.16	3/17/17							
PbTRI	Triad	Room A43	sink	90	A	704	12/28/16	C	0.16	3/17/17							
PbTRI	Triad	Room A43	sink	90	B	136	12/28/16	D	0.16	3/17/17							
PbTRI	Triad	Room A47	sink	91	A	305	12/28/16	C	0.16	3/17/17							
PbTRI	Triad	Room A47	sink	91	B	88.1	12/28/16	D	0.16	3/17/17							
PbTRI	Triad	Room A44	sink	92	A	261	12/28/16	C	0.16	3/17/17	E	4.2	8/16/17				
PbTRI	Triad	Room A44	sink	92	B	153	12/28/16	D	0.16	3/17/17	F	0.21	8/16/17				
PbTRI	Triad	Room A46	sink	93	A	71.2	12/28/16	C	0.16	3/17/17							
PbTRI	Triad	Room A46	sink	93	B	2.5	12/28/16	D	0.16	3/17/17							
PbTRI	Triad	Room S-4	sink	94	A	99.8	12/28/16	C	0.16	3/17/17							
PbTRI	Triad	Room S-4	sink	94	B	98.2	12/28/16	D	0.16	3/17/17							
PbTRI	Triad	Room B41	sink	95	A	188	12/28/16	C	0.16	3/17/17	E	5.8	8/16/17				
PbTRI	Triad	Room B41	sink	95	B	5.1	12/28/16	D	0.16	3/17/17	F	0.16	8/16/17				
PbTRI	Triad	Room B49	sink	96	A	442	12/28/16	C	0.16	3/17/17							
PbTRI	Triad	Room B49	sink	96	B	9.8	12/28/16	D	0.16	3/17/17							
PbTRI	Triad	Room B48	sink	97	A	2070	12/28/16	C	0.16	3/17/17							
PbTRI	Triad	Room B48	sink	97	B	72.1	12/28/16	D	0.16	3/17/17							
PbTRI	Triad	Room B42	sink	98	A	32.3	12/28/16	C	0.16	3/17/17							
PbTRI	Triad	Room B42	sink	98	B	2.3	12/28/16	D	0.16	3/17/17							
PbTRI	Triad	Room B43	sink	99	A	67.8	12/28/16	C	0.16	3/17/17							
PbTRI	Triad	Room B43	sink	99	B	50.4	12/28/16	D	0.16	3/17/17							
PbTRI	Triad	Room B47	sink	100	A	75.6	12/28/16	C	0.16	3/17/17							
PbTRI	Triad	Room B47	sink	100	B	39.8	12/28/16	D	0.16	3/17/17							
PbTRI	Triad	Room B44	sink	101	A	154	12/28/16	C	0.16	3/17/17							
PbTRI	Triad	Room B44	sink	101	B	16.3	12/28/16	D	0.16	3/17/17							
PbTRI	Triad	Room B46	sink	102	A	165	12/28/16	C	0.16	3/17/17							
PbTRI	Triad	Room B46	sink	102	B	82.1	12/28/16	D	0.16	3/17/17							
PbTRI	Triad	Room B45	sink	103	A	70.8	12/28/16	C	0.16	3/17/17	E	5.1	8/16/17				
PbTRI	Triad	Room B45	sink	103	B	114	12/28/16	D	0.16	3/17/17	F	0.23	8/16/17				
PbTRI	Triad	Room C49	sink	104	A	26.6	12/28/16	C	0.16	3/17/17							
PbTRI	Triad	Room C49	sink	104	B	5.9	12/28/16	D	0.16	3/17/17							
PbTRI	Triad	Room C41	sink	105	A	327	12/28/16	C	0.16	3/17/17	E	7.6	8/16/17				
PbTRI	Triad	Room C41	sink	105	B	24	12/28/16	D	0.16	3/17/17	F	0.16	8/16/17				
PbTRI	Triad	Room C48	sink	106	A	45.8	12/28/16	C	0.16	3/17/17							
PbTRI	Triad	Room C48	sink	106	B	0.97	12/28/16	D	0.16	3/17/17							
PbTRI	Triad	Room C42	sink	107	A	75.7	12/28/16	C	0.16	3/17/17							
PbTRI	Triad	Room C42	sink	107	B	21.8	12/28/16	D	0.16	3/17/17							
PbTRI	Triad	Room C43	sink	108	A	119	12/28/16	C	0.16	3/17/17							
PbTRI	Triad	Room C43	sink	108	B	8.8	12/28/16	D	0.16	3/17/17							
PbTRI	Triad	Room C47	sink	109	A	34	12/28/16	C	0.16	3/17/17							
PbTRI	Triad	Room C47	sink	109	B	1.9	12/28/16	D	0.16	3/17/17							
PbTRI	Triad	Room C44	sink	110	A	232	12/28/16	C	0.16	3/17/17							
PbTRI	Triad	Room C44	sink	110	B	88.4	12/28/16	D	0.16	3/17/17							
PbTRI	Triad	Room C46	sink	111	A	192	12/28/16	C	0.16	3/17/17							
PbTRI	Triad	Room C46	sink	111	B	5.8	12/28/16	D	0.16	3/17/17							
PbTRI	Triad	Room G4	sink	112	A	646	12/28/16	C	0.16	3/17/17							
PbTRI	Triad	Room G4	sink	112	B	23.2	12/28/16	D	0.16	3/17/17							
PbTRI	Triad	Room A45	sink	113	A	418	12/28/16	C	0.16	3/17/17							
PbTRI	Triad	Room A45	sink	113	B	143	12/28/16	D	0.16	3/17/17							
PbTRI	Triad	Room B19BA	sink	114	A	0.16	3/17/17										
PbTRI	Triad	Room B19BA	sink	114	B	0.16	3/17/17										
PbTRI	Triad	Room B18BA	sink	115	A	0.16	3/17/17										

Sample ID	Building	Room/Location	Sample Location	Sample No.	Draw	Result (ug/L)	Date	Draw	Result (ug/L)	Date	Draw	Result (ug/L)	Date	Draw	Result (ug/L)	Date	Notes
PbTRI	Triad	Room B18BA	sink	115	B	0.16	3/17/17										
PbTRI	Triad	Room B17BA	sink	116	A	0.16	3/17/17										
PbTRI	Triad	Room B17BA	sink	116	B	0.16	3/17/17										
PbTRI	Triad	Room B16BA	sink	117	A	0.16	3/17/17										
PbTRI	Triad	Room B16BA	sink	117	B	0.16	3/17/17										
PbTRI	Triad	Room B15BA	sink	118	A	0.16	3/17/17										
PbTRI	Triad	Room B15BA	sink	118	B	0.16	3/17/17										
PbTRI	Triad	Room B14BA	sink	119	A	0.16	3/17/17										
PbTRI	Triad	Room B14BA	sink	119	B	0.16	3/17/17										
PbTRI	Triad	Room B13BA	sink	120	A	0.16	3/17/17										
PbTRI	Triad	Room B13BA	sink	120	B	0.16	3/17/17										
PbTRI	Triad	Room B12BA	sink	121	A	0.41	3/17/17										
PbTRI	Triad	Room B12BA	sink	121	B	0.16	3/17/17										
PbTRI	Triad	Room B11BA	sink	122	A	0.16	3/17/17										
PbTRI	Triad	Room B11BA	sink	122	B	0.16	3/17/17										
PbTRI	Triad	Room S1/ 102	sink	123	A	0.16	3/17/17										
PbTRI	Triad	Room S1/ 102	sink	123	B	0.16	3/17/17										
PbTRI	Triad	Room C19BA	sink	124	A	0.16	3/17/17										
PbTRI	Triad	Room C19BA	sink	124	B	0.16	3/17/17										
PbTRI	Triad	Room C18BA	sink	125	A	0.16	3/17/17										
PbTRI	Triad	Room C18BA	sink	125	B	0.16	3/17/17										
PbTRI	Triad	Room C17BA	sink	126	A	0.16	3/17/17										
PbTRI	Triad	Room C17BA	sink	126	B	0.16	3/17/17										
PbTRI	Triad	Room C16BA	sink	127	A	0.16	3/17/17										
PbTRI	Triad	Room C16BA	sink	127	B	0.16	3/17/17										
PbTRI	Triad	Room C15BA	sink	128	A	0.16	3/17/17										
PbTRI	Triad	Room C15BA	sink	128	B	0.16	3/17/17										
PbTRI	Triad	Room C14BA	sink	129	A	0.16	3/17/17										
PbTRI	Triad	Room C14BA	sink	129	B	0.16	3/17/17										
PbTRI	Triad	Room C14BA	sink	129	2A	0.16	3/17/17										
PbTRI	Triad	Room C14BA	sink	129	2B	0.16	3/17/17										
PbTRI	Triad	Room C13BA	sink	130	A	0.16	3/17/17										
PbTRI	Triad	Room C13BA	sink	130	B	0.16	3/17/17										
PbTRI	Triad	Room C12BA	sink	131	A	0.16	3/17/17										
PbTRI	Triad	Room C12BA	sink	131	B	0.16	3/17/17										
PbTRI	Triad	Room C11BA	sink	132	A	0.16	3/17/17										
PbTRI	Triad	Room C11BA	sink	132	B	0.16	3/17/17										
PbTRI	Triad	Room A19BA	sink	133	A	0.19	3/17/17										
PbTRI	Triad	Room A19BA	sink	133	B	0.16	3/17/17										
PbTRI	Triad	Room A18BA	sink	134	A	0.16	3/17/17										
PbTRI	Triad	Room A18BA	sink	134	B	0.16	3/17/17										
PbTRI	Triad	Room A17BA	sink	135	A	0.16	3/17/17										
PbTRI	Triad	Room A17BA	sink	135	B	0.16	3/17/17										
PbTRI	Triad	Room A16BA	sink	136	A	0.16	3/17/17										
PbTRI	Triad	Room A16BA	sink	136	B	0.16	3/17/17										
PbTRI	Triad	Room A15BA	sink	137	A	0.16	3/17/17										
PbTRI	Triad	Room A15BA	sink	137	B	0.16	3/17/17										
PbTRI	Triad	Room A14BA	sink	138	A	0.16	3/17/17										
PbTRI	Triad	Room A14BA	sink	138	B	0.16	3/17/17										
PbTRI	Triad	Room A14BA	sink	138	2A	0.17	3/17/17										
PbTRI	Triad	Room A14BA	sink	138	2B	0.16	3/17/17										
PbTRI	Triad	Room A13BA	sink	139	A	0.16	3/17/17										
PbTRI	Triad	Room A13BA	sink	139	B	0.16	3/17/17										
PbTRI	Triad	Room A12BA	sink	140	A	0.16	3/17/17										
PbTRI	Triad	Room A12BA	sink	140	B	0.16	3/17/17										
PbTRI	Triad	Room A11BA	sink	141	A	0.16	3/17/17										
PbTRI	Triad	Room A11BA	sink	141	B	0.16	3/17/17										

Sample ID	Building	Room/Location	Sample Location	Sample No.	Draw	Result (ug/L)	Date	Draw	Result (ug/L)	Date	Draw	Result (ug/L)	Date	Draw	Result (ug/L)	Date	Notes
PbTRI	Triad	Room A29BA	sink	142	A	0.16	3/17/17										
PbTRI	Triad	Room A29BA	sink	142	B	0.16	3/17/17										
PbTRI	Triad	Room A28BA	sink	143	A	0.16	3/17/17										
PbTRI	Triad	Room A28BA	sink	143	B	0.16	3/17/17										
PbTRI	Triad	Room A27BA	sink	144	A	0.16	3/17/17										
PbTRI	Triad	Room A27BA	sink	144	B	0.16	3/17/17										
PbTRI	Triad	Room A26BA	sink	145	A	0.16	3/17/17										
PbTRI	Triad	Room A26BA	sink	145	B	0.16	3/17/17										
PbTRI	Triad	Room A25BA	sink	146	A	0.16	3/17/17										
PbTRI	Triad	Room A25BA	sink	146	B	0.16	3/17/17										
PbTRI	Triad	Room A24BA	sink	147	A	0.16	3/17/17										
PbTRI	Triad	Room A24BA	sink	147	B	0.49	3/17/17										
PbTRI	Triad	Room A24BA	sink	147	2A	0.16	3/17/17										
PbTRI	Triad	Room A24BA	sink	147	2B	0.16	3/17/17										
PbTRI	Triad	Room A23BA	sink	148	A	0.26	3/17/17										
PbTRI	Triad	Room A23BA	sink	148	B	0.16	3/17/17										
PbTRI	Triad	Room A22BA	sink	149	A	0.16	3/17/17										
PbTRI	Triad	Room A22BA	sink	149	B	0.16	3/17/17										
PbTRI	Triad	Room A21BA	sink	150	A	0.16	3/17/17										
PbTRI	Triad	Room A21BA	sink	150	B	0.16	3/17/17										
PbTRI	Triad	Room B29BA	sink	151	A	0.16	3/17/17										
PbTRI	Triad	Room B29BA	sink	151	B	0.16	3/17/17										
PbTRI	Triad	Room B28BA	sink	152	A	0.16	3/17/17										
PbTRI	Triad	Room B28BA	sink	152	B	0.16	3/17/17										
PbTRI	Triad	Room B27BA	sink	153	A	0.16	3/17/17										
PbTRI	Triad	Room B27BA	sink	153	B	0.16	3/17/17										
PbTRI	Triad	Room B26BA	sink	154	A	0.16	3/17/17										
PbTRI	Triad	Room B26BA	sink	154	B	0.16	3/17/17										
PbTRI	Triad	Room B25BA	sink	155	A	0.16	3/17/17										
PbTRI	Triad	Room B25BA	sink	155	B	0.16	3/17/17										
PbTRI	Triad	Room B24BA	sink	156	A	0.16	3/17/17										
PbTRI	Triad	Room B24BA	sink	156	B	0.16	3/17/17										
PbTRI	Triad	Room B24BA	sink	156	2A	0.16	3/17/17										
PbTRI	Triad	Room B24BA	sink	156	2B	0.16	3/17/17										
PbTRI	Triad	Room B23BA	sink	157	A	0.16	3/17/17										
PbTRI	Triad	Room B23BA	sink	157	B	0.16	3/17/17										
PbTRI	Triad	Room B22BA	sink	158	A	0.16	3/17/17										
PbTRI	Triad	Room B22BA	sink	158	B	0.16	3/17/17										
PbTRI	Triad	Room B21BA	sink	159	A	0.16	3/17/17										
PbTRI	Triad	Room B21BA	sink	159	B	0.16	3/17/17										
PbTRI	Triad	Room G2	sink	160	A	0.16	3/17/17										
PbTRI	Triad	Room G2	sink	160	B	0.16	3/17/17										
PbTRI	Triad	Room C21BA	sink	161	A	0.16	3/17/17										
PbTRI	Triad	Room C21BA	sink	161	B	0.16	3/17/17										
PbTRI	Triad	Room C22BA	sink	162	A	0.16	3/17/17										
PbTRI	Triad	Room C22BA	sink	162	B	0.16	3/17/17										
PbTRI	Triad	Room C23BA	sink	163	A	0.16	3/17/17										
PbTRI	Triad	Room C23BA	sink	163	B	0.16	3/17/17										
PbTRI	Triad	Room C24BA	sink	164	A	0.16	3/17/17										
PbTRI	Triad	Room C24BA	sink	164	B	0.16	3/17/17										
PbTRI	Triad	Room C24BA	sink	164	2A	0.16	3/17/17										
PbTRI	Triad	Room C24BA	sink	164	2B	0.16	3/17/17										
PbTRI	Triad	Room C25BA	sink	165	A	0.16	3/17/17										
PbTRI	Triad	Room C25BA	sink	165	B	0.16	3/17/17										
PbTRI	Triad	Room C26BA	sink	166	A	0.16	3/17/17										
PbTRI	Triad	Room C26BA	sink	166	B	0.16	3/17/17										
PbTRI	Triad	Room C27BA	sink	167	A	0.16	3/17/17										

Sample ID	Building	Room/Location	Sample Location	Sample No.	Draw	Result (ug/L)	Date	Draw	Result (ug/L)	Date	Draw	Result (ug/L)	Date	Draw	Result (ug/L)	Date	Notes
PbTRI	Triad	Room C27BA	sink	167	B	0.16	3/17/17										
PbTRI	Triad	Room C28BA	sink	168	A	0.16	3/17/17										
PbTRI	Triad	Room C28BA	sink	168	B	0.16	3/17/17										
PbTRI	Triad	Room C29BA	sink	169	A	0.16	3/17/17										
PbTRI	Triad	Room C29BA	sink	169	B	0.16	3/17/17										
PbTRI	Triad	Room A39	sink	170	A	0.16	3/17/17										
PbTRI	Triad	Room A39	sink	170	B	0.16	3/17/17										
PbTRI	Triad	Room A38	sink	171	A	0.16	3/17/17										
PbTRI	Triad	Room A38	sink	171	B	0.16	3/17/17										
PbTRI	Triad	Room A37	sink	172	A	0.16	3/17/17										
PbTRI	Triad	Room A37	sink	172	B	0.16	3/17/17										
PbTRI	Triad	Room A36	sink	173	A	0.16	3/17/17										
PbTRI	Triad	Room A36	sink	173	B	0.16	3/17/17										
PbTRI	Triad	Room A35	sink	174	A	0.16	3/17/17										
PbTRI	Triad	Room A35	sink	174	B	0.16	3/17/17										
PbTRI	Triad	Room A34	sink	175	A	0.16	3/17/17										
PbTRI	Triad	Room A34	sink	175	B	0.16	3/17/17										
PbTRI	Triad	Room A34	sink	175	2A	0.17	3/17/17										
PbTRI	Triad	Room A34	sink	175	2B	0.16	3/17/17										
PbTRI	Triad	Room A33	sink	176	A	0.16	3/17/17										
PbTRI	Triad	Room A33	sink	176	B	0.16	3/17/17										
PbTRI	Triad	Room A32	sink	177	A	0.16	3/17/17										
PbTRI	Triad	Room A32	sink	177	B	0.16	3/17/17										
PbTRI	Triad	Room A31	sink	178	A	0.16	3/17/17										
PbTRI	Triad	Room A31	sink	178	B	0.16	3/17/17										
PbTRI	Triad	Room B39	sink	179	A	0.16	3/17/17										
PbTRI	Triad	Room B39	sink	179	B	0.16	3/17/17										
PbTRI	Triad	Room B38	sink	180	A	0.16	3/17/17										
PbTRI	Triad	Room B38	sink	180	B	0.16	3/17/17										
PbTRI	Triad	Room B38	sink	180	B	0.16	3/17/17										
PbTRI	Triad	Room B37	sink	181	A	0.16	3/17/17										
PbTRI	Triad	Room B37	sink	181	B	0.16	3/17/17										
PbTRI	Triad	Room B36	sink	182	A	0.16	3/17/17										
PbTRI	Triad	Room B36	sink	182	B	0.16	3/17/17										
PbTRI	Triad	Room B35	sink	183	A	0.16	3/17/17										
PbTRI	Triad	Room B35	sink	183	B	0.16	3/17/17										
PbTRI	Triad	Room B34	sink	184	A	0.16	3/17/17										
PbTRI	Triad	Room B34	sink	184	B	0.16	3/17/17										
PbTRI	Triad	Room B34	sink	184	2A	0.16	3/17/17										
PbTRI	Triad	Room B34	sink	184	2B	0.16	3/17/17										
PbTRI	Triad	Room B33	sink	185	A	0.16	3/17/17										
PbTRI	Triad	Room B33	sink	185	B	0.16	3/17/17										
PbTRI	Triad	Room B32	sink	186	A	0.16	3/17/17										
PbTRI	Triad	Room B32	sink	186	B	0.16	3/17/17										
PbTRI	Triad	Room B31	sink	187	A	0.16	3/17/17										
PbTRI	Triad	Room B31	sink	187	B	0.16	3/17/17										
PbTRI	Triad	Room C39	sink	188	A	0.16	3/17/17										
PbTRI	Triad	Room C39	sink	188	B	0.16	3/17/17										
PbTRI	Triad	Room C38	sink	189	A	0.16	3/17/17										
PbTRI	Triad	Room C38	sink	189	B	0.16	3/17/17										
PbTRI	Triad	Room C37	sink	190	A	0.16	3/17/17										
PbTRI	Triad	Room C37	sink	190	B	0.16	3/17/17										
PbTRI	Triad	Room C36	sink	191	A	0.16	3/17/17										
PbTRI	Triad	Room C36	sink	191	B	0.16	3/17/17										
PbTRI	Triad	Room C35	sink	192	A	0.16	3/17/17										
PbTRI	Triad	Room C35	sink	192	B	0.16	3/17/17										
PbTRI	Triad	Room C34	sink	193	A	0.16	3/17/17										
PbTRI	Triad	Room C34	sink	193	B	0.16	3/17/17										

Sample ID	Building	Room/Location	Sample Location	Sample No.	Draw	Result (ug/L)	Date	Draw	Result (ug/L)	Date	Draw	Result (ug/L)	Date	Draw	Result (ug/L)	Date	Notes
PbTRI	Triad	Room C34	sink	193	2A	0.16	3/17/17										
PbTRI	Triad	Room C34	sink	193	2B	0.16	3/17/17										
PbTRI	Triad	Room C33	sink	194	A	0.16	3/17/17										
PbTRI	Triad	Room C33	sink	194	B	0.16	3/17/17										
PbTRI	Triad	Room C32	sink	195	A	0.16	3/17/17										
PbTRI	Triad	Room C32	sink	195	B	0.16	3/17/17										
PbTRI	Triad	Room C31	sink	196	A	0.16	3/17/17										
PbTRI	Triad	Room C31	sink	196	B	0.16	3/17/17										
PbTRI	Triad	Room S3	sink	197	A	0.16	3/17/17										
PbTRI	Triad	Room S3	sink	197	B	0.16	3/17/17										
PbTRI	Triad	Room A41	sink	198	A	0.16	3/17/17										
PbTRI	Triad	Room A41	sink	198	B	0.16	3/17/17										
PbTRI	Triad	Room A49	sink	199	A	0.16	3/17/17										
PbTRI	Triad	Room A49	sink	199	B	0.16	3/17/17										
PbTRI	Triad	Room A42	sink	200	A	0.16	3/17/17										
PbTRI	Triad	Room A42	sink	200	B	0.16	3/17/17										
PbTRI	Triad	Room A48	sink	201	A	0.16	3/17/17										
PbTRI	Triad	Room A48	sink	201	B	0.16	3/17/17										
PbTRI	Triad	Room A43	sink	202	A	0.16	3/17/17										
PbTRI	Triad	Room A43	sink	202	B	0.16	3/17/17										
PbTRI	Triad	Room A47	sink	203	A	0.16	3/17/17										
PbTRI	Triad	Room A47	sink	203	B	0.16	3/17/17										
PbTRI	Triad	Room A44	sink	204	A	0.16	3/17/17										
PbTRI	Triad	Room A44	sink	204	B	0.16	3/17/17										
PbTRI	Triad	Room A44	sink	204	2A	0.16	3/17/17										
PbTRI	Triad	Room A44	sink	204	2B	0.16	3/17/17										
PbTRI	Triad	Room A46	sink	205	A	0.16	3/17/17										
PbTRI	Triad	Room A46	sink	205	B	0.16	3/17/17										
PbTRI	Triad	Room S-4	sink	206	A	0.16	3/17/17										
PbTRI	Triad	Room S-4	sink	206	B	0.16	3/17/17										
PbTRI	Triad	Room B41	sink	207	A	0.16	3/17/17										
PbTRI	Triad	Room B41	sink	207	B	0.16	3/17/17										
PbTRI	Triad	Room B49	sink	208	A	0.16	3/17/17										
PbTRI	Triad	Room B49	sink	208	B	0.16	3/17/17										
PbTRI	Triad	Room B48	sink	209	A	0.16	3/17/17										
PbTRI	Triad	Room B48	sink	209	B	0.16	3/17/17										
PbTRI	Triad	Room B42	sink	210	A	0.16	3/17/17										
PbTRI	Triad	Room B42	sink	210	B	0.16	3/17/17										
PbTRI	Triad	Room B43	sink	211	A	0.16	3/17/17										
PbTRI	Triad	Room B43	sink	211	B	0.16	3/17/17										
PbTRI	Triad	Room B47	sink	212	A	0.16	3/17/17										
PbTRI	Triad	Room B47	sink	212	B	0.16	3/17/17										
PbTRI	Triad	Room B44	sink	213	A	0.16	3/17/17										
PbTRI	Triad	Room B44	sink	213	B	0.16	3/17/17										
PbTRI	Triad	Room B44	sink (adj to KN)	214	2A	0.16	3/17/17										
PbTRI	Triad	Room B44	sink (adj to KN)	215	2B	0.16	3/17/17										
PbTRI	Triad	Room B46	sink	214	A	0.16	3/17/17										
PbTRI	Triad	Room B46	sink	214	B	0.16	3/17/17										
PbTRI	Triad	Room B45	sink	215	A	0.16	3/17/17										
PbTRI	Triad	Room B45	sink	215	B	0.16	3/17/17										
PbTRI	Triad	Room C49	sink	216	A	0.16	3/17/17										
PbTRI	Triad	Room C49	sink	216	B	0.16	3/17/17										
PbTRI	Triad	Room C41	sink	217	A	0.16	3/17/17										
PbTRI	Triad	Room C41	sink	217	B	0.16	3/17/17										
PbTRI	Triad	Room C48	sink	218	A	0.16	3/17/17										
PbTRI	Triad	Room C48	sink	218	B	0.16	3/17/17										
PbTRI	Triad	Room C42	sink	219	A	0.16	3/17/17										

Sample ID	Building	Room/Location	Sample Location	Sample No.	Draw	Result (ug/L)	Date	Draw	Result (ug/L)	Date	Draw	Result (ug/L)	Date	Draw	Result (ug/L)	Date	Notes
PbTRI	Triad	Room C42	sink	219	B	0.16	3/17/17										
PbTRI	Triad	Room C43	sink	220	A	0.16	3/17/17										
PbTRI	Triad	Room C43	sink	220	B	0.16	3/17/17										
PbTRI	Triad	Room C47	sink	221	A	0.16	3/17/17										
PbTRI	Triad	Room C47	sink	221	B	0.16	3/17/17										
PbTRI	Triad	Room C44	sink	222	A	0.16	3/17/17										
PbTRI	Triad	Room C44	sink	222	B	0.16	3/17/17										
PbTRI	Triad	Room C46	sink	223	A	0.16	3/17/17										
PbTRI	Triad	Room C46	sink	223	B	0.16	3/17/17										
PbTRI	Triad	Room G4	sink	224	A	0.16	3/17/17										
PbTRI	Triad	Room G4	sink	224	B	0.16	3/17/17										
PbTRI	Triad	Room A45	sink	225	A	0.16	3/17/17										
PbTRI	Triad	Room A45	sink	225	B	0.16	3/17/17										
PbTRI	Triad	Room C45	sink	226	A	0.16	3/17/17	C	4.5	8/16/17							
PbTRI	Triad	Room C45	sink	226	B	0.16	3/17/17	D	0.26	8/16/17							
PbTRI	Triad	Room G3	sink	227	A	0.19	3/17/17										
PbTRI	Triad	Room G3	sink	227	B	0.16	3/17/17										
PbWES	Westby	Room 014	water fountain	2	A	0.26	11/3/16										
PbWES	Westby	Room 014	water fountain	2	B	0.16	11/3/16										
PbWES	Westby	Room 208A	water fountain	3	A	0.16	11/3/16										
PbWES	Westby	Room 208A	water fountain	3	B	0.16	11/3/16										
PbWES	Westby	Room 207G	sink	4	A	3.8	11/3/16										
PbWES	Westby	Room 207G	sink	4	B	1.1	11/3/16										
PbWIW	Willow Hall	Room 108BA	sink	2	A	24.6	1/5/17	C	0.16	3/13/17	E	1.6	8/1/17				
PbWIW	Willow Hall	Room 108BA	sink	2	B	21.1	1/5/17	D	0.16	3/13/17	F	2.2	8/1/17				
PbWIW	Willow Hall	Room 106BA	sink	3	A	2.7	1/5/17	C	0.16	3/13/17							
PbWIW	Willow Hall	Room 106BA	sink	3	B	4.4	1/5/17	D	0.16	3/13/17							
PbWIW	Willow Hall	Room 105BA	sink	4	A	4.9	1/5/17	C	0.16	3/13/17							
PbWIW	Willow Hall	Room 105BA	sink	4	B	2.2	1/5/17	D	0.16	3/13/17							
PbWIW	Willow Hall	Room 104BA	sink	5	A	10.4	1/5/17	C	0.16	3/13/17							
PbWIW	Willow Hall	Room 104BA	sink	5	B	3	1/5/17	D	0.16	3/13/17							
PbWIW	Willow Hall	Room103BA	sink	6	A	10.5	1/5/17	C	0.16	3/13/17							
PbWIW	Willow Hall	Room103BA	sink	6	B	2.6	1/5/17	D	0.16	3/13/17							
PbWIW	Willow Hall	Room 102BA	sink	7	A	9.5	1/5/17	C	0.16	3/13/17							
PbWIW	Willow Hall	Room 102BA	sink	7	B	6.1	1/5/17	D	0.16	3/13/17							
PbWIW	Willow Hall	Room 101BA	sink	8	A	2.4	1/5/17	C	0.16	3/13/17							
PbWIW	Willow Hall	Room 101BA	sink	8	B	0.66	1/5/17	D	0.16	3/13/17							
PbWIW	Willow Hall	Room 100BA	sink	9	B	6.7	1/5/17	C	0.16	3/13/17							
PbWIW	Willow Hall	Room 100BA	sink	9	A	73.6	1/5/17	D	0.16	3/13/17							
PbWIW	Willow Hall	Room 207BA	sink	10	A	8.6	1/5/17	C	0.16	3/13/17							
PbWIW	Willow Hall	Room 207BA	sink	10	B	11.6	1/5/17	D	0.16	3/13/17							
PbWIW	Willow Hall	Room 206BA	sink	11	A	21.3	1/5/17	C	0.16	3/13/17							
PbWIW	Willow Hall	Room 206BA	sink	11	B	6.1	1/5/17	D	0.16	3/13/17							
PbWIW	Willow Hall	Room 205BA	sink	12	A	320	1/5/17	C	0.16	3/13/17	E	2	8/1/17				
PbWIW	Willow Hall	Room 205BA	sink	12	B	31.5	1/5/17	D	0.16	3/13/17	F	0.21	8/1/17				
PbWIW	Willow Hall	Room 204BA	sink	13	A	17.1	1/5/17	C	0.16	3/13/17							
PbWIW	Willow Hall	Room 204BA	sink	13	B	1.7	1/5/17	D	0.16	3/13/17							
PbWIW	Willow Hall	Room 203BA	sink	14	A	14.8	1/5/17	C	0.16	3/13/17							
PbWIW	Willow Hall	Room 203BA	sink	14	B	1.4	1/5/17	D	0.16	3/13/17							
PbWIW	Willow Hall	Room 202BA	sink	15	A	20.7	1/5/17	C	0.16	3/13/17							
PbWIW	Willow Hall	Room 202BA	sink	15	B	2.6	1/5/17	D	0.16	3/13/17							
PbWIW	Willow Hall	Room 201BA	sink	16	A	29	1/5/17	C	0.16	3/13/17							
PbWIW	Willow Hall	Room 201BA	sink	16	B	1.4	1/5/17	D	0.16	3/13/17							
PbWIW	Willow Hall	Room 200BA	sink	17	A	6.7	1/5/17	C	0.16	3/13/17							
PbWIW	Willow Hall	Room 200BA	sink	17	B	0.6	1/5/17	D	0.16	3/13/17							

Sample ID	Building	Room/Location	Sample Location	Sample No.	Draw	Result (ug/L)	Date	Draw	Result (ug/L)	Date	Draw	Result (ug/L)	Date	Draw	Result (ug/L)	Date	Notes
PbWIW	Willow Hall	Room 307BA	sink	18	A	13.7	1/5/17	C	0.16	3/13/17							
PbWIW	Willow Hall	Room 307BA	sink	18	B	301	1/5/17	D	0.16	3/13/17							
PbWIW	Willow Hall	Room 306BA	sink	19	A	4.1	1/5/17	C	0.16	3/13/17							
PbWIW	Willow Hall	Room 306BA	sink	19	B	7.1	1/5/17	D	0.16	3/13/17							
PbWIW	Willow Hall	Room 305BA	sink	20	A	7.9	1/5/17	C	0.16	3/13/17							
PbWIW	Willow Hall	Room 305BA	sink	20	B	3.8	1/5/17	D	0.16	3/13/17							
PbWIW	Willow Hall	Room 304BA	sink	21	A	7.1	1/5/17	C	0.16	3/13/17							
PbWIW	Willow Hall	Room 304BA	sink	21	B	2.1	1/5/17	D	0.16	3/13/17							
PbWIW	Willow Hall	Room 303BA	sink	22	A	42.9	1/5/17	C	0.16	3/13/17							
PbWIW	Willow Hall	Room 303BA	sink	22	B	0.91	1/5/17	D	0.16	3/13/17							
PbWIW	Willow Hall	Room 302BA	sink	23	A	18.8	1/5/17	C	0.16	3/13/17							
PbWIW	Willow Hall	Room 302BA	sink	23	B	39.5	1/5/17	D	0.16	3/13/17							
PbWIW	Willow Hall	Room 301BA	sink	24	A	4.4	1/5/17	C	0.16	3/13/17							
PbWIW	Willow Hall	Room 301BA	sink	24	B	0.73	1/5/17	D	0.16	3/13/17							
PbWIW	Willow Hall	Room 300BA	sink	25	A	10,100	1/5/17	C	0.16	3/13/17	E	2	8/1/17				
PbWIW	Willow Hall	Room 300BA	sink	25	B	297	1/5/17	D	0.16	3/13/17	F	0.27	8/1/17				
PbWIW	Willow Hall	Room 145KN	sink	26	A	0.26	1/5/17										
PbWIW	Willow Hall	Room 145KN	sink	26	B	0.16	1/5/17										
PbWIL	Wilson Hall	Room 155	Water Fountain	2	A	0.09	11/8/16										
PbWIL	Wilson Hall	Room 155	Water Fountain	2	B	0.09	11/8/16										
PbWIL	Wilson Hall	Room 154	Sink	3	A	2	11/8/16										
PbWIL	Wilson Hall	Room 154	Sink	3	B	0.95	11/8/16										
PbWIL	Wilson Hall	Room 154	Water Line	4	A	1.1	11/8/16										
PbWIL	Wilson Hall	Room 154	Water Line	4	B	0.5	11/8/16										
PbWIL	Wilson Hall	Room L102	Water Fountain	5	A	0.11	11/8/16										
PbWIL	Wilson Hall	Room L102	Water Fountain	5	B	0.23	11/8/16										
PbWIL	Wilson Hall	Room L101	Water Fountain	6	A	0.1	11/8/16										
PbWIL	Wilson Hall	Room L101	Water Fountain	6	B	0.09	11/8/16										
PbWIL	Wilson Hall	Room L100	Water Fountain	7	A	0.09	11/8/16										
PbWIL	Wilson Hall	Room L100	Water Fountain	7	B	0.09	11/8/16										
PbWIL	Wilson Hall	Room 103B	Sink	8	A	20.8	11/8/16	C	2	2/28/17							
PbWIL	Wilson Hall	Room 103B	Sink	8	B	0.89	11/8/16	D	0.16	2/28/17							
PbWIL	Wilson Hall	Room 107A	Sink	9	A	37.6	11/8/16	C	0.16	2/28/17							
PbWIL	Wilson Hall	Room 107A	Sink	9	B	4.2	11/8/16	D	0.16	2/28/17							
PbWIL	Wilson Hall	Room R114	Water Fountain	10	A	0.09	11/8/16										
PbWIL	Wilson Hall	Room R114	Water Fountain	10	B	0.09	11/8/16										
PbWIN	Winans Hall	Room 126	sink	2	A	0.57	11/15/16										
PbWIN	Winans Hall	Room 126	sink	2	B	0.2	11/15/16										
PbWIN	Winans Hall	Room 156	sink	3	A	0.52	11/15/16										
PbWIN	Winans Hall	Room 156	sink	3	B	0.17	11/15/16										
PbWIN	Winans Hall	Room 156	ice machine	4	A	47.8	11/15/16	C	10.2	2/23/17							
PbWIN	Winans Hall	Room 156	ice machine	4	B	0.16	11/15/16	D	1.4	2/23/17							
PbWIN	Winans Hall	Room 101	water fountain	5	A	0.16	11/15/16										
PbWIN	Winans Hall	Room 101	water fountain	5	B	0.16	11/15/16										